

# HIGHWAY WORK PROPOSAL

Wisconsin Department of Transportation  
DT1502 10/2010 s.66.29(7) Wis. Stats.

Proposal Number:

14

<u>COUNTY</u>	<u>STATE PROJECT ID</u>	<u>FEDERAL PROJECT ID</u>	<u>PROJECT DESCRIPTION</u>	<u>HIGHWAY</u>
Ashland	1181-11-70		C Ashland, Lake Shore Drive 29th Avenue to 36th Avenue	USH 2

This proposal, submitted by the undersigned bidder to the Wisconsin Department of Transportation, is in accordance with the advertised request for proposals. The bidder is to furnish and deliver all materials, and to perform all work for the improvement of the designated project in the time specified, in accordance with the appended Proposal Requirements and Conditions.

Proposal Guaranty Required, \$ 75,000.00 Payable to: Wisconsin Department of Transportation	Attach Proposal Guaranty on back of this PAGE.
Bid Submittal Due  Date: November 11, 2014 Time (Local Time): 9:00 AM	Firm Name, Address, City, State, Zip Code
Contract Completion Time  July 10, 2015	<b>SAMPLE</b> <b>NOT FOR BIDDING PURPOSES</b>
Assigned Disadvantaged Business Enterprise Goal  0%	This contract is exempt from federal oversight.

This certifies that the undersigned bidder, duly sworn, is an authorized representative of the firm named above; that the bidder has examined and carefully prepared the bid from the plans, Highway Work Proposal, and all addenda, and has checked the same in detail before submitting this proposal or bid; and that the bidder or agents, officer, or employees have not, either directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken any action in restraint of free competitive bidding in connection with this proposal bid.

**Do not sign, notarize, or submit this Highway Work Proposal when submitting an electronic bid on the Internet.**

Subscribed and sworn to before me this date \_\_\_\_\_

\_\_\_\_\_  
(Signature, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Print or Type Name, Notary Public, State Wisconsin)

\_\_\_\_\_  
(Date Commission Expires)

Notary Seal

\_\_\_\_\_  
(Bidder Signature)

\_\_\_\_\_  
(Print or Type Bidder Name)

\_\_\_\_\_  
(Bidder Title)

## For Department Use Only

Type of Work Culvert replacement, storm sewer, grading, base aggregate dense, concrete pavement, curb and gutter, beam guard, pavement marking, permanent signing, water main work.	
Notice of Award Dated	Date Guaranty Returned

**PLEASE ATTACH  
PROPOSAL GUARANTY HERE**

**Effective with November 2007 Letting**

**PROPOSAL REQUIREMENTS AND CONDITIONS**

The bidder, signing and submitting this proposal, agrees and declares as a condition thereof, to be bound by the following conditions and requirements.

If the bidder has a corporate relationship with the proposal design engineering company, the bidder declares that it did not obtain any facts, data, or other information related to this proposal from the design engineering company that was not available to all bidders.

The bidder declares that they have carefully examined the site of, and the proposal, plans, specifications and contract forms for the work contemplated, and it is assumed that the bidder has investigated and is satisfied as to the conditions to be encountered, as to the character, quality, and quantities of work to be performed and materials to be furnished, and as to the requirements of the specifications, special provisions and contract. It is mutually agreed that submission of a proposal shall be considered conclusive evidence that the bidder has made such examination.

The bidder submits herewith a proposal guaranty in proper form and amount payable to the party as designated in the advertisement inviting proposals, to be retained by and become the property of the owner of the work in the event the undersigned shall fail to execute the contract and contract bond and return the same to the office of the engineer within fourteen (14) days after having been notified in writing to do so; otherwise to be returned.

The bidder declares that they understand that the estimate of quantities in the attached schedule is approximate only and that the attached quantities may be greater or less in accordance with the specifications.

The bidder agrees to perform the said work, for and in consideration of the payment of the amount becoming due on account of work performed, according to the unit prices bid in the following schedule, and to accept such amounts in full payment of said work.

The bidder declares that all of the said work will be performed at their own proper cost and expense, that they will furnish all necessary materials, labor, tools, machinery, apparatus, and other means of construction in the manner provided in the applicable specifications and the approved plans for the work together with all standard and special designs that may be designed on such plans, and the special provisions in the contract of which this proposal will become a part, if and when accepted. The bidder further agrees that the applicable specifications and all plans and working drawings are made a part hereof, as fully and completely as if attached hereto.

The bidder, if awarded the contract, agrees to begin the work not later than ten (10) days after the date of written notification from the engineer to do so, unless otherwise stipulated in the special provisions.

The bidder declares that if they are awarded the contract, they will execute the contract agreement and begin and complete the work within the time named herein, and they will file a good and sufficient surety bond for the amount of the contract for performance and also for the full amount of the contract for payment.

The bidder, if awarded the contract, shall pay all claims as required by Section 779.14, Statutes of Wisconsin, and shall be subject to and discharge all liabilities for injuries pursuant to Chapter 102 of the Statutes of Wisconsin, and all acts amendatory thereto. They shall further be responsible for any damages to property or injury to persons occurring through their own negligence or that of their employees or agents, incident to the performance of work under this contract, pursuant to the Standard Specifications for Road and Bridge Construction applicable to this contract.

In connection with the performance of work under this contract, the contractor agrees to comply with all applicable state and federal statutes relating to non-discrimination in employment. No otherwise qualified person shall be excluded from employment or otherwise be subject to discrimination in employment in any manner on the basis of age, race, religion, color, gender, national origin or ancestry, disability, arrest or conviction record (in keeping with s.111.32), sexual orientation, marital status, membership in the military reserve, honesty testing, genetic testing, and outside use of lawful products. This provision shall include, but not be limited to the following: employment, upgrading, demotion or transfer; recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation, and selection for training, including apprenticeship. The contractor further agrees to ensure equal opportunity in employment to all applicants and employees and to take affirmative action to attain a representative workforce.

The contractor agrees to post notices and posters setting forth the provisions of the nondiscrimination clause, in a conspicuous and easily accessible place, available for employees and applicants for employment.

If a state public official (section 19.42, Stats.) or an organization in which a state public official holds at least a 10% interest is a party to this agreement, this contract is voidable by the state unless appropriate disclosure is made to the State of Wisconsin Ethics Board.

## BID PREPARATION

### Preparing the Proposal Schedule of Items

#### A General

- (1) Obtain bidding proposals as specified in **section 102** of the standard specifications prior to 11:45 AM of the last business day preceding the letting. Submit bidding proposals using one of the following methods:
  1. Electronic bid on the internet.
  2. Electronic bid on a printout with accompanying diskette or CD ROM.
  3. Paper bid under a waiver of the electronic submittal requirements.
- (2) Bids submitted on a printout with accompanying diskette or CD ROM or paper bids submitted under a waiver of the electronic submittal requirements govern over bids submitted on the internet.
- (3) The department will provide bidding information through the department's web site at <http://www.dot.wisconsin.gov/business/engrserv/bid-letting-information.htm>. The contractor is responsible for reviewing this web site for general notices as well as information regarding proposals in each letting. The department will also post special notices of all addenda to each proposal through this web site no later than 4:00 P.M. local time on the Thursday before the letting. Check the department's web site after 5:00 P.M. local time on the Thursday before the letting to ensure all addenda have been accounted for before preparing the bid. When bidding using methods 1 and 2 above, check the Bid Express™ on-line bidding exchange at <http://www.bidx.com/> after 5:00 P.M. local time on the Thursday before the letting to ensure that the latest schedule of items Expedite file (\*.ebs or \*.00x) is used to submit the final bid.
- (4) Interested parties can subscribe to the Bid Express™ on-line bidding exchange by following the instructions provided at the [www.bidx.com](http://www.bidx.com) web site or by contacting:

Info Tech Inc.  
5700 SW 34th Street, Suite 1235  
Gainesville, FL 32608-5371  
email: <mailto:customer.support@bidx.com>

- (5) The department will address equipment and process failures, if the bidder can demonstrate that those failures were beyond their control.
- (6) Contractors are responsible for checking on the issuance of addenda and for obtaining the addenda. Notice of issuance of addenda is posted on the department's web site at <http://www.dot.wisconsin.gov/business/engrserv/bid-letting-information.htm> or by calling the department at (608) 266-1631. Addenda can ONLY be obtained from the departments web site listed above or by picking up the addenda at the Bureau of Highway Construction, Room 601, 4802 Sheboygan Avenue, Madison, WI, during regular business hours.

#### B Submitting Electronic Bids

##### B.1 On the Internet

- (1) Do the following before submitting the bid:
  1. Have a properly executed annual bid bond on file with the department.
  2. Have a digital ID on file with and enabled by Info Tech Inc. Using this digital ID will constitute the bidder's signature for proper execution of the bidding proposal.
- (2) In lieu of preparing, delivering, and submitting the proposal as specified in **102.6** and **102.9** of the standard specifications, submit the proposal on the internet as follows:

1. Download the latest schedule of items reflecting all addenda from the Bid Express™ web site.
  2. Use Expedite™ software to enter a unit price for every item in the schedule of items.
  3. Submit the bid according to the requirements of Expedite™ software and the Bid Express™ web site. Do not submit a bid on a printout with accompanying diskette or CD ROM or a paper bid. If the bidder does submit a bid on a printout with accompanying diskette or a paper bid in addition to the internet submittal, the department will disregard the internet bid.
  4. Submit the bid before the hour and date the Notice to Contractors designates.
  5. Do not sign, notarize, and return the bidding proposal described in 102.2 of the standard specifications.
- (3) The department will not consider the bid accepted until the hour and date the Notice to Contractors designates.

## **B.2 On a Printout with Accompanying Diskette or CD ROM**

- (1) Download the latest schedule of items from the Wisconsin pages of the Bid Express™ web site reflecting the latest addenda posted on the department's web site at <http://www.dot.wisconsin.gov/business/engrserv/bid-letting-information.htm>. Use Expedite™ software to prepare and print the schedule of items. Provide a valid amount for all price fields. Follow instructions and review the help screens provided on the Bid Express™ web site to assure that the schedule of items is prepared properly.
- (2) Staple an 8 1/2 by 11 inch printout of the Expedite™ generated schedule of items to the other proposal documents submitted to the department as a part of the bidder's sealed bid. As a separate submittal not in the sealed bid envelop but due at the same time and place as the sealed bid, also provide the Expedite™ generated schedule of items on a 3 1/2 inch computer diskette or CD ROM. Label each diskette or CD ROM with the bidder's name, the 4 character department-assigned bidder identification code from the top of the bidding proposal, and a list of the proposal numbers included on that diskette or CD ROM as indicated in the following example:

**Bidder Name**

**BN00**

**Proposals: 1, 12, 14, & 22**

- (3) If bidding on more than one proposal in the letting, the bidder may include all proposals for that letting on one diskette or CD ROM. Include only submitted proposals with no incomplete or other files on the diskette or CD ROM.
- (4) The bidder-submitted printout of the Expedite™ generated schedule of items is the governing contract document and must conform to the requirements of section 102 of the standard specifications. If a printout needs to be altered, cross out the printed information with ink or typewriter and enter the new information and initial it in ink. If there is a discrepancy between the printout and the diskette or CD ROM, the department will analyze the bid using the printout information.
- (5) In addition to the reasons specified in section 102 of the standard specifications, proposals are irregular and the department may reject them for one or more of the following:
  1. The check code printed on the bottom of the printout of the Expedite™ generated schedule of items is not the same on each page.
  2. The check code printed on the printout of the Expedite™ generated schedule of items is not the same as the check code for that proposal provided on the diskette or CD ROM.

3. The diskette or CD ROM is not submitted at the time and place the department designates.

### **C Waiver of Electronic Submittal**

- (1) The bidder may request a waiver of the electronic submittal requirements. Submit a written request for a waiver in lieu of bids submitted on the internet or on a printout with accompanying diskette or CD ROM. Use the waiver that was included with the paper bid document sent to the bidder or type up a waiver on the bidder's letterhead. The department will waive the electronic submittal requirements for a bidding entity (individual, partnership, joint venture, corporation, or limited liability company) for up to 4 individual proposals in a calendar year. The department may allow additional waivers for equipment malfunctions.
- (2) Submit a schedule of items on paper conforming to [section 102](#) of the standard specifications. The department charges the bidder a \$75 administrative fee per proposal, payable at the time and place the department designates for receiving bids, to cover the costs of data entry. The department will accept a check or money order payable to: "Wisconsin, Dept. of Transportation."
- (3) In addition to the reasons specified in [section 102](#) of the standard specifications, proposals are irregular and the department may reject them for one or more of the following:
  1. The bidder fails to provide the written request for waiver of the electronic submittal requirements.
  2. The bidder fails to pay the \$75 administrative fee before the time the department designates for the opening of bids unless the bidder requests on the waiver that they be billed for the \$75.
  3. The bidder exceeds 4 waivers of electronic submittal requirements within a calendar year.
- (4) In addition to the reasons specified in [section 102](#) of the standard specifications, the department may refuse to issue bidding proposals for future contracts to a bidding entity that owes the department administrative fees for a waiver of electronic submittal requirements.





# PROPOSAL BID BOND

DT1303 1/2006

Wisconsin Department of Transportation

Proposal Number	Project Number	Letting Date
Name of Principal		
Name of Surety	State in Which Surety is Organized	

We, the above-named Principal and the above-named Surety, are held and firmly bound unto the State of Wisconsin in the sum equal to the Proposal Guaranty for the total bid submitted for the payment to be made; we jointly and severally bind ourselves, our heirs, executors, administrators, successors and assigns. The condition of this obligation is that the Principal has submitted a bid proposal to the State of Wisconsin acting through the Department of Transportation for the improvement designated by the Proposal Number and Letting Date indicated above.

If the Principal is awarded the contract and, within the time and manner required by law after the prescribed forms are presented for signature, enters into a written contract in accordance with the bid, and files the bond with the Department of Transportation to guarantee faithful performance and payment for labor and materials, as required by law, or if the Department of Transportation shall reject all bids for the work described, then this obligation shall be null and void; otherwise, it shall be and remain in full force and effect. In the event of failure of the Principal to enter into the contract or give the specified bond, the Principal shall pay to the Department of Transportation **within 10 business days of demand** a total equal to the Proposal Guaranty as liquidated damages; the liability of the Surety continues for the full amount of the obligation as stated until the obligation is paid in full.

The Surety, for value received, agrees that the obligations of it and its bond shall not be impaired or affected by any extension of time within which the Department of Transportation may accept the bid; and the Surety does waive notice of any such extension.

IN WITNESS, the Principal and Surety have agreed and have signed by their proper officers and have caused their corporate seals to be affixed this date: **(DATE MUST BE ENTERED)**

## PRINCIPAL

\_\_\_\_\_  
(Company Name) **(Affix Corporate Seal)**

\_\_\_\_\_  
(Signature and Title)

\_\_\_\_\_  
(Company Name)

\_\_\_\_\_  
(Signature and Title)

\_\_\_\_\_  
(Company Name)

\_\_\_\_\_  
(Signature and Title)

\_\_\_\_\_  
(Company Name)

\_\_\_\_\_  
(Signature and Title)

## NOTARY FOR PRINCIPAL

\_\_\_\_\_  
(Date)

State of Wisconsin )  
 ) ss.  
\_\_\_\_\_ County )

On the above date, this instrument was acknowledged before me by the named person(s).

\_\_\_\_\_  
(Signature, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Print or Type Name, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Date Commission Expires)

**Notary Seal**

\_\_\_\_\_  
(Name of Surety) **(Affix Seal)**

\_\_\_\_\_  
(Signature of Attorney-in-Fact)

## NOTARY FOR SURETY

\_\_\_\_\_  
(Date)

State of Wisconsin )  
 ) ss.  
\_\_\_\_\_ County )

On the above date, this instrument was acknowledged before me by the named person(s).

\_\_\_\_\_  
(Signature, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Print or Type Name, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Date Commission Expires)

**Notary Seal**

**IMPORTANT: A certified copy of Power of Attorney of the signatory agent must be attached to the bid bond.**



# CERTIFICATE OF ANNUAL BID BOND

DT1305 8/2003

Wisconsin Department of Transportation

Time Period Valid (From/To)	
Name of Surety	
Name of Contractor	
Certificate Holder	Wisconsin Department of Transportation

This is to certify that an annual bid bond issued by the above-named Surety is currently on file with the Wisconsin Department of Transportation.

This certificate is issued as a matter of information and conveys no rights upon the certificate holder and does not amend, extend or alter the coverage of the annual bid bond.

**Cancellation:** Should the above policy be cancelled before the expiration date, the issuing surety will give thirty (30) days written notice to the certificate holder indicated above.

\_\_\_\_\_  
(Signature of Authorized Contractor Representative)

\_\_\_\_\_  
(Date)



## March 2010

## LIST OF SUBCONTRACTORS

Section 66.0901(7), Wisconsin Statutes, provides that as a part of the proposal, the bidder also shall submit a list of the subcontractors the bidder proposes to contract with and the class of work to be performed by each. In order to qualify for inclusion in the bidder's list a subcontractor shall first submit a bid in writing, to the general contractor at least 48 hours prior to the time of the bid closing. The list may not be added to or altered without the written consent of the municipality. A proposal of a bidder is not invalid if any subcontractor and the class of work to be performed by the subcontractor has been omitted from a proposal; the omission shall be considered inadvertent or the bidder will perform the work personally.

No subcontract, whether listed herein or later proposed, may be entered into without the written consent of the Engineer as provided in Subsection 108.1 of the Standard Specifications.

[illegible]

**DECEMBER 2000**

**CERTIFICATION REGARDING DEBARMENT, SUSPENSION, AND OTHER  
RESPONSIBILITY MATTERS - PRIMARY COVERED TRANSACTIONS**

Instructions for Certification

1. By signing and submitting this proposal, the prospective contractor is providing the certification set out below.
2. The inability of a person to provide the certification required below will not necessarily result in denial of participation in this covered transaction. The prospective contractor shall submit an explanation of why it cannot provide the certification set out below. The certification or explanation will be considered in connection with the department or agency's determination whether to enter into this transaction. However, failure of the prospective contractor to furnish a certification or an explanation shall disqualify such person from participation in this transaction.
3. The certification in this clause is a material representation of fact upon which reliance was placed when the department determined to enter into this transaction. If it is later determined that the contractor knowingly rendered an erroneous certification in addition to other remedies available to the Federal Government the department may terminate this transaction for cause or default.
4. The prospective contractor shall provide immediate written notice to the department to whom this proposal is submitted if at any time the prospective contractor learns that its certification was erroneous when submitted or has become erroneous by reason of changed circumstances.
5. The terms "covered transaction," "debarred," "suspended," "ineligible," "lower tier covered transaction," "participant," "person," "primary covered transaction," "principal," "proposal," and "voluntarily excluded," as used in this clause, have the meanings set out in the Definitions and Coverage sections of the rules implementing Executive Order 12549. You may contact the department to which this proposal is being submitted for assistance in obtaining a copy of those regulations.
6. The prospective contractor agrees by submitting this proposal that, should this contract be entered into, it shall not knowingly enter into any lower tier covered transaction with a person who is debarred, suspended, declared ineligible, or voluntarily excluded from participation in this covered transaction, unless authorized by the department entering into this transaction.
7. The prospective contractor further agrees by submitting this proposal that it will include the clause titled "Certification Regarding Debarment, Suspension, Ineligibility and Voluntary Exclusion-Lower Tier Covered Transaction," which is included as an addendum to PR-1273 - "Required Contract Provisions Federal Aid Construction Contracts," without

modification, in all lower tier covered transactions and in all solicitations for lower tier covered transactions.

8. The contractor may rely upon a certification of a prospective subcontractor/materials supplier that it is not debarred, suspended, ineligible, or voluntarily excluded from the covered transaction, unless it knows that the certification is erroneous. A contractor may decide the method and frequency by which it determines the eligibility of its principals. Each contractor may, but is not required to, check the Disapproval List (telephone # 608/266/1631).
9. Nothing contained in the foregoing shall be construed to require establishment of a system of records in order to render in good faith the certification required by this clause. The knowledge and information of a contractor is not required to exceed that which is normally possessed by a prudent person in the ordinary course of business dealings.
10. Except for transactions authorized under paragraph 6 of these instructions, if a contractor in a covered transaction knowingly enters into a lower tier covered transaction with a person who is suspended, debarred, ineligible or voluntarily excluded from participation in this transaction, in addition to other remedies available to the Federal Government, the department may terminate this transaction for cause or default.

Certification Regarding Debarment, Suspension, and Other Responsibility Matters - Primary Covered Transactions

- (1) The prospective contractor certifies to the best of its knowledge and belief, that it and its principals:
  - (a) Are not presently debarred, suspended, proposed for debarment, declared ineligible, or voluntarily excluded from covered transactions by any Federal department or agency;
  - (b) Have not within a three-year period preceding this proposal been convicted of or had a civil judgment rendered against them for commission of fraud or a criminal offense in connection with obtaining, attempting to obtain, or performing a public (Federal, State or local) transaction or contract under a public transaction; violation of Federal or State antitrust statutes or commission of embezzlement, theft, forgery, bribery, falsification or destruction of records, making false statements or receiving stolen property;
  - (c) Are not presently indicted for or otherwise criminally or civilly charged by a governmental entity (Federal, State or local) with commission of any of the offense enumerated in paragraph (1)(b) of this certification; and
  - (d) Have not within a three-year period preceding this proposal had one or more public transactions (Federal, State or local) terminated for cause or default.
- (2) Where the prospective contractor is unable to certify to any of the statements in this certification, such prospective contractor shall attach an explanation to this proposal.

## Special Provisions

### Table of Contents

Article	Description	Page #
1.	General.....	2
2.	Scope of Work. ....	2
3.	Prosecution and Progress. ....	2
4.	Traffic. ....	3
5.	Holiday Work Restrictions. ....	3
6.	Utilities.....	3
7.	Referenced Construction Specifications.....	4
8.	Municipality Acceptance of Sanitary Sewer and Water Main Construction.....	5
9.	General Requirements for Water Main Constructed Within the City of Ashland.....	5
10.	Cover Sanitary Manhole.....	5
11.	Information to Bidders, U.S. Army Corps of Engineers Section 404 Permit.....	5
12.	Environmental Protection, Aquatic Exotic Species Control.....	6
13.	Dredging.....	7
14.	Culvert Placement.....	7
15.	Culvert Interior Surface.....	7
16.	Removing Small Pipe Culverts.....	7
17.	QMP Base Aggregate.....	7
18.	QMP Ride; Incentive IRI Ride, Item 440.4410.S.....	16
19.	Storm Sewer Pipe Reinforced Concrete Class III.....	23
20.	Pipe Underdrain 6-Inch, Item 612.0106.....	24
21.	Salvaged Rail.....	24
22.	Insulation Board Polystyrene, 4-Inch, Item 612.0902.S.01.....	24
23.	Removing Signs Type II.....	25
24.	Gate Valve and Box 8-Inch, Item SPV.0060.01.....	25
25.	Cut Into and Connect to Existing Water Main, Item SPV.0060.02.....	26
26.	Install and Remove Temporary Service for Testing, Item SPV.0060.03.....	27
27.	Construction Staking Detour Widening Staking, Item SPV.0060.04.....	28
28.	Water Main Fittings, Item SPV.0085.01.....	29
29.	Concrete Curb and Gutter 6-Inch Sloped 20-Inch Type G Modified, Item SPV.0090.01.....	30
30.	Culvert Pipe Reinforced Concrete Class IV 96-Inch, Item SPV.0090.02.....	31
31.	Water Main 8-Inch, Item SPV.0090.03.....	31
32.	Concrete Curb and Gutter Cure and Seal Treatment, Item SPV.0090.04.....	34
33.	Special Storm Sewer Protection, Item SPV.0105.01.....	34
34.	Concrete Sidewalk Cure and Seal Treatment, Item SPV.0165.01.....	35
35.	Concrete Pavement Repair Doweled Special, Item SPV.0180.01; Concrete Pavement Replacement Doweled Special, Item SPV.0180.02.....	36



## **SPECIAL PROVISIONS**

### **1. General.**

Perform the work under this construction contract for Project 1181-11-70, C Ashland, Lake Shore Drive, 29th Avenue to 36th Avenue, USH 2, Ashland County, Wisconsin as the plans show and execute the work as specified in the State of Wisconsin, Department of Transportation, Standard Specifications for Highway and Structure Construction, 2014 Edition, as published by the department, and these special provisions.

If all or a portion of the plans and special provisions are developed in the SI metric system and the schedule of prices is developed in the US standard measure system, the department will pay for the work as bid in the US standard system.

100-005 (20130615)

### **2. Scope of Work.**

The work under this contract shall consist of culvert replacement, grading, base aggregate dense, concrete pavement, curb and gutter, beam guard, pavement marking, permanent signing, water main work, and all incidental items necessary to complete the work as shown on the plans and included in the proposal and contract.

104-005 (20090901)

### **3. Prosecution and Progress.**

Begin work within ten calendar days after the engineer issues a written notice to do so.

Provide the start date to the engineer in writing within a month after executing the contract but at least 14 calendar days before the preconstruction conference. Upon approval, the engineer will issue the notice to proceed within ten calendar days before the approved start date.

To revise the start date, submit a written request to the engineer at least two weeks before the intended start date. The engineer will approve or deny that request based on the conditions cited in the request and its effect on the department's scheduled resources.

#### **Fish Spawning**

There shall be no instream disturbance of the west tributary as a result of construction activity under or for this contract, from November 1 to June 15 both dates inclusive, in order to avoid adverse impacts upon the spawning of suckers and creek chubs.

Any change to this limitation will require submitting a written request by the contractor to the engineer, subsequent review and concurrence by the Department of Natural Resources

in the request, and final approval by the engineer. The approval will include all conditions to the request as mutually agreed upon by WisDOT and DNR.

#### **4. Traffic.**

For construction of the east culvert, detour USH 2 Eastbound (EB) traffic south on Industrial Park Road, east on Toll Road, north on Sum Road, and back to USH 2. Detour USH 2 Westbound (WB) south on Sum Road, west on Toll Road, north on Industrial Park Road, and back to USH 2. For construction of the west culvert, detour USH 2 EB traffic south on 26<sup>th</sup> Avenue, east on Toll Road, north on Industrial Park Road, and back to USH 2. Detour USH 2 WB south on Industrial Park Road, west on Toll Road, north on 26<sup>th</sup> Avenue, and back to USH 2.

Construct only one culvert pipe location at a time, beginning with the east culvert. Maintain access across one culvert location at all times during construction.

Perform work in such a manner to ensure pedestrian access to adjacent residences and businesses at all times.

Use Drums and/or barricades to protect hazards in the work zone - such as exposed manholes, inlets, or drop-offs for pedestrians and vehicles.

#### **5. Holiday Work Restrictions.**

Do not perform work on, nor haul materials of any kind along or across any portion of the highway carrying USH 2 traffic, and entirely clear the traveled way and shoulders of such portions of the highway of equipment, barricades, signs, lights, and any other material that might impede the free flow of traffic during the following holiday periods:

- From noon Friday, May 22, 2015 to 6:00 AM Tuesday, May 26, 2015 for Memorial Day;
- From noon Friday, July 3, 2015 to 6:00 AM Monday, July 6, 2015 for Independence Day.

107-005 (20050502)

#### **6. Utilities.**

This contract comes under the provision of Administrative Rule Trans 220.  
107-065 (20080501)

It is the contractor's responsibility to coordinate all work with utilities. This includes giving proper notification prior to when utility work is to be performed in conjunction with roadway construction.

**The City of Ashland Water Utility** has multiple water main and storm sewer facilities crossing USH 2 throughout the project limits. Removal and replacement of approximately 160 linear feet of water main is included in the contract to facilitate the culvert

replacement near Station 10+00. Contact 7 days in advance where work is needed during construction.

The City of Ashland Water Utility has water main and sanitary facilities that parallel Toll Road, Industrial Park Road, and Sum Road along the detour route. These facilities have crossings on the north and west sides of the intersection of Toll Road and Industrial Park Road and on the west side of the intersection of Toll Road and Sum Road. A sanitary manhole at the northwest corner of Toll Road and Industrial Park Road will be covered by the temporary widening, and uncovered upon completion of the project (See the special provision Cover Sanitary Manhole).

**CenturyLink** has facilities on USH 2 approximately at Stations 10+85. CenturyLink will be rerouting this cable prior to construction. Contact seven days prior to construction to confirm the cable has been rerouted.

Century Link has buried fiber optic cable facilities that cross Industrial Park Road and Toll road along the detour route to the north and east of the intersection. No Conflicts anticipated with these facilities.

**Charter Communications** has multiple coaxial cable facilities on Xcel electric poles crossing USH 2 approximately at Stations 5+00, 14+50, and 41+00. No Conflicts anticipated.

**Norvado** has buried fiber optic cable facilities crossing USH 2 approximately at Stations 19+50. Buried fiber optic cable facilities also parallel Toll Road along the detour route and cross Toll Road to the west of the intersection of Toll Road and Industrial Park Road. No Conflicts anticipated.

**XCEL Energy** has gas facilities crossing USH 2 approximately at Stations 4+50, 8+75, 13+25, and 40+50. Conflicts are anticipated on the North and South side of the road at west culvert pipe replacement. XCEL Energy will be rerouting these lines on a temporary bypass around the site in conjunction with the roadway construction. Contact one month prior to construction to coordinate with XCEL.

XCEL Energy has buried electric and gas facilities that parallel Sum Road and Industrial Park Road along the detour route. These facilities cross on the north and west sides of the intersection of Toll Road and Industrial Park Road and on the west side of the intersection of Toll Road and Sum Road. No Conflicts anticipated.

XCEL Energy has a light pole at approximately Station 10+39. Conflicts are anticipated due to west culvert pipe replacement. XCEL will remove the pole prior to construction in the area. Contact 7 days in advance to coordinate the removal of the pole.

## **7. Referenced Construction Specifications.**

Construct the water main work conforming to the Standard Specifications for Sewer and Water Construction in Wisconsin. If there is a discrepancy or conflict between the

referenced specification and the standard specifications regarding contract administration, part 1 of the standard specifications governs.

**8. Municipality Acceptance of Sanitary Sewer and Water Main Construction.**

Both the department and City of Ashland personnel will inspect construction of sanitary sewer and water main under this contract. However, construction staking, testing, and final acceptance of the sanitary sewer and water main construction will be by the City of Ashland.

105-001 (20061009)

**9. General Requirements for Water Main Constructed Within the City of Ashland.**

All water main construction completed within the city of Ashland shall be in accordance to *Standard Specifications for Sewer and Water Construction in Wisconsin*, Sixth Edition, December 22, 2003, as amended by Addenda 1 and 2; hereinafter referred to as *Wisconsin Water and Sewer Specifications*. Modifications or clarifications made within this specification supersede the *Wisconsin Water and Sewer Specifications*.

**10. Cover Sanitary Manhole.**

The contractor will be permitted to cover the sanitary manhole at the Northwest corner of Industrial Park Road and Toll Road for the duration of the culvert replacement project in order to widen the corner on the detour route.

After the project is completed the manhole will need to be exposed, and the surrounding ground returned to the existing conditions.

The contractor is responsible to protect the manhole and cover from damage and will be liable for the cost of any repairs due to damage. The contractor is liable for any costs related to cleaning the sanitary line if dirt or debris gets into the line due to related project work. Payment is considered incidental to the temporary widening items.

**11. Information to Bidders, U.S. Army Corps of Engineers Section 404 Permit.**

The department has obtained a U.S. Army Corps of Engineers Section 404 permit. Comply with the requirements of the permit in addition to requirements of the special provisions. A copy of the permit is available from the regional office by contacting Philip Keppers at (715) 395-3027.

107-054 (20080901)

## 12. Environmental Protection, Aquatic Exotic Species Control.

Exotic invasive organisms such as VHS, zebra mussels, purple loosestrife, and Eurasian water milfoil are becoming more prolific in Wisconsin and pose adverse effects to waters of the state. Wisconsin State Statutes 30.07, “Transportation of Aquatic Plants and Animals; Placement of Objects in Navigable Waters”, details the state law that requires the removal of aquatic plants and zebra mussels each time equipment is put into state waters.

At construction sites that involve navigable water or wetlands, use the follow cleaning procedures to minimize the chance of exotic invasive species infestation. Use these procedures for all equipment that comes in contact with waters of the state and/or infested water or potentially infested water in other states.

Ensure that all equipment that has been in contact with waters of the state, or with infested or potentially infested waters, has been decontaminated for aquatic plant materials and zebra mussels prior to being used in other waters of the state. Before using equipment on this project, thoroughly disinfect all equipment that has come into contact with potentially infested waters. Use the following inspection and removal procedures (guidelines from the Wisconsin Department of Natural Resources [http://dnr.wi.gov/topic/fishing/documents/vhs/disinfection\\_protocols.pdf](http://dnr.wi.gov/topic/fishing/documents/vhs/disinfection_protocols.pdf) for disinfection:

1. Prior to leaving the contaminated site, wash machinery and ensure that the machinery is free of all soil and other substances that could possibly contain exotic invasive species;
2. Drain all water from boats, trailers, bilges, live wells, coolers, bait buckets, engine compartments, and any other area where water may be trapped;
3. Inspect boat hulls, propellers, trailers and other surfaces. Scrape off any attached mussels, remove any aquatic plant materials (fragments, stems, leaves, seeds, or roots), and dispose of removed mussels and plant materials in a garbage can prior to leaving the area or invested waters; and
4. Disinfect your boat, equipment and gear by either:
  - a. Washing with ~212° F water (steam clean), or
  - b. Drying thoroughly for five days after cleaning with soap and water and/or high pressure water, or
  - c. Disinfecting with either 200 ppm (0.5 oz per gallon or 1 Tablespoon per gallon) Chlorine for 10-minute contact time or 1:100 solution (38 grams per gallon) of Virkon Aquatic for 20- to 30-minute contact time. Note: Virkon is not registered to kill zebra mussel veligers nor invertebrates like spiny water flea. Therefore this disinfect should be used in conjunction with a hot water (>104° F) application.

Complete the inspection and removal procedure before equipment is brought to the project site and before the equipment leaves the project site.

107-055 (20130615)

### **13. Dredging.**

Do not alter the width and depth of the tributaries. A minor amount of dredging to place the structure elements is permissible.

### **14. Culvert Placement.**

Set culverts in such a manner that they do not cause stream fragmentation and allow for fish and other aquatic organisms to migrate upstream and downstream during low flow conditions. Set invert of the 72-inch pipe 1 foot below the final streambed elevation, and set invert of the 96-inch pipe 2 feet below the final streambed elevation to allow a natural and continuous streambed condition to occur.

### **15. Culvert Interior Surface.**

Provide a ½-inch raked finish every 8 inches to the interior surface of the of the 72” and 96” culvert pipes. The raked finish is to be done when the pipe is manufactured.

### **16. Removing Small Pipe Culverts.**

This work shall be in accordance to the pertinent requirements of standard specs 203 and 204 and as hereinafter provided.

Salvaged materials will become the property of Ashland County.

The existing ADS dual wall 48-Inch pipe (liner) shall be completely removed from inside of the existing 66-Inch culvert pipe at Station 24+82. The existing 48-Inch pipe has not been grouted in place. Carefully remove in a manner that will preclude any damage to the pipe liner (cutting or destructive measures not allowed).

The salvaged pipe shall be stored on the right-of-way, outside the limits of construction where they may be retrieved by Ashland County forces.

All other material shall be removed from the right-of-way and disposed of by the contractor.

Upon completion of the removal and storage of salvageable materials contact Ashland County Highway Commissioner Emmer Shields at (715) 274-3662.

### **17. QMP Base Aggregate.**

#### **A Description**

#### **A.1 General**

- (1) This special provision describes contractor quality control (QC) sampling and testing for base aggregates, documenting those test results, and documenting related production and placement process changes. This special provision also describes

department quality verification (QV), independent assurance (IA), and dispute resolution.

- (2) Conform to standard spec 301, standard spec 305, and standard spec 310 as modified here in this special provision. Apply this special provision to material placed under all of the Base Aggregate Dense and Base Aggregate Open Graded bid items, except do not apply this special provision to material classified as reclaimed asphaltic pavement placed under the Base Aggregate Dense bid items.
- (3) Do not apply this special provision to material placed under the Aggregate Detours, Salvaged Asphaltic Pavement Base, Breaker Run, Select Crushed, Pit Run, Subbase, or Riprap bid items.
- (4) Provide and maintain a quality control program, defined as all activities related to and documentation of the following:
  1. Production and placement control and inspection.
  2. Material sampling and testing.
- (5) Chapter 8 of the department's construction and materials manual (CMM) provides additional detailed guidance for QMP work and describes required sampling and testing procedures. The contractor may obtain the CMM from the department's web site at:

<http://roadwaystandards.dot.wi.gov/standards/cmm/index.htm>

## **A.2 Contractor Testing for Small Quantities**

- (1) The department defines a small quantity, for each individual Base Aggregate bid item, as a plan quantity of 9000 tons or less of material as shown in the schedule of items under that bid item.
- (2) The requirements under this special provision apply equally to a small quantity for an individual bid item except as follows:
  1. The contractor need not submit a full quality control plan but shall provide an organizational chart to the engineer including names, telephone numbers, and current certifications of all persons involved in the quality control program for material under affected bid items.
  2. Divide the aggregate into uniformly sized sublots for testing as follows:

<b>Plan Quantity</b>	<b>Minimum Required Testing</b>
$\leq 1500$ tons	One test from production, load-out, or placement at the contractor's option <sup>[1]</sup>
$> 1500$ tons and $\leq 6000$ tons	Two tests of the same type, either from production, load-out, or placement at the contractor's option <sup>[1]</sup>
$> 6000$ tons and $\leq 9000$ tons	Three placement tests <sup>[2][3]</sup>

<sup>[1]</sup> If using production tests for acceptance, submit test results to the engineer for review prior to incorporating the material into the work. Production test results are valid for a period of 3 years.

- [2] For 3-inch material, obtain samples at load-out.
  - [3] If the actual quantity overruns 9000 tons, create overrun sublots to test at a rate of one additional placement test for each 3000 tons, or fraction of 3000 tons, of overrun.
  - 3. No control charts are required. Submit aggregate load-out and placement test results to the engineer within one business day of obtaining the sample. Assure that all properties are within the limits specified for each test.
  - 4. Department verification testing is optional for quantities of 6000 tons or less.
- (3) Material represented by a subplot with any property outside the specification limits is nonconforming. The department may reject material or otherwise determine the final disposition of nonconforming material as specified in standard spec 106.5.

## **B Materials**

### **B.1 Quality Control Plan**

- (1) Submit a comprehensive written quality control plan to the engineer at or before the pre-construction meeting. Do not place base before the engineer reviews and comments on the plan. Construct the project as that plan provides.
- (2) Do not change the quality control plan without the engineer's review. Update the plan with changes as they become effective. Provide a current copy of the plan to the engineer and post in each of the contractor's laboratories as changes are adopted. Ensure that the plan provides the following elements:
  - 1. An organizational chart with names, telephone numbers, current certifications and/or titles, and roles and responsibilities of QC personnel.
  - 2. The process used to disseminate QC information and corrective action efforts to the appropriate persons. Include a list of recipients, the communication means that will be used, and action time frames.
  - 3. A list of source and processing locations, section and quarter descriptions, for all aggregate materials requiring QC testing.
  - 4. Test results for wear, sodium sulfate soundness, freeze/thaw soundness, and plasticity index of all aggregates requiring QC testing. Obtain this information from the region materials unit or from the engineer.
  - 5. Descriptions of stockpiling and hauling methods.
  - 6. Locations of the QC laboratory, retained sample storage, and where control charts and other documentation is posted.
  - 7. An outline for resolving a process control problem. Include responsible personnel, required documentation, and appropriate communication steps.

### **B.2 Personnel**

- (1) Have personnel certified under the department's highway technician certification program (HTCP) perform sampling, testing, and documentation as follows:



<b>Required Certification Level:</b>	<b>Sampling or Testing Roles:</b>
Aggregate Technician IPP Aggregate Sampling Technician Aggregate Assistant Certified Technician (ACT-AGG)	Aggregate Sampling <sup>[1]</sup>
Aggregate Technician IPP Aggregate Assistant Certified Technician (ACT-AGG)	Aggregate Gradation Testing, Aggregate Fractured Particle Testing, Aggregate Liquid Limit and Plasticity Index Testing

<sup>[1]</sup> Plant personnel under the direct observation of an aggregate technician certified at level one or higher may operate equipment to obtain samples.

- (2) A certified technician must coordinate and take responsibility for the work an ACT performs. Have a certified technician ensure that all sampling and testing is performed correctly, analyze test results, and post resulting data. No more than one ACT can work under a single certified technician.

### **B.3 Laboratory**

- (1) Perform QC testing at a department-qualified laboratory. Obtain information on the Wisconsin laboratory qualification program from:  
Materials Management Section  
3502 Kinsman Blvd.  
Madison, WI 53704  
Telephone: (608) 246-5388  
<http://www.dot.state.wi.us/business/engrserv/lab-qualification.htm>

### **B.4 Quality Control Documentation**

#### **B.4.1 General**

- (1) Submit base aggregate placement documentation to the engineer within 10 business days after completing base placement. Ensure that the submittal is complete, neatly organized, and includes applicable project records and control charts.

#### **B.4.2 Records**

- (1) Document all placement observations, inspection records, and control adjustments daily in a permanent field record. Also include all test results in the project records. Provide test results to the engineer within 6 hours after obtaining a sample. For 3-inch base, extend this 6-hour limit to 24 hours. Post or distribute tabulated results using a method mutually agreeable to the engineer and contractor.

#### **B.4.3 Control Charts**

- (1) Plot gradation and fracture on the appropriate control chart as soon as test results are available. Format control charts according to CMM 8.30. Include the project number on base placement control charts. Maintain separate control charts for each base aggregate size, source or classification, and type.

- (2) Provide control charts to the engineer within 6 hours after obtaining a sample. For 3-inch base, extend this 6-hour limit to 24 hours. Post or distribute charts using a method mutually agreeable to the engineer and contractor. Update control charts daily to include the following:
  1. Contractor individual QC tests.
  2. Department QV tests.
  3. Department IA tests.
  4. Four-point running average of the QC tests.
- (3) Except as specified under B.8.2.1 for nonconforming QV tests, include only QC tests in the running average. The contractor may plot process control or informational tests on control charts, but do not include these tests, conforming QV tests, or IA tests in the running average.

## **B.5 Contractor Testing**

- (1) Test gradation, fracture, liquid limit and plasticity index during placement for each base aggregate size, source or classification, and type.
- (2) Test gradation once per 3000 tons of material placed. Determine random sample locations and provide those sample locations to the engineer. Obtain samples after the material has been bladed, mixed, and shaped but before compacting; except collect 3-inch samples from the stockpile at load-out. Do not sample from material used to maintain local traffic or from areas of temporary base that will not have an overlying pavement. On days when placing only material used to maintain local traffic or only temporary base that will not have an overlying pavement, no placement testing is required.
- (3) Split each contractor QC sample and identify it according to CMM 8.30. Retain the split for 7 calendar days in a dry, protected location. If requested for department comparison testing, deliver the split to the engineer within one business day.
- (4) The engineer may require additional sampling and testing to evaluate suspect material or the technician's sampling and testing procedures.
- (5) Test fracture for each gradation test until the fracture running average is above the lower warning limit. Subsequently, the contractor may reduce the frequency to one test per 10 gradation tests if the fracture running average remains above the warning limit.
- (6) Test the liquid limit and plasticity index for the first gradation test. Subsequently, test the liquid limit and plasticity index a minimum of once per 10 gradation tests.

## **B.6 Test Methods**

### **B.6.1 Gradation**

- (1) Test gradation using a washed analysis conforming to the following as modified in CMM 8.60:

Gradation..... AASHTO T 27  
Material finer than the No. 200 sieve..... AASHTO T 11

- (2) For 3-inch base, if 3 consecutive running average points for the percent passing the No. 200 sieve are 8.5 percent or less, the contractor may use an unwashed analysis. Wash at least one sample out of 10. If a single running average for the percent passing the No. 200 sieve exceeds 8.5 percent, resume washed analyses until 3 consecutive running average points are again 8.5 percent passing or less.
- (3) Maintain a separate control chart for each sieve size specified in standard spec 305 or standard spec 310 for each base aggregate size, source or classification, and type. Set control and warning limits based on the standard specification gradation limits as follows:
  1. Control limits are at the upper and lower specification limits.
  2. There are no upper warning limits for sieves allowing 100 percent passing and no lower control limits for sieves allowing 0 percent passing.
  3. Dense graded warning limits, except for the No. 200 sieve, are 2 percent within the upper and lower control limits. Warning limits for the No. 200 sieve are set 0.5 percent within the upper and lower control limits.
  4. Open graded warning limits for the 1-inch, 3/8-inch, and No. 4 sieves are 2 percent within the upper and lower control limits. Upper warning limits for the No. 10, No. 40, and No. 200 sieves are 1 percent inside the upper control limit.

#### **B.6.2 Fracture**

- (1) Test fracture conforming to CMM 8.60. The engineer will waive fractured particle testing on quarried stone.
- (2) Maintain a separate fracture control chart for each base aggregate size, source or classification, and type. Set the lower control limit at the contract specification limit, either specified in another special provision or in table 301-2 of standard spec 301.2.4.5. Set the lower warning limit 2 percent above the lower control limit. There are no upper limits.

#### **B.6.3 Liquid Limit and Plasticity**

- (1) Test the liquid limit and plasticity according to AASHTO T 89 and T 90.
- (2) Ensure the material conforms to the limits specified in standard spec table 301-2.

### **B.7 Corrective Action**

#### **B.7.1 General**

- (1) Consider corrective action when the running average trends toward a warning limit. Take corrective action if an individual test exceeds the contract specification limit. Document all corrective actions both in the project records and on the appropriate control chart.

### **B.7.2 Placement Corrective Action**

- (1) Do not blend additional material on the roadbed to correct gradation problems.
- (2) Notify the engineer whenever the running average exceeds a warning limit. When two consecutive running averages exceed a warning limit, the engineer and contractor will discuss appropriate corrective action. Perform the engineer's recommended corrective action and increase the testing frequency as follows:
  1. For gradation, increase the QC testing frequency to at least one randomly sampled test per 1000 tons placed.
  2. For fracture, increase the QC testing frequency to at least one test per gradation test.
- (3) If corrective action improves the property in question such that the running average after four additional tests is within the warning limits, the contractor may return to the testing frequency specified in B.5.3. If corrective action does not improve the property in question such that the running average after 4 additional individual tests is still in the warning band, repeat the steps outlined above starting with engineer notification.
- (4) If the running average exceeds a control limit, material starting from the first running average exceeding the control limit and ending at the first subsequent running average inside the control limit is nonconforming and subject to pay reduction.
- (5) For individual test results significantly outside the control limits, notify the engineer, stop placing base, and suspend other activities that may affect the area in question. The engineer and contractor will jointly review data, data reduction, and data analysis; evaluate sampling and testing procedures; and perform additional testing as required to determine the extent of potentially unacceptable material. The engineer may direct the contractor to remove and replace that material. Individual test results are significantly outside the control limits if meeting one or more of the following criteria:
  1. A gradation control limit for the No. 200 sieve is exceeded by more than 3.0 percent.
  2. A gradation control limit for any sieve, except the No. 200, is exceeded by more than 5.0 percent.
  3. The fracture control limit is exceeded by more than 10.0 percent.

## **B.8 Department Testing**

### **B.8.1 General**

- (1) The department will conduct verification testing to validate the quality of the product and independent assurance testing to evaluate the sampling and testing. The department will provide the contractor with a listing of names and telephone numbers of all QV and IA personnel for the project, and provide test results to the contractor within 2 business days after the department obtains the sample.

## **B.8.2 Verification Testing**

### **B.8.2.1 General**

- (1) The department will have an HTCP technician, or ACT working under a certified technician, perform QV sampling and testing. Department verification testing personnel must meet the same certification level requirements specified in B.2 for contractor testing personnel for each test result being verified. The department will notify the contractor before sampling so the contractor can observe QV sampling.
- (2) The department will conduct QV tests of each base aggregate size, source or classification, and type during placement conforming to the following:
  1. One non-random test on the first day of placement.
  2. At least one random test per 30,000 tons, or fraction of 30,000 tons, placed.
- (3) The department will sample randomly, at locations independent of the contractor's QC work, collecting one sample at each QV location. The department will collect QV samples after the material has been bladed, mixed, and shaped but before compacting; except, for 3-inch aggregates, the department will collect samples from the stockpile at load-out. The department will split each sample, test half for QV, and retain half.
- (4) The department will conduct QV tests in a separate laboratory and with separate equipment from the contractor's QC tests. The department will use the same methods specified for QC testing.
- (5) The department will assess QV results by comparing to the appropriate specification limits. If QV test results conform to the specification, the department will take no further action. If QV test results are nonconforming, add the QV to the QC test results as if it were an additional QC test.

### **B.8.3 Independent Assurance**

- (1) Independence assurance is unbiased testing the department performs to evaluate the department's QV and the contractor's QC sampling and testing including personnel qualifications, procedures, and equipment. The department will perform an IA review according to the department's independent assurance program. That review may include one or more of the following:
  1. Split sample testing.
  2. Proficiency sample testing.
  3. Witnessing sampling and testing.
  4. Test equipment calibration checks.
  5. Reviewing required worksheets and control charts.
  6. Requesting that testing personnel perform additional sampling and testing.
- (2) If the department identifies a deficiency, and after further investigation confirms it, correct that deficiency. If the contractor does not correct or fails to cooperate in resolving identified deficiencies, the engineer may suspend placement until action is taken. Resolve disputes as specified in B.9.

## **B.9 Dispute Resolution**

- (1) The engineer and contractor should make every effort to avoid conflict. If a dispute between some aspect of the contractor's and the engineer's testing program does occur, seek a solution mutually agreeable to the project personnel. The department and contractor may review the data, examine data reduction and analysis methods, evaluate sampling and testing procedures, and perform additional testing. Use ASTM E 178 to evaluate potential statistically outlying data.
- (2) Production test results, and results from other process control testing, may be considered when resolving a dispute.
- (3) If the project personnel cannot resolve a dispute, and the dispute affects payment or could result in incorporating non-conforming product, the department will use third party testing to resolve the dispute. The department's central office laboratory, or a mutually agreed on independent testing laboratory, will provide this testing. The engineer and contractor will abide by the results of the third party tests. The party in error will pay service charges incurred for testing by an independent laboratory. The department may use third party test results to evaluate the quality of questionable materials and determine the appropriate payment. The department may reject material or otherwise determine the final disposition of nonconforming material as specified in standard spec 106.5.

## **C (Vacant)**

## **D (Vacant)**

## **E Payment**

- (1) Costs for all sampling, testing, and documentation required under this special provision are incidental to this work. If the contractor fails to perform the work required under this special provision, the department may reduce the contractor's pay. The department will administer pay reduction under the non-performance of QMP administrative item.
- (2) For material represented by a running average exceeding a control limit, the department will reduce pay by 10 percent of the contract price for the affected Base Aggregate bid items listed in subsection A. The department will administer pay reduction under the Nonconforming QMP Base Aggregate Gradation or Nonconforming QMP Base Aggregate Fracture Administrative items. The department will determine the quantity of nonconforming material as specified in B.7.2.

301-010 (20100709)

## **18. QMP Ride; Incentive IRI Ride, Item 440.4410.S.**

### **A Description**

- (1) This special provision describes profiling pavements with a non-contact profiler, locating areas of localized roughness, and determining the International Roughness Index (IRI) for each wheel path segment.
- (2) Profile the final riding surface of all mainline pavements. Include auxiliary lanes in Category I and II segments; crossroads with county, state or U.S. highway designations greater than 1500 feet in continuous length; bridges, bridge approaches; and railroad crossings. Exclude roundabouts and pavements within 150 feet of the points of curvature of roundabout intersections.
- (3) The engineer may direct straightedging under standard spec 415.3.10 for pavement excluded from localized roughness under C.5.2 (1); for bridges; and for roundabouts and pavements within 150 feet of the points of curvature of roundabout intersections. Other surfaces being tested under this provision are exempt from straightedging requirements.

### **B (Vacant)**

### **C Construction**

#### **C.1 Quality Control Plan**

- (1) Submit a written quality control plan to the engineer at or before the pre-pave meeting. Ensure that the plan provides the following elements:
  1. An organizational chart with names, telephone numbers, current certifications and/or titles, and roles and responsibilities of all quality control personnel.
  2. The process by which quality control information and corrective action efforts will be disseminated to the appropriate persons. Include a list of recipients, the communication means that will be used, and action time frames.
  3. The methods and timing used for monitoring and/or testing ride quality throughout the paving process. Also indicate the approximate timing of acceptance testing in relation to the paving operations.
  4. The segment locations of each profile run used for acceptance testing.
  5. Traffic Control Plan

#### **C.2 Personnel**

- (1) Have a profiler operator, certified under the department's highway technician certification program (HTCP), operate the equipment, collect the required data, and analyze the results using the methods taught in the HTCP profiling course. Ensure that an HTCP-certified profiler operator supervises data entry into the material records system (MRS).

### **C.3 Equipment**

- (1) Furnish a profile-measuring device capable of measuring IRI from the list of department-approved devices published on the department's web site:  
<http://roadwaystandards.dot.wi.gov/standards/qmp/index.htm>
- (2) Unless the engineer and contractor mutually agree otherwise, arrange to have a calibrated profiler available when paving the final riding surface.
- (3) Perform daily calibration verification of the profiler using test methods according to the manufacturer's recommendations. Notify the engineer before performing the calibration verification. If the engineer requests, arrange to have the engineer observe the calibration verification and operation. Maintain records of the calibration verification activities, and provide the records to the engineer upon request.

### **C.4 Testing**

#### **C.4.1 Run and Reduction Parameters**

- (1) Enter the equipment-specific department-approved filter settings and parameters given in the approved profilers list on the department's QMP ride web site.  
<http://roadwaystandards.dot.wi.gov/standards/qmp/profilers.pdf>

#### **C.4.2 Contractor Testing**

- (1) Operate profilers within the manufacturer's recommended speed tolerances. Perform all profile runs in the direction of travel. Measure the longitudinal profile of each wheel track of each lane. The wheel tracks are 6.0 feet apart and centered in the traveled way of the lane.
- (2) Coordinate with the engineer to schedule profile runs for acceptance. The department may require testing to accommodate staged construction or if corrective action may be required.
- (3) Measure the profiles of each standard or partial segment. Define primary segments starting at a project terminus and running contiguously along the mainline to the other project terminus. Field-locate the beginning and ending points for each profile run. When applicable, align segment limits with the subplot limits used for testing under the QMP Concrete Pavement specification. Define segments one wheel path wide and distinguished by length as follows:
  1. Standard segments are 500 feet long.
  2. Partial segments are less than 500 feet long.



- (4) Treat partial segments as independent segments.

The department will categorize each standard or partial segment as follows:

<b>Segments with a Posted Speed Limit of 55 MPH or Greater</b>	
<b>Category</b>	<b>Description</b>
HMA I	Asphalt pavement with multiple opportunities to achieve a smooth ride. The following operations performed under this contract are considered as opportunities: a layer of HMA, a leveling or wedging layer of HMA, and diamond grinding or partial depth milling of the underlying pavement surface.
HMA II	Asphalt pavement with a single opportunity to achieve a smooth ride.
HMA III	Asphalt pavement segments containing any portion of a bridge, bridge approach, railroad crossing, or intersection. An intersection is defined as the area within the points of curvature of the intersection radii.
PCC II	Concrete pavement.
PCC III	Concrete pavement segments containing any portion of a bridge, bridge approach, railroad crossing, intersection or gap. An intersection is defined as the area within the points of curvature of the intersection radii.

<b>Segments with Any Portion Having a Posted Speed Limit Less Than 55 MPH</b>	
<b>Category</b>	<b>Description</b>
HMA IV	Asphalt pavement including intersections, bridges, approaches, and railroad crossings.
PCC IV	Concrete pavement including gaps, intersections, bridges, approaches, and railroad crossings.

#### **C.4.3 Verification Testing**

- (1) The department may conduct verification testing (QV) to validate the quality of the product. A HTCP certified profiler operator will perform the QV testing. The department will provide the contractor with a listing of the names and telephone numbers of all verification personnel for the project.
- (2) The department will notify the contractor before testing so the contractor can observe the QV testing. Verification testing will be performed independent of the contractor's QC work using separate equipment from the contractor's QC tests. The department will provide test results to the contractor within 1 business day after the department completes the testing.
- (3) The engineer and contractor will jointly investigate any testing discrepancies. The investigation may include additional testing as well as review and observation of both the department's and contractor's testing procedures and equipment. Both parties will document all investigative work.

- (4) If the contractor does not respond to an engineer request to resolve a testing discrepancy, the engineer may suspend production until action is taken. Resolve disputes as specified in C.6.

#### **C.4.4 Documenting Profile Runs**

- (1) Compute the IRI for each segment and analyze areas of localized roughness using the ProVAL software. Also, the contractor shall prepare the ProVAL Ride Quality Module Reports, showing the IRI for each segment and the areas of localized roughness exceeding an IRI of 200 in/mile. Use ride quality module report as follows:

	<u>Fixed Interval</u>	<u>Continuous (Localized Roughness)</u>
Base-length	500'	25'
Threshold	140"/Mile	200"/Mile

The ProVAL software is available for download at:

<http://www.roadprofile.com>.

- (2) As part of the profiler software outputs and ProVAL reports, document the areas of localized roughness. Field-locate the areas of localized roughness prior to the engineer's assessment for corrective actions. Document the reasons for areas excluded and submit to the engineer.
- (3) Within 5 business days after completing profiling of the pavement covered under this special provision, unless the engineer and contractor mutually agree to a different timeline, submit the electronic ProVAL project file containing the .ppf files for each profiler acceptance run data and Ride Quality Module Reports, in .pdf format using the department's Materials Reporting System (MRS) software available on the department's web site:

<http://www.atwoodsystems.com/mrs>

Notify the engineer when the Profiler Acceptance Run data and the Ride Quality Report have been submitted to the MRS system.

#### **C.5 Corrective Actions**

##### **C.5.1 General**

- (1) Analyze the data from the PROVAL reports and make corrective action recommendations to the department. The department will independently assess whether a repair will help or hurt the long-term pavement performance before deciding on corrective action. Correct the ride as the engineer directs in writing.

### C.5.2 Corrective Actions for Localized Roughness

- (1) Apply localized roughness requirements to all pavements, including HMA III, PCC III, HMA IV, and PCC IV; except localized roughness requirements will not be applied to pavements within 25 feet of the following surfaces if they are not constructed under this contract: bridges, bridge approaches, or railroad crossings. The department may direct the contractor to make corrections to the pavement within the 25-foot exclusionary zones.
- (2) The engineer will review each individual wheel track for areas of localized roughness. The engineer will assess areas of localized roughness within 5 business days of receiving notification that the reports were uploaded. The engineer will analyze the report documenting areas that exceed an IRI of 200 in/mile and do one of the following for each location:
  1. Direct the contractor to correct the area to minimize the effect on the ride.
  2. Leave the area of localized roughness in place with no pay reduction.
  3. Except for HMA IV and PCC IV segments, assess a pay reduction as follows for each location in each wheel path:

Localized Roughness IRI (in/mile)	Pay Reduction <sup>[1]</sup> (dollars)
> 200	(Length in Feet) x (IRI – 200)

<sup>[1]</sup> A maximum \$250 pay reduction may be assessed for locations of localized roughness that are less than or equal to 25 feet long. Locations longer than 25 feet may be assessed a maximum pay reduction of \$10 per foot.

- (3) The engineer will not direct corrective action or assess a pay reduction for an area of localized roughness without independent identification of that area as determined by physically riding the pavement. For corrections, use only techniques the engineer approves.
- (4) Re-profile corrected areas to verify that the IRI is less than 140 in/mile after correction. Submit a revised ProVAL ride quality module report to the reference documents section of the MRS for the corrected areas to validate the results.

### C.5.3 Corrective Actions for Excessive IRI

- (1) If an individual segment IRI exceeds 140 in/mile for HMA I, HMA II, and PCC II pavements after correction for localized roughness, the engineer may require the contractor to correct that segment. Correct the segment final surface as follows:

- HMA I: Correct to an IRI of 60 in/mile using whichever of the following methods as approved by the engineer:  
Mill and replace the full lane width of the riding surface excluding the paved shoulder.  
Continuous diamond grinding or fine-tooth milling the full lane width, if required, of the riding surface including adjustment of the paved shoulders.
- HMA II: Correct to an IRI of 85 in/mile using whichever of the following methods as approved by the engineer:  
Mill and replace the full lane width of the riding surface excluding the paved shoulder.  
Continuous diamond grinding or fine-tooth milling of the full lane width, if required, of the riding surface including adjustment of the paved shoulders
- PCC II: Correct to an IRI of 85 in/mile using whichever of the following methods as approved by the engineer:  
Continuous diamond grinding of the full lane width, if required, of the riding surface including adjustment of the paved shoulders. Conform to sections C.1 through C.4 of Concrete Pavement Continuous Diamond Grinding Special provision contained elsewhere in the contract.  
Remove and replace the full lane width of the riding surface.

- (2) Re-profile corrected segments to verify that the final IRI meets the above correction limits and there are no areas of localized roughness. Enter a revised ProVAL ride quality module report for the corrected areas to the reference documents section of the MRS. Segments failing these criteria after correction are subject to the engineer's right to adjust pay for non-conforming work under standard spec 105.3.

### **C.6 Dispute Resolution**

- (1) The engineer and contractor should make every effort to avoid conflict. If a dispute between some aspect of the contractor's and the engineer's testing program does occur, seek a solution mutually agreeable to the project personnel. The department and contractor may review the data, examine data reduction and analysis methods, evaluate testing procedures, and perform additional testing.
- (2) If the project personnel cannot resolve a dispute and the dispute affects payment or could result in incorporating nonconforming pavement, the department will use third party testing to resolve the dispute. The department's Quality Assurance Unit, or a mutually agreed on independent testing company, will provide this testing. The engineer and contractor will abide by the results of the third party tests. The party in

error will pay service charges incurred for testing by an independent tester. The department may use third party tests to evaluate the quality of questionable pavement and determine the appropriate payment.

#### **D Measurement**

- (1) The department will measure Incentive IRI Ride by the dollar, adjusted as specified in E.2.

#### **E Payment**

##### **E.1 Payment for Profiling**

- (1) Costs for furnishing and operating the profiler, documenting profile results, and correcting the final pavement surface are incidental to the contract. The department will pay separately for engineer-directed corrective action performed within the 25-foot exclusionary zones under C.5.2 as extra work.

##### **E.2 Pay Adjustment**

- (1) The department will pay incentive for ride under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
440.4410.S	Incentive IRI Ride	DOL

- (2) Incentive payment is not limited, either up or down, to the amount the schedule of items shows.
- (3) The department will administer disincentives for ride under the Disincentive IRI Ride administrative item.
- (4) The department will not assess disincentive on HMA III or PCC III segments. Incentive pay for HMA III and PCC III segments will be according to the requirements for the category of the adjoining segments.
- (5) The department will adjust pay for each segment based on the initial IRI for that segment. If corrective action is required, the department will base disincentives on the IRI after correction for pavement meeting the following conditions:
  - All Pavement: The corrective work is performed in a contiguous, full lane width section 500 feet long, or a length as agreed with the engineer.
  - HMA Pavements: The corrective work is a mill and inlay or full depth replacement and the inlay or replacement layer thickness conforms to standard spec 460.3.2.
  - Concrete Pavements: The corrective work is a full depth replacement and conforms to standard spec 415.
- (6) The department will adjust pay for 500-foot long standard segments nominally one wheel path wide using equation “QMP 1.04” as follows:

<b>HMA I</b>	
<b>Initial IRI (inches/mile)</b>	<b>Pay Adjustment<sup>[1]</sup> (dollars per standard segment)</b>
< 30	250
≥ 30 to <35	1750 – (50 x IRI)
≥ 35 to < 60	0
≥ 60 to < 75	1000 – (50/3 x IRI)
≥ 75	-250

<b>HMA II and PCC II</b>	
<b>Initial IRI (inches/mile)</b>	<b>Pay Adjustment<sup>[1][2]</sup> (dollars per standard segment)</b>
< 50	250
≥ 50 to < 55	2750 – (50 x IRI)
≥ 55 to < 85	0
≥ 85 to < 100	(4250/3) – (50/3 x IRI)
≥ 100	-250

<b>HMA IV and PCC IV</b>	
<b>Initial IRI (inches/mile)</b>	<b>Pay Adjustment<sup>[1][2]</sup> (dollars per standard segment)</b>
< 35	250
≥ 35 to < 45	1125-(25xIRI)
≥ 45	0

<sup>[1]</sup> If the engineer directs placing upper layer asphaltic mixtures between October 15 and May 1 for department convenience as specified in standard spec 450.3.2.1(5), the department will not adjust pay for ride on pavement the department orders the contractor to place when the temperature, as defined in standard spec 450.3.2.1(2), is less than 36 F.

<sup>[2]</sup> If the engineer directs placing concrete pavement for department convenience, the department will not adjust pay for ride on pavement the department orders the contractor to place when the air temperature falls below 35 F.

(7) The department will prorate the pay adjustment for partial segments based on their length.

440-010 (20130615)

## **19. Storm Sewer Pipe Reinforced Concrete Class III.**

*Add the following to standard spec 611.3.2, Connections:*

When connecting storm sewer pipe to an inlet, cut or extend the storm sewer pipe into the new structure. Cutting the structure or storm sewer pipe, any additional storm sewer pipe length or connections required are considered incidental to the new Storm Sewer Pipe Reinforced Concrete Class III.

## **20. Pipe Underdrain 6-Inch, Item 612.0106.**

*Add the following to standard spec 611.3.2, Connections:*

When connecting pipe underdrain to an inlet, cut or extend the underdrain into the new or existing structure. Cutting the structure or underdrain, any additional underdrain length or connections required are considered incidental to the new pipe underdrain.

## **21. Salvaged Rail.**

This work shall be in accordance to the pertinent requirements of standard spec 204 and as hereinafter provided.

Salvaged materials will become the property of Ashland County.

The existing guardrail shall be completely disassembled and all salvageable post, blocks, guardrail and hardware (brackets, reflectors, nuts, washers, bolts, etc.,) shall be carefully removed in a manner that will preclude any damage (cutting or destructive measures not allowed). The salvaged materials shall be stored on the right-of-way, outside the limits of construction where they may be retrieved by Ashland County forces. Salvaged materials will be stored as follows:

- Posts – Banded and neatly stacked on pallets.
- Blocks – Banded and neatly stacked on pallets.
- Beams – banded and neatly stacked on pallets.
- Hardware – in 5 gallon pails or burlap sacks

All other material shall be removed from the right-of-way and disposed of by the contractor.

Upon completion of the removal and storage of salvageable materials contact Ashland County Highway Commissioner Emmer Shields at (715) 274-3662.

This work will also include removal of posts (below ground) and backfilling of holes, as necessary.

## **22. Insulation Board Polystyrene, 4-Inch, Item 612.0902.S.01.**

### **A Description**

This special provision describes furnishing and placing polystyrene insulation board as shown on the plans and as hereinafter provided.

### **B Materials**

Provide polystyrene insulation board that conforms to the requirements for Extruded Insulation Board, AASHTO Designation M230, except as hereinafter revised.

Delete flammability requirement.

**C Construction**

Install polystyrene insulation board a minimum 4-feet wide and 6 inches above and below water main as shown on the plans and directed by the engineer and City of Ashland. Stagger joints to achieve 4 inch minimum thickness.

**D Measurement**

The department will measure Insulation Board Polystyrene (4-inch) by area in square yards of work, completed and accepted.

**E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
612.0902.S.01	Insulation Board Polystyrene 4-Inch	SY

Payment is full compensation for furnishing all excavation; furnishing, cutting, and placing the insulation board.

**23. Removing Signs Type II.**

Type II aluminum signs are the department's property. Return aluminum signs to the Northwest Region sign shop palletized for handling with a forklift. Northwest Eau Claire Sign Shop coordinators Steve Allard at (715) 855-7671 or Steve Sydow at (715) 855-7669 shall be notified at least 3 business days prior to delivery to coordinate shipment to be delivered to the Northwest Region Spooner Sign Shop at:

Junction 253 and 63  
Green Valley Road  
Spooner, WI 54801

Plywood Type II and all Type I and Type III signs are the contractor's property, unless the contract specifies otherwise. Dispose of these signs off of the right-of-way.

**24. Gate Valve and Box 8-Inch, Item SPV.0060.01.****A Description**

This special provision describes furnishing and installing gate valves and boxes as shown on the plans and as hereinafter provided.

**B Materials**

Gate Valves shall be in accordance to Chapter 8.27.0, *Wisconsin Water and Sewer Specifications*, except as modified herein:



1. Gate Valves: resilient seated, conforming to AWWA C515
2. Working Pressure: 200psi.
3. Ends: Mechanical Joint
4. Operating stem: non-rising with O-ring seals.
5. Operating nut: 2-inch square, open left.
6. Operating nut extension stem: 48-inch; shall be Diversified Fabricators, Inc., Economy Extension Stem, or equal.
7. Bonnet to body connection: stainless steel bolts and 50% zinc anode nuts.
8. Valve boxes: adjustable screw type.
9. Gate valve adaptor: Adaptor, Inc., or equal.

### **C Construction**

Install gate valves in accordance to Chapter 4.8.0, *Wisconsin Water and Sewer Specifications* and plan details and at locations shown on the plan sheets. Place and compact native material around all pipe embedment material.

### **D Measurement**

The department will measure Gate Valve and Box 8-Inch as each individual valve and box as each complete unit in place, acceptably completed.

### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.01	Gate Valve and Box 8-Inch	Each

Payment is full compensation for removing existing water main and gate valves and boxes where necessary; furnishing and installing all materials; and for making final adjustments to the valve and valve box; and for furnishing all labor, tools, equipment; and incidentals necessary to satisfactorily complete the work.

## **25. Cut Into and Connect to Existing Water Main, Item SPV.0060.02.**

### **A Description**

Cut into and connect to the existing water mains as shown on the plans and hereinafter provided.

### **B (Vacant)**

### **C Construction**

#### **C.1 General**

Construct all connections to existing water mains in accordance to Chapter 4.14.0, *Wisconsin Water and Sewer Specifications*. All necessary fittings, materials, labor, and equipment shall be incidental to the item. Have all necessary and proper materials and equipment immediately on hand when a water main is taken out of service for connection.

Cut into existing water main at locations as shown on the plans after meeting quality control (safe water, pressure tests, and conductivity tests) requirements for a new water main.

Disinfect all sleeves, fittings, and other appurtenances used in the connection with 50 parts per million chlorine solution prior to installation using a disinfection method approved by the engineer and the City of Ashland.

### **C.2 Interruption of Water Service**

Coordinate with the engineer and City of Ashland on allowable times to turn off the main in order to install gate valves and necessary pipe and thrust blocking and connect to the existing main. Times will be between 11:00 AM and 4:00 PM Monday through Friday.

Provide minimum 72 hours notice to residents, emergency services, local police, local radio station, engineer, and City of Ashland prior to taking any main out of service. Water shutdown shall be limited to 5 hours maximum time unless permitted by all out of service residents.

Alternatively, following the approval of the engineer, the contractor may elect to provide and install insertion valves for the valve installation with no additional compensation.

### **D Measurement**

The department will measure Cut Into and Connect to Existing Water Main as each individual unit, regardless of pipe size or material, acceptably completed.

### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.02	Cut Into and Connect to Existing Water Main	Each

Payment is full compensation for cutting existing water main; removing existing pipe, fittings, and sleeves as needed; connecting to existing water main; and for furnishing and placing all materials, including and required sleeves and fittings. Removal of 8-inch plugs, thrust blocks, and connection to new 8-inch water main shall be considered incidental to this item.

## **26. Install and Remove Temporary Service for Testing, Item SPV.0060.03.**

### **A Description**

This special provision describes installing and removing a temporary water service and all required fittings and material to allow safe water and pressure testing.

## **B Materials**

Materials shall be in accordance to Chapter 8.27.0, *Wisconsin Water and Sewer Specifications*, except as modified herein:

1. Service pipe: 1-Inch Copper ASTM B88 Type K, Soft or 1-Inch HDPE ASTM D2737 SDR 9, AWWA C901, NSF14, class 200
2. Corporation Stop: 1-Inch Mueller H-15000 or Ford #1 FB600 AWWA CC Inlet Thread and Copper Service Outlet Thread.
3. Curb Stop: 1-Inch Ford B22-444M or Mueller H15151, Copper Service Thread Inlet and Outlet.

## **C Construction**

Install corporation stop in accordance to Chapter 5.5.0, *Wisconsin Water and Sewer Specifications*, except as modified herein:

Locate the corporation stop and saddle within 5 feet of the Gate Valve 8-Inch, opposite the intended fill direction, installed as part of this project. Install the service pipe and corporation stop to allow for flushing, safe water sampling, and pressure testing of the newly installed water main. Once tests are satisfactory and completed the curb stop and service pipe shall be removed and the corporation turned off and left in place.

Alternative engineer and City of Ashland approved testing methods may be utilized with no additional compensation.

## **D Measurement**

The department will measure Install and Remove Temporary Service for Testing as each individual unit, acceptably completed.

## **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.03	Install and Remove Temporary Service for Testing	Each

Payment is full compensation for installing corporation stop; installing and removing service pipe and curb stop as needed; connecting to water main; and for furnishing and placing all materials, including and required sleeves and fittings. Removed curb stop shall become property of the City of Ashland once testing is completed.

## **27. Construction Staking Detour Widening Staking, Item SPV.0060.04.**

### **A Description**

This special provision describes surveying and staking the existing curb line and pavement edges at the two intersections where widening is required for the temporary detour route in order to reestablish the existing curb lines and pavement edges after the detour route is removed as shown on plans, and as hereinafter provided.

**B (Vacant)**

**C Construction**

Survey the existing curb line and pavement edges and offset stake the locations, reestablish the existing curb lines and pavement edges after the detour route is removed.

**D Measurement**

The department will measure Construction Staking Detour Widening Staking, will be measured as each individual unit, acceptably completed.

**E Payment**

The department will pay for measured quantities at the contract unit price under the following bid items:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.04	Construction Staking Detour Widening Staking	Each

Payment is full compensation for survey work necessary to locate and offset the existing curb line, pavement edges and profiles in order to reestablish the existing curb lines and pavement edges after the detour route is removed.

**28. Water Main Fittings, Item SPV.0085.01.**

**A Description**

This special provision describes furnishing and installing water main fittings as shown on the plans, as necessary to complete the work, and as hereinafter provided:

Fittings Include, but are not limited to, the following:

1. 8-Inch plugs
2. 8-Inch sleeve
3. 8-Inch bends

**B Materials**

All water main fittings shall meet the requirements of Chapter 8.22.0, *Wisconsin Water and Sewer Specifications* and the following requirements:

1. Joints: Mechanical.
2. Lugged retainer glands and/or mechanical joint restraints with Coral Blue fasteners are required.
3. All fittings shall be provided with zinc nut sacrificial anodes for 50% of the bolts, or a minimum of 4 bolts.

**C Construction**

All fittings shall be installed in accordance to Chapter 4.7.0 and 4.9.0, *Wisconsin Water and Sewer Specifications* and the requirements of this specification.

If contractor is not able to deflect pipe to facilitate installation without high points, contractor shall furnish and install necessary fittings.

Protect all water main fittings components in accordance to Chapter 4.9.3, *Wisconsin Water and Sewer Specifications*.

Install buttresses and/or thrust blocks for all water main fittings as outlined in Chapter 4.3.13 of the *Wisconsin Water and Sewer Specifications*.

**D Measurement**

The department will measure Water Main Fittings by the Pound, acceptably completed. Fitting weight does not include retainer glands, bolts, or sacrificial anodes.

The 19<sup>th</sup> Edition of the *American Pipe Manual, (Ductile Iron Mechanical Joints Section)* will be used to calculate the total pounds of Water Main Fittings.

**E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV. 0085.01	Water Main Fittings	LB

Payment is full compensation for furnishing and placing all material, fittings, buttress and or thrust block; and for furnishing all tools, labor, equipment, and incidentals necessary to complete the work.

**29. Concrete Curb and Gutter 6-Inch Sloped 20-Inch Type G Modified, Item SPV.0090.01.**

**A Description**

This special provision describes furnishing and installing Concrete Curb and Gutter 6-Inch Sloped 20-Inch Type G Modified as shown in the plan, in accordance to the pertinent requirements of standard spec 601 and as hereinafter provided.

**B Materials**

Furnish Concrete Curb and Gutter 6-Inch Sloped 20-Inch Type G Modified that is according to the pertinent requirements of standard spec 601.2.

**C Construction**

Construct the Concrete Curb and Gutter 6-Inch Sloped 20-Inch Type G Modified in accordance to standard spec 601.3 and as directed in the plans.

**D Measurement**

The department will measure Concrete Curb and Gutter 6-Inch Sloped 20-Inch Type G Modified by the linear foot, acceptably completed.

**E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0090.01	Concrete Curb and Gutter 6-Inch Sloped 20-Inch Type G Modified	LF

Payment is full compensation for completing all necessary work and for furnishing all labor, tools, equipment and incidentals necessary to complete the work.

### **30. Culvert Pipe Reinforced Concrete Class IV 96-Inch, Item SPV.0090.02.**

#### **A Description**

This special provision describes furnishing and installing Culvert Pipe Reinforced Concrete Class IV 96-Inch as shown in the plan, in accordance to the pertinent requirements of standard spec 601 and as hereinafter provided.

#### **B Materials**

Furnish Culvert Pipe Reinforced Concrete Class IV 96-Inch that is according to the pertinent requirements of standard spec 522.2.

#### **C Construction**

Construct the Culvert Pipe Reinforced Concrete Class IV 96-Inch in accordance to standard spec 522.3 and as directed in the plans.

#### **D Measurement**

The department will measure Culvert Pipe Reinforced Concrete Class IV 96-Inch by the linear foot, acceptably completed.

#### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0090.02	Culvert Pipe Reinforced Concrete Class IV 96-Inch	LF

Payment is full compensation for providing, hauling, and placing pipe, joint ties; for furnishing all excavating, including foundation or bed, and any necessary dewatering; for maintaining temporary drainage and for completing all necessary work.

### **31. Water Main 8-Inch, Item SPV.0090.03.**

#### **A Description**

This special provision describes furnishing and installing water main as shown on the plans and described by these specifications.

## **B Materials**

Water main pipe shall conform to *Wisconsin Water and Sewer Specifications*, Chapter 8.18.0, except as modified herein:

1. Pipe: Ductile Iron Pipe Class 52
2. Polyethelene film envelope is not required.

## **C Construction**

### **C.1 General**

Install water main in accordance to Chapters 4.1.0, 4.2.0, 4.3.0 and 4.4.0, *Wisconsin Water and Sewer Specifications*, and the requirements of these specifications. *Wisconsin Water and Sewer Specifications* Section 4.4.2.c does not apply; lead joints are not permitted.

Minimum cover from the top of pipe shall be no less than 8 feet, unless approved by the engineer. For cover less than 8 feet, furnish and install 2 layers of 2-inch polystyrene insulation, with the longitudinal and transverse joints offset by a minimum of one 1 foot. See Insulation Board Polystyrene 4-Inch item for more information.

The City of Ashland will provide site observation of the watermain work as deemed necessary by the city. Contractor is responsible for staking and elevation verification of watermain to ensure compliance with the plans. Contractor is responsible for specified testing, subject to coordination and supervision efforts of the city utility staff. The City of Ashland has final acceptance authority of the water utility improvements.

### **C.2 Conductivity**

All ductile iron water main will use cable bonding, copper strip conductors, or American Fastite conductive gaskets, or approved equals. Cable bonding and copper strapping will bypass valves and hydrant assemblies. The copper cable bonding will be a minimum of ½ inch diameter copper. The copper strip conductors will be a minimum 1/16 inch thick by ¾ inch wide. A continuity lead will be placed within 6 inches of all hydrants.

### **C.3 Deflection**

If failing to adequately deflect pipe within allowable tolerances in anticipation of a change in grade, furnish and install any necessary fittings to provide the required cover over the water main.

### **C.4 Separation Distances**

Maintain a minimum horizontal and/or vertical (under or over) distance of 18 inches between water main and sanitary or storm sewer piping. When crossing over or under sanitary or storm sewer pipes, located water main pipe joints as far as possible from the crossing.

### **C.5 Backfilling and Compaction of Native Material**

Compact native material by using a sheep's foot and placing the soil in 12"-18" lifts. The upper 3 feet of trench shall be compacted to a standard Proctor density of 100 percent and the area under the upper 3 feet shall be compacted to a standard Proctor density of 95 percent. No substitutions of compacting equipment are allowed unless specifically

permitted by the engineer. All compaction and compliance testing is considered incidental to the water main being installed. One test minimum is required during backfill. If the first test is satisfactory the engineer or City of Ashland may waive any other compaction and compliance testing if the equipment, operator, methods, and native soil material remain the same. If at any time any of the previously mentioned operations or materials change, the engineer or City of Ashland may require additional compaction and compliance testing at no additional cost.

## **C.6 Quality Control**

### **C.6.1 Hydrostatic Tests**

Perform all hydrostatic tests in accordance to Chapter 4.15.0, *Wisconsin Water and Sewer Specifications*.

### **C.6.2 Electrical Conductivity**

Test the system for electrical continuity and current capacity. Perform the electrical test after the hydrostatic tests while the line is at normal operating pressure.

1. Pass current of 350 amperes plus or minus 10 percent through the pipeline for 5 minutes. Continuously measure current flow with a suitable ammeter. Current shall remain steady without interruption or fluctuation in excess of 10% throughout the test period.
2. Insufficient current or intermittent current or arcing, indicated by fluctuations in the ammeter needle, will be evidence of defective contact in the pipeline. Immediately determine the cause, isolate, and correct the problem. Retest according to these specifications.
3. Supply all testing equipment and obtain prior approval of the engineer for the testing equipment supplied.

### **C.6.3 Disinfection of Water Main**

Disinfect all water mains in accordance to Chapter 4.16.0, *Wisconsin Water and Sewer Specifications*, except as modified herein:

1. Chapter 4.16.5 shall be modified that sampling and testing, including costs thereof, are the contractor's responsibility. Sample testing shall be coordinated and completed using the City of Ashland Public Works department utility lab.
2. Swab connections to existing water mains that must be placed back in service with a chlorine solution as approved by the engineer.

## **D Measurement**

The department will measure Water Main 8-Inch along the axis of the pipe in linear feet in place. Segments between valves, fittings, and hydrants will be measured from the center of valves, fittings, and hydrants with no deductions. All lengths will be measured in a horizontal plane unless the grade of the pipe exceeds 15 percent.

## **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:



ITEM NUMBER	DESCRIPTION	UNIT
SPV. 0090.03	Water Main 8-Inch	LF

Payment is full compensation for furnishing and placing all material; and for furnishing all tools, labor, equipment, and incidentals necessary to complete the work. In addition, backfill, compaction, pipe trench stabilizing aggregate, Class B pipe embedment, testing, disinfection and removal of existing water main are considered incidental to the unit prices for water main.

### **32. Concrete Curb and Gutter Cure and Seal Treatment, Item SPV.0090.04.**

#### **A Description**

This work includes treating all newly constructed concrete curb and gutter with a surface cure and seal treatment as shown on plans, and as hereinafter provided.

#### **B Materials**

The treating material shall conform to ASTM C1315, ASTM C309, and AASHTO M148 specifications and be produced by a manufacturer on the approved list.

#### **C Construction**

Application rates for the treating material shall be in accordance to the manufacturer's specifications.

#### **D Measurement**

The department will measure the Concrete Curb and Gutter Cure and Seal Treatment by the linear foot, acceptably completed.

#### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0090.04	Concrete Curb and Gutter Cure and Seal Treatment	LF

Payment is full compensation for furnishing and applying Concrete Curb and Gutter Cure and Seal Treatment.

### **33. Special Storm Sewer Protection, Item SPV.0105.01.**

#### **A Description**

Some elements of the storm sewer system may be exposed during excavation and may require protection and/or stabilization. This special provision describes Special Storm Sewer Protection as directed in the plans and by the engineer.

#### **B (Vacant)**

**C Construction**

Construct the storm sewers, protect and stabilize the existing system in accordance to standard spec 607.3 and as directed in the plans.

**D Measurement**

The department will measure Special Storm Sewer Protection as a single lump sum unit of work, acceptably completed.

**E Payment**

The department will pay for measured quantities at the contract unit price under the following bid items:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0105.01	Special Storm Sewer Protection	LS

Payment is full compensation for furnishing all materials, labor, tools, equipment and incidentals necessary to protect and/or stabilize the system.

**34. Concrete Sidewalk Cure and Seal Treatment, Item SPV.0165.01.****A Description**

This work includes treating all newly constructed concrete sidewalks with a surface protective treatment as shown on plans, and as hereinafter provided.

**B Materials**

The treating material shall conform to ASTM C1315, ASTM C309, and AASHTO M148 specifications and be produced by a manufacturer on the approved list.

**C Construction**

Application rates for the treating material shall be in accordance to the manufacturer's specifications.

**D Measurement**

The department will measure the Concrete Sidewalk Cure and Seal Treatment by the square foot, acceptably completed.

**E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0165.01	Concrete Sidewalk Cure and Seal Treatment	SF

Payment is full compensation for furnishing and applying Cure and Seal Treatment for concrete sidewalk.

**35. Concrete Pavement Repair Doweled Special, Item SPV.0180.01;  
Concrete Pavement Replacement Doweled Special, Item SPV.0180.02.**

**A Description**

This special provision describes construction of Concrete Pavement Repair Doweled Special and Concrete Pavement Replacement Repair Doweled Special accordance with standard spec 415, standard spec 416, and standard spec 710. QMP for these items shall be combined and covered under standard spec 716, as shown on the plans, and hereinafter provided. The repaired surface will be the pavement's final surface.

**B Materials**

**B.1 Concrete Mixtures**

*Supplement standard spec 716.2 with the following:*

Concrete mix design shall be the responsibility of the contractor. Provide the concrete mix designs necessary to accommodate the contractors operations and contractor scheduling according to the traffic provisions and prosecution and progress provisions included in the plan.

Chloride based accelerators shall be allowed in any concrete mixes that are specifically designed to meet opening strength within six hours or less within the time of placement to accommodate lane restrictions as specified in the contract.

QC slump testing is not required for any concrete mixture that has been approved and has at least 700 lbs of cement per cubic yard.

Random 28-day compressive strength cylinders are not required.

Any chemical admixture(s) to be used, other than air-entraining agents or water reducers from the department's approved list, must be approved in advance by the engineer. The water-cement ratio of the concrete mixture shall not exceed 0.40.

**C Construction**

**C.1 General**

Perform work when USH 2 traffic is being detoured. Perform work in areas closed to traffic only. Restrict work to single lane closures. Perform work to cause the least possible inconvenience to local traffic.

Prepare the base as specified in standard spec 211 using engineer-approved hand methods. Place the repair to the thickness of the contiguous pavement. In lieu of replacing base that was damaged or removed, the contractor will be allowed to place concrete to fill this area at no additional cost to the department.

## **C.2 Concrete Repair**

*Supplement standard spec 416.3.7 and standard spec 416.3.8.2 with the following:*

Deposit concrete to require as little re-handling as possible, place and consolidate by hand with an immersion type vibrator, and strike off and finish flush with adjoining surfaces.

Any finished surface within the repair that is 0.5 inches higher than the adjoining pavement shall be diamond ground to match elevation. Any individual repair that, within its defined boundaries, has any finished surface that is 0.5 inch lower than the adjoining pavement shall be paid at 50% of the bid price within the individual repair. Repair areas greater than 15 feet in length shall meet the Surface Testing and Correction parameters as defined in 415.3.10.

Unless the plans show or the engineer directs otherwise, the department will not require ties to the existing adjoining pavement within repairs that are fifteen feet or less in length.

Construct, cure, and protect as specified for concrete pavement repairs in standard spec 416.

## **C.3 Concrete Replacement**

Placement of Concrete Pavement Replacement Doweled Special shall fall under standard spec 415.3.6 through standard spec 415.3.14.

## **C.4 Opening to Traffic**

Concrete Pavement Repair Doweled Special and Concrete Pavement Replacement Repair Doweled Special must attain a minimum compressive strength of 2500 psi before they can be opened to traffic. The opening strength shall be determined by Maturity Methods, standard spec 502.3.10.1.3.3, or other engineer approved methods. If cylinders are used, the compressive strength shall be measured by testing concrete cylinders cured in the field on top of the slab, under the curing blanket. At least two cylinders shall be tested in determining the attained strength of concrete repairs for the purpose of opening the pavement to traffic. The average of test results for the two cylinders shall be used to determine compliance, except that neither cylinder may be less than 10 percent below the required strength.

If opening is not controlled by maturity methods or cylinders, cores may be substituted.

## **C.5 Details**

Details for the construction of these two items shall fall under SDD 13C9-10a, 10b, 10c Concrete Pavement Repair and Replacement and plan details.

## **D Measurement**

The department will measure Concrete Pavement Repair Doweled Special and Concrete Pavement Replacement Repair Doweled Special by the square yard, acceptably completed.

**E Payment**

The department will pay for measured quantity at the contract unit price under the following bid items:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0180.01	Concrete Pavement Repair Doweled Special	SY
SPV.0180.02	Concrete Pavement Replacement Doweled Special	SY

Payment is full compensation for removing old pavement and disposing of removed materials; for preparing the base; for providing the concrete, curing and protecting concrete.

The department will pay separately for the following bid items Sawing Concrete, Drilled Tie Bars and Drilled Dowel Bars into existing pavement.

## **ADDITIONAL SPECIAL PROVISION 4**

### **Payment to First-Tier Subcontractors**

Within 10 calendar days of receiving a progress payment for work completed by a subcontractor, pay the subcontractor for that work. The prime contractor may withhold payment to a subcontractor if, within 10 calendar days of receipt of that progress payment, the prime contractor provides written notification to the subcontractor and the department documenting "just cause" for withholding payment.

The prime contractor may also withhold routine retainage from payments due subcontractors.

### **Payment to Lower-Tier Subcontractors**

Ensure that subcontracting agreements at all tiers provide prompt payment rights to lower-tier subcontractors that parallel those granted first-tier subcontractors in this provision.

### **Release of Routine Retainage**

After granting substantial completion the department may reduce the routine retainage withheld from the prime contractor to 75 percent of the original total amount retained.

When the Department sends the semi-final estimate the department may reduce the routine retainage withheld from the prime contractor to 10 percent of the original total amount retained.

Within 30 calendar days of receiving the semi-final estimate from the department, submit written certification that subcontractors at all tiers are paid in full for acceptably completed work and that no routine retainage is being withheld. The department will pay the prime contractor in full and reduce the routine retainage withheld from the prime contractor to zero when the department approves the final estimate.

This special provision does not limit the right of the department, prime contractor, or subcontractors at any tier to withhold payment for work not acceptably completed or work subject to an unresolved contract dispute.

**ADDITIONAL SPECIAL PROVISION 6****ASP 6 - Modifications to the standard specifications**

*Make the following revisions to the 2014 edition of the standard specifications:*

---

**101.3 Definitions**

*Replace the definition of semi-final estimate with the following effective with the December 2013 letting:*

**Semi-final estimate** An estimate indicating the engineer has measured and reported all contract quantities and materials requirements.

---

**105.11.1 Partial Acceptance**

*Replace paragraph two with the following effective with the December 2013 letting:*

- (2) Partial acceptance will relieve the contractor of maintenance responsibility for the designated portion of the work. By relieving the contractor of maintenance, the department does not relieve the contractor of responsibility for defective work or damages caused by the contractor's operations. Do not construe partial acceptance to be conditional final acceptance or final acceptance of any part of the project, or a waiver of any legal rights specified under 107.16.
- 

**105.11.2 Final Acceptance**

*Retitle and replace the entire text with the following effective with the December 2013 letting:*

**105.11.2 Project Acceptance****105.11.2.1 Inspection****105.11.2.1.1 General**

- (1) Notify the engineer when the project is substantially complete as defined in 105.11.2.1.3. As soon as it is practical, the engineer will inspect the work and categorize it as one of the following:
  1. Unacceptable or not complete.
  2. Substantially complete.
  3. Complete.

**105.11.2.1.2 Unacceptable or Not Complete**

- (1) The engineer will identify, in writing, work that is unacceptable or not complete. Immediately correct or complete that work. The engineer will assess contract time until the work is corrected or completed.
- (2) Proceed as specified in 105.11.2.1.1 until the engineer determines that the work is complete.

**105.11.2.1.3 Substantially Complete**

- (1) The project is substantially complete and the engineer will no longer assess contract time if the contractor has completed all contract bid items and change order work, except for the punch-list. As applicable, the following must have occurred:
  1. All lanes of traffic are open on a finished surface.
  2. All signage and traffic control devices are in place and operating.
  3. All drainage, erosion control, excavation, and embankments are completed.
  4. All safety appurtenances are completed.
- (2) The engineer will provide a written punch-list enumerating work the contractor must perform and documents the contractor must submit before the the engineer will categorize the work as complete.
  1. Punch-list work includes uncompleted cleanup work required under 104.9 and minor corrective work. Immediately correct or complete the punch-list work. The engineer may restart contract time if the contractor does not complete the punch-list work within 5 business days after receiving the written punch-list. The engineer and contractor may mutually agree to extend this 5-day requirement.
  2. Punch-list documents include whatever contract required documentation is missing. The engineer may restart contract time if the contractor does not submit the punch-list documents within 15 business days after receiving the written punch-list. The engineer and contractor may mutually agree to extend this 15-day requirement.
- (3) Proceed as specified in 105.11.2.1.1 until the work is complete.

**105.11.2.1.4 Complete**

- (1) The project is complete when the contractor has completed all contract bid items, change order work, and punch-list work including the submission of all missing documentation.

**105.11.2.2 Conditional Final Acceptance**

- (1) When the engineer determines that the project is complete, the engineer will give the contractor written notice of conditional final acceptance relieving the contractor of maintenance responsibility for the completed work.

**105.11.2.3 Final Acceptance**

- (1) The engineer will grant final acceptance of the project after determining that all contract is work complete; all contract, materials, and payroll records are reviewed and approved; and the semi-final estimate quantities are final under 109.7.
- (2) Failure to discover defective work or materials before final acceptance does not prevent the department from rejecting that work or those materials later. The department may revoke final acceptance if the department discovers defective work or materials after it has accepted the work.

**105.13.3 Submission of Claim**

*Replace paragraph one with the following effective with the December 2013 letting:*

- (1) Submit the claim to the project engineer as promptly as possible following the submission of the Notice of Claim, but not later than final acceptance of the project as specified in 105.11.2.3. If the contractor does not submit the claim before final acceptance of the project, the department will deny the claim.

**107.17.3 Railroad Insurance Requirements**

*Replace paragraph one with the following effective with the December 2013 letting:*

- (1) If required by the special provisions, provide or arrange for a subcontractor to provide railroad protective liability insurance in addition to the types and limits of insurance required in 107.26. Keep railroad protective liability insurance coverage in force until completing all work, under or incidental to the contract, on the railroad right of way or premises of the railroad and until the engineer determines that the work is complete as specified in 105.11.2.1.4.

**107.26 Standard Insurance Requirements**

*Replace paragraph one with the following effective with the December 2013 letting:*

- (1) Maintain the following types and limits of commercial insurance in force until the engineer determines that the work is complete as specified in 105.11.2.1.4.

**TABLE 107-1 REQUIRED INSURANCE AND MINIMUM COVERAGES**

TYPE OF INSURANCE	MINIMUM LIMITS REQUIRED <sup>[1]</sup>
1. Commercial general liability insurance endorsed to include blanket contractual liability coverage. <sup>[2]</sup>	\$2 million combined single limits per occurrence with an annual aggregate limit of not less than \$4 million.
2. Workers' compensation.	Statutory limits
3. Employers' liability insurance.	Bodily injury by accident: \$100,000 each accident Bodily injury by disease: \$500,000 each accident \$100,000 each employee
4. Commercial automobile liability insurance covering all contractor-owned, non-owned, and hired vehicles used in carrying out the contract. <sup>[2]</sup>	\$1 million-combined single limits per occurrence.

<sup>[1]</sup> The contractor may satisfy these requirements with primary insurance coverage or with excess/umbrella policies.

<sup>[2]</sup> The Wisconsin Department of Transportation, its officers, agents, and employees shall be named as an additional insured under the general liability and automobile liability insurance.



**108.14 Terminating the Contractor's Responsibility**

Replace paragraph one with the following effective with the December 2013 letting:

- (1) The contractor's responsibilities are terminated, except as set forth in the contract bond and specified in 107.16, when the department grants final acceptance as specified in 105.11.2.3.

---

**109.2 Scope of Payment**

Replace paragraph two with the following effective with the December 2013 letting:

- (2) The department will pay for the quantity of work acceptably completed and measured for payment as the measurement subsection for each bid item specifies. Within the contract provide means to furnish and install the work complete and in-place. Payment is full compensation for everything required to perform the work under the applicable bid items including, but not limited to, the work elements listed in the payment subsection. Payment also includes all of the following not specifically excluded in that payment subsection:
  1. Furnishing and installing all materials as well as furnishing the labor, tools, supplies, equipment, and incidentals necessary to perform the work.
  2. All losses or damages, except as specified in 107.14, arising from one or more of the following:
    - The nature of the work.
    - The action of the elements.
    - Unforeseen difficulties encountered during prosecution of the work.
  3. All insurance costs, expenses, and risks connected with the prosecution of the work.
  4. All expenses incurred because of an engineer-ordered suspension, except as specified in 104.2.2.3.
  5. All infringements of patents, trademarks, or copyrights.
  6. All other expenses incurred to complete and protect the work under the contract.

---

**109.6.1 General**

Replace paragraphs three and four with the following effective with the December 2013 letting:

- (3) The department's payment of an estimate before conditional final acceptance of the work does not constitute the department's acceptance of the work, and does not relieve the contractor of responsibility for:
  1. Protecting, repairing, correcting, or renewing the work.
  2. Replacing all defects in the construction or in the materials used in the construction of the work under the contract, or responsibility for damage attributable to these defects.
- (4) The contractor is responsible for all defects or damage that the engineer may discover on or before the engineer's conditional final acceptance of the work. The engineer is the sole judge of these defects or damage, and the contractor is liable to the department for not correcting all defects or damage.

---

**109.7 Acceptance and Final Payment**

Replace paragraphs one and two with the following effective with the December 2013 letting:

- (1) After the engineer grants conditional final acceptance of the work as specified in 105.11.2.2 and reviews required document submittals and materials test reports, the engineer will issue the semi-final estimate.
- (2) Within 30 calendar days after receiving the semi-final estimate, submit to the engineer a written statement of agreement or disagreement with the semi-final estimate. For an acceptable statement of disagreement, submit an item-by-item list with reasons for each disagreement. If the contractor does not submit this written statement within those 30 days, the engineer will process the final estimate for payment. The engineer and the contractor can mutually agree to extend this 30-day submission requirement.

**450.3.3 Maintaining the Work**

*Replace paragraph one with the following effective with the December 2013 letting:*

- (1) Protect and repair the prepared foundation, tack coat, base, paved traffic lanes, shoulders, and seal coat. Correct all rich or bleeding areas, breaks, raveled spots, or other nonconforming areas in the paved surface.

**455.3.2.5 Maintaining Tack Coat**

*Replace paragraph one with the following effective with the December 2013 letting:*

- (1) Protect and repair the existing surface and the tack coat. Correct areas with excess or deficient tack material and any breaks, raveled spots, or other areas where bond might be affected.

**460.2.2.3 Aggregate Gradation Master Range**

*Replace paragraph one with the following effective with the January 2014 letting:*

- (1) Ensure that the aggregate blend, including recycled material and mineral filler, conforms to the gradation requirements in table 460-1. The values listed are design limits; production values may exceed those limits.

**TABLE 460-1 AGGREGATE GRADATION MASTER RANGE AND VMA REQUIREMENTS**

SIEVE	PERCENTS PASSING DESIGNATED SIEVES						
	NOMINAL SIZE						
	37.5 mm	25.0 mm	19.0 mm	12.5 mm	9.5 mm	SMA 12.5 mm	SMA 9.5 mm
50.0-mm	100						
37.5-mm	90 – 100	100					
25.0-mm	90 max	90 - 100	100				
19.0-mm	—	90 max	90 - 100	100		100	
12.5-mm	—	—	90 max	90 - 100	100	90 - 97	100
9.5-mm	—	—	—	90 max	90 - 100	58 - 72	90 - 100
4.75-mm	—	—	—	—	90 max	25 - 35	35 - 45
2.36-mm	15 – 41	19 - 45	23 - 49	28 - 58	20 - 65	15 - 25	18 - 28
75-µm	0 – 6.0	1.0 - 7.0	2.0 - 8.0	2.0 - 10.0	2.0 - 10.0	8.0 - 12.0	10.0 - 14.0
% MINIMUM VMA	11.0	12.0	13.0	14.0 <sup>[1]</sup>	15.0 <sup>[2]</sup>	16.0	17.0

<sup>[1]</sup> 14.5 for E-3 mixes.

<sup>[2]</sup> 15.5 for E-3 mixes.

**460.2.7 HMA Mixture Design**

*Replace paragraph one with the following effective with the January 2014 letting:*

- (1) For each HMA mixture type used under the contract, develop and submit an asphaltic mixture design according to the department's test method number 1559 as described in CMM 8-66 and conforming to the requirements of table 460-1 and table 460-2. The values listed are design limits; production values may exceed those limits. The department will review mixture designs and report the results of that review to the designer according to the department's test method number 1559.

TABLE 460-2 MIXTURE REQUIREMENTS

Mixture type	E - 0.3	E - 1	E - 3	E - 10	E - 30	E - 30x	SMA
ESALs x 10 <sup>6</sup> (20 yr design life)	< 0.3	0.3 - < 1	1 - < 3	3 - < 10	10 - < 30	>= 30	—
LA Wear (AASHTO T96)							
100 revolutions(max % loss)	13	13	13	13	13	13	13
500 revolutions(max % loss)	50	50	45	45	45	45	40
Soundness (AASHTO T104) (sodium sulfate, max % loss)	12	12	12	12	12	12	12
Freeze/Thaw (AASHTO T103) (specified counties, max % loss)	18	18	18	18	18	18	18
Fractured Faces (ASTM 5821) (one face/2 face, % by count)	60 / —	65 / —	75 / 60	85 / 80	98 / 90	100/100	100/90
Flat & Elongated (ASTM D4791) (max %, by weight)	5 (5:1 ratio)	5 (5:1 ratio)	5 (5:1 ratio)	5 (5:1 ratio)	5 (5:1 ratio)	5 (5:1 ratio)	20 (3:1ratio)
Fine Aggregate Angularity (AASHTO T304, method A, min)	40	40	43	45	45	45	45
Sand Equivalency (AASHTO T176, min)	40	40	40	45	45	50	50
Gyratory Compaction							
Gyrations for N <sub>ini</sub>	6	7	7	8	8	9	8
Gyrations for N <sub>des</sub>	40	60	75	100	100	125	65
Gyrations for N <sub>max</sub>	60	75	115	160	160	205	160
Air Voids, %V <sub>a</sub> (%G <sub>mm</sub> N <sub>des</sub> )	4.0 (96.0)	4.0 (96.0)	4.0 (96.0)	4.0 (96.0)	4.0 (96.0)	4.0 (96.0)	4.0 (96.0)
% G <sub>mm</sub> N <sub>ini</sub>	<= 91.5 <sup>[1]</sup>	<= 90.5 <sup>[1]</sup>	<= 89.0 <sup>[1]</sup>	<= 89.0	<= 89.0	<= 89.0	—
% G <sub>mm</sub> N <sub>max</sub>	<= 98.0	<= 98.0	<= 98.0	<= 98.0	<= 98.0	<= 98.0	—
Dust to Binder Ratio <sup>[2]</sup> (% passing 0.075/P <sub>be</sub> )	0.6 - 1.2	0.6 - 1.2	0.6 - 1.2	0.6 - 1.2	0.6 - 1.2	0.6 - 1.2	1.2 - 2.0
Voids filled with Binder (VFB or VFA, %)	68 - 80 <sup>[4] [5]</sup>	65 - 78 <sup>[4]</sup>	65 - 75 <sup>[3] [4]</sup>	65 - 75 <sup>[3] [4]</sup>	65 - 75 <sup>[3] [4]</sup>	65 - 75 <sup>[3] [4]</sup>	70 - 80
Tensile Strength Ratio (TSR) (ASTM 4867)							
no antistripping additive	0.70	0.70	0.70	0.70	0.70	0.70	0.70
with antistripping additive	0.75	0.75	0.75	0.75	0.75	0.75	0.75
Draindown at Production Temperature (%)	—	—	—	—	—	—	0.30

<sup>[1]</sup> The percent maximum density at initial compaction is only a guideline.

<sup>[2]</sup> For a gradation that passes below the boundaries of the caution zone(ref. AASHTO MP3), the dust to binder ratio limits are 0.6 - 1.6.

<sup>[3]</sup> For 9.5mm and 12.5 mm nominal maximum size mixtures, the specified VFB range is 70 - 76%.

<sup>[4]</sup> For 37.5mm nominal maximum size mixes, the specified VFB lower limit is 67%.

<sup>[5]</sup> For 25.0mm nominal maximum size mixes, the specified VFB lower limit is 67%.

**460.2.8.2.1.5 Control Limits**

*Replace paragraph one with the following effective with the January 2014 letting:*

- (1) Conform to the following control limits for the JMF and warning limits based on a running average of the last 4 data points:

ITEM	JMF LIMITS	WARNING LIMITS
Percent passing given sieve:		
37.5-mm	+/- 6.0	+/- 4.5
25.0-mm	+/- 6.0	+/- 4.5
19.0-mm	+/- 5.5	+/- 4.0
12.5-mm	+/- 5.5	+/- 4.0
9.5-mm	+/- 5.5	+/- 4.0
2.36-mm	+/- 5.0	+/- 4.0
75-µm	+/- 2.0	+/- 1.5
Asphaltic content in percent	- 0.3	- 0.2
Air voids in percent	+/- 1.3	+/- 1.0
VMA in percent <sup>[1]</sup>	- 0.5	- 0.2

<sup>[1]</sup> VMA limits based on minimum requirement for mix design nominal maximum aggregate size in Table 460-1.

- (2) Warning bands are defined as the area between the JMF limits and the warning limits.

**460.2.8.2.1.6 Job Mix Formula Adjustment**

*Replace the entire text with the following effective with the January 2014 letting:*

- (1) The contractor may request adjustment of the JMF according to the department's test method number 1559. Have an HTCP HMA technician certified at a level appropriate for process control and troubleshooting or mix design submit a written JMF adjustment request. Ensure that the resulting JMF is within specified master gradation bands. The department will have an HMA technician certified at level III review the proposed adjustment and, if acceptable, issue a revised JMF.
- (2) The department will not allow adjustments that do the following:
- Exceed specified JMF tolerance limits.
  - Reduce the JMF asphalt content unless the production VMA running average meets or exceeds the minimum VMA design requirement defined in table 460-1 for the mixture produced.
- (3) Have an HMA technician certified at level II make related process adjustments. If mixture redesign is necessary, submit a new JMF, subject to the same specification requirements as the original JMF.

**520.3.8 Protection After Laying**

*Delete the entire subsection.*

**614.2.1 General**

*Replace paragraphs five and six with the following effective with the December 2013 letting:*

- (5) Furnish zinc coated wire rope and fitting conforming to the plans and galvanized according to ASTM A741.
- (6) Before installation store galvanized components above ground level and away from surface run off. The department may reject material if the zinc coating is physically damaged or oxidized.
- (7) Provide manufacturer's drawings, and installation and maintenance instructions when providing proprietary systems.

---

**614.2.3 Steel Rail and Fittings**

Replace paragraph one with the following effective with the December 2013 letting:

- (1) Furnish galvanized steel rail conforming to AASHTO M180 class A, type II beam using the single-spot test coating requirements. Furnish plates, anchor plates, post mounting brackets, and other structural steel components conforming to 506.2.2.1 and hot-dip galvanized according to ASTM A123.
- 

**614.2.7 Crash Cushions**

Replace paragraph one with the following effective with the December 2013 letting:

- (1) Furnish permanent and temporary crash cushions from the department's approved products list. Use cushions as wide or wider than the plan back-width. Furnish transitions conforming to the crash cushion manufacturer's design and specifications. Submit manufacturer crash cushion and transition design details to engineer before installing.
- 

**616.3.1 General**

Replace paragraph six with the following effective with the December 2013 letting:

- (6) Remove and dispose of all excess excavation and surplus materials from the fence site.
- 

**618.3.3 Restoration**

Replace paragraph one with the following effective with the December 2013 letting:

- (1) Upon termination of hauling operations and before conditional final acceptance, restore all haul roads, including drainage facilities and other components, to the equivalent of pre-hauling conditions.
- 

**627.3.1 General**

Replace paragraph four with the following effective with the December 2013 letting:

- (4) Maintain the mulched areas and repair all areas damaged by wind, erosion, traffic, fire or other causes.
- 

**637.3.2.1 General**

Delete paragraph three effective with the December 2013 letting.

---

**670.3.4.2 Post-Construction Work**

Replace paragraph one with the following effective with the December 2013 letting:

- (1) Submit 5 copies of ITS documentation including but not limited to the following:
  - Operator's manual: for contractor furnished equipment, submit a manual containing detailed operating instructions for each different type or model of equipment and or operation performed.
  - Maintenance procedures manuals: for contractor furnished equipment, submit a manual containing detailed preventive and corrective maintenance procedures for each type or model of equipment furnished.
  - Cabinet fiber optic wiring diagram: submit a cabinet wiring diagram, identified by location for each cabinet. Include both electrical wiring and fiber optic conductor and cable connections. Place one copy of the fiber optic wiring diagram in a weatherproof holder in the cabinet. Deliver the other copies to the engineer.
  - As-built drawings: submit final as-built drawings that detail the final placement of all conduit, cabling, equipment, and geometric modifications within the contract. Provide all documentation in an electronic format adhering to the region's ITS computer aided drafting standards and according to the department's as-built requirements. The department will review the as-built drawings for content and electronic format. Modify both the content and format of as-built drawings until meeting all requirements.
  - Equipment inventory list: submit an inventory list including serial number, make, model, date installed, and location installed of all equipment installed under the contract.

---

## Errata

---

*Make the following corrections to the 2014 edition of the standard specifications:*

---

### 415.3.14 Protecting Concrete

Correct errata by referencing the opening to service specification.

- (1) Erect and maintain suitable barricades and, if necessary, provide personnel to keep traffic off the newly constructed pavement until it is opened for service as specified in 415.3.15. Conform to 104.6 for methods of handling and facilitating traffic.
- 

### 501.2.9 Concrete Curing Materials

Correct errata by changing AASHTO M171 to ASTM C171.

- (2) Furnish sheeting conforming to ASTM C171 for white opaque polyethylene film, except that the contractor may use clear or black polyethylene for cold weather protection.
- 

### 607.2 Materials

Correct errata by changing AASHTO M198 to ASTM C990.

- (1) Use materials conforming to the requirements for the class of material named and specified below.
 

Composite pipe, couplings, fittings and joint materials .....	ASTM D2680
Annular rubber and plastic gaskets for flexible, watertight joints .....	ASTM C990
External rubber gaskets, mastic, and protective film.....	ASTM C877
Mortar .....	519.2.3
- 

### 637.2.1.3 Sheet Aluminum

Correct errata by changing ASTM B449 to B921 and eliminating the specification for coating thickness.

- (4) Degrease, etch, and coat the sign blank on both sides with a chromate treatment conforming to ASTM B921, class 2.
- 

### 637.3.3.4 Performance

Correct errata to reference to 105.11.2.3 as revised to implement changes to the finals process.

- (1) Under 105.11.2.3 the department may revoke acceptance and direct the contractor to repair or replace previously accepted sign installations if the department subsequently discovers evidence of defective materials or improper installation. Deficiencies that warrant department action include but are not limited to the following:
    - Sign posts more than five degrees out of plumb.
    - Signs twisted by more than 5 degrees from plan orientation.
    - Signs with delaminated or warped plywood.
    - Signs with bubbling, fading, delaminating, or buckling sheeting.
- 

### 646.3.3.4 Proving Period

Correct errata to reference to 105.11.2.3 as revised to implement changes to the finals process.

- (4) Replace all marking within sections with a percent failing more than 10% and repair or replace all markings that, in the engineer's assessment, show evidence of improper construction. If post-acceptance inspections uncover evidence of defective materials or improper construction, the department may revoke acceptance under 105.11.2.3.

**ADDITIONAL SPECIAL PROVISION 7**

- A. Reporting 1<sup>st</sup> Tier and DBE Payments During Construction
1. Comply with reporting requirements specified in the department's Civil Rights Compliance, Contractor's User Manual, Sublets and Payments.
  2. Report payments to all DBE firms within 10 calendar days of receipt of a progress payment by the department or a contractor for work performed, materials furnished, or materials stockpiled by a DBE firm. Report the payment as specified in A(1) for all work satisfactorily performed and for all materials furnished or stockpiled.
  3. Report payments to all first tier subcontractor relationships within 10 calendar days of receipt of a progress payment by the department for work performed. Report the payment as specified in A(1) for all work satisfactorily performed.
  4. All tiers shall report payments as necessary to comply with the DBE payment requirement as specified in A(2).
  5. Require all first tier relationships, DBE firms and all other tier relationships necessary to comply with the DBE payment requirement in receipt of a progress payment by contractor to acknowledge receipt of payment as specified in A(1), (2), (3) and (4).
  6. All agreements made by a contractor shall include the provisions in A(1), (2), (3), (4) and (5), and shall be binding on all first tier subcontractor relationships and all contractors and subcontractors utilizing DBE firms on the project.
- B. Costs for conforming to this special provision are incidental to the contract.





**ADDITIONAL SPECIAL PROVISION 9**  
**Electronic Certified Payroll Submittal**

(1) Use the department's Civil Rights Compliance System (CRCS) to submit certified payrolls electronically. Details are available online through the department's highway construction contractor information (HCCI) site on the Labor, Wages, and EEO Information page at: <http://www.dot.wi.gov/business/civilrights/laborwages/index.htm>

(2) Ensure that all tiers of subcontractors, as well as all trucking firms, submit their weekly certified payrolls electronically through CRCS. These payrolls are due within seven calendar days following the close of the payroll period. Every firm providing physical labor towards completing the project is a subcontractor under this special provision.

(3) Upon receipt of contract execution, promptly make all affected firms aware of the requirements under this special provision and arrange for them to receive CRCS training as they are about to begin payrolls. The department will provide training either in a classroom setting at one of our regional offices or by telephone. Contact Tess Mulrooney at 608-267-4489 to schedule the training.

(4) The department will reject all paper submittals of forms DT-1816 and DT-1929 for information required under this special provision. All costs for conforming to this special provision are incidental to the contract.

(5) Firms wishing to export payroll data from their computer system into CRCS should have their payroll coordinator send several sample electronic files to Tess two months before a payroll needs to be submitted. Not every contractor's payroll system is capable of producing export files. For details, see pages 17-22 of the CRCS System Background Information manual available online on the Labor, Wages, and EEO Information page at: <http://www.dot.wi.gov/business/civilrights/laborwages/docs/crc-payroll-manual.pdf>



**DECEMBER 2013**

**BUY AMERICA PROVISION**

All steel and iron materials permanently incorporated in this project shall be domestic products and all manufacturing and coating processes for these materials from smelting forward in the manufacturing process must have occurred within the United States. Coating includes epoxy coating, galvanizing, painting and any other coating that protects or enhances the value of a material subject to the requirements of Buy America. The exemption of this requirement is the minimal use of foreign materials if the total cost of such material permanently incorporated in the product does not exceed one-tenth of one percent (1/10 of 1%) of the total contract cost or \$2,500.00, whichever is greater. For purposes of this paragraph, the cost is that shown to be the value of the subject products as they are delivered to the project. The contractor shall take actions and provide documentation conforming to CMM 2-28.5 to ensure compliance with this "Buy America" provision.

<http://roadwaystandards.dot.wi.gov/standards/cmm/cm-02-28.pdf#cm2-28.5>

Upon completion of the project certify to the engineer, in writing using department form WS4567, that all steel, iron, and coating processes for steel or iron incorporated into the contract work conform to these "Buy America" provisions. Attach a list of exemptions and their associated costs to the certification form. Department form WS4567 is available at:

<http://roadwaystandards.dot.wi.gov/standards/forms/ws4567.doc>

**Effective with September 2004 Letting**

**WISCONSIN DEPARTMENT OF TRANSPORTATION  
DIVISION OF HIGHWAYS AND TRANSPORTATION FACILITIES**

**SUPPLEMENTAL REQUIRED CONTRACT PROVISIONS**

- I. Wage Rates, Hours of labor and payment of Wages
- II. Payroll Requirements
- III. Postings at the Site of the Work
- IV. Affidavits
- V. Wage Rate Redistribution
- VI. Additional Classifications

**I. WAGE RATES, HOURS OF LABOR AND PAYMENT OF WAGES**

The schedule of "Minimum Wage Rates" attached hereto and made a part hereof furnishes the prevailing wage rates that have been determined pursuant to Section 103.50 of the Wisconsin Statutes. These wage rates are the minimum required to be paid to the various laborers, workers, mechanics and truck drivers employed by contractors and subcontractors on the construction work embraced by the contract and subject to prevailing hours and wages under Section 103.50, Stats. If necessary to employ laborers, workers, mechanics or truck drivers whose classification is not listed on the schedule, they shall be paid at rates conformable to those listed for similar classifications. Apprentices shall be paid at rates not less than those prescribed in their state indenture contracts.

While the wage rates shown are the minimum rates required by the contract to be paid during its life, this is not a representation that labor can be obtained at these rates. It is the responsibility of bidders to inform themselves as to the local labor conditions and prospective changes or adjustments of wage rates. No increase in the contract price shall be allowed or authorized on account of the payment of wage rates in excess of those listed herein.

Pursuant to Section 103.50 of the Wisconsin Statutes, the prevailing hours of labor have been determined to be up to 10 hours per day and 40 hours per calendar week Monday through Friday. If any laborer, worker, mechanic or truck driver is permitted or required to work more than the prevailing number of hours per day or per calendar week on this contract, they shall be paid for all hours in excess of the prevailing hours at a rate of at least one and one-half (1 1/2) times their hourly rate of pay. All work on Saturday, Sunday and the following holidays is to be paid at time and a half: (1) January 1, (2) the last Monday in May, (3) July 4, (4) the first Monday in September, (5) the fourth Thursday in November, (6) December 25, (7) the day before if January 1, July 4 or December 25 falls on a Saturday and (8) the day following if January 1, July 4 or December 25 falls on a Sunday.

All laborers, workers, mechanics and truck drivers shall be paid unconditionally not less often than once a week. Persons who own and operate their own trucks must receive the prevailing truck driver rate for the applicable type of truck (i.e. 2 axle, 3 or more axle, articulated, eculid or dumptor) he or she operates, plus an agreed upon amount for the use of his or her truck. Every owner-operator MUST be paid separately for their driving and for the use of their truck.

For those projects subject to the requirements of the Davis-Bacon Act, the Secretary of Labor will also have determined "Minimum Wage Rates" for work to be performed under the contract. These rates are, for all or most of the labor, worker, mechanic or truck driver classifications, identical to those established under Section 103.50 of the Wisconsin Statutes. In the event the rates are not identical, the higher of the two rates will govern.

## **II. PAYROLL REQUIREMENTS**

All contractors and subcontractors must submit weekly Certified Payrolls and Compliance Statement verifying that all laborers, workers, mechanics and truck drivers working on the project have been paid the prevailing wage rates for all work performed under the contract required by Section 103.50 of the Wisconsin Statutes.

## **III. POSTINGS AT THE SITE OF THE WORK**

In addition to the required postings furnished by the Department, the contractor shall post the following in at least one conspicuous place at the site of work:

- a. "NOTICE TO EMPLOYEES," which provides information required to be posted by the provisions of Section 103.50 of the Wisconsin Statutes.
- b. A copy of the State of Wisconsin Minimum Wages Rates. (Four pages.)
- c. A copy of the contractor's Equal Employment Opportunity Policy.
- d. On any project involving federal aid, in addition to the furnished postings, the contractor shall post a copy of the "Davis-Bacon Act, Minimum Wage Rates". (Three pages.)

## **IV. WAGE RATE REDISTRIBUTION**

The amount specified as the hourly basic rate of pay and the amount(s) specified as the fringe benefit contribution(s), for all classes of laborers, workers, mechanics or truck drivers may be redistributed, when necessary, to conform to those specified in any applicable collective bargaining agreement, provided that both parties to such agreement

request and receive the approval for any such redistribution from both the Department of Transportation and the Department of Workforce Development prior to the implementation of such redistribution.

## **V. ADDITIONAL CLASSIFICATIONS**

Any unlisted laborer or mechanic classification that is needed to perform work on this project, and is not included within the scope of any of the classifications listed in the application prevailing wage rate determination, may be added after award only if all of the following criteria have been met:

1. The affected employer(s) must make a written request to WisDOT Central Office to utilize the unlisted classification on this project.
2. The request must indicate the scope of the work to be performed by the unlisted classification and must indicate the proposed wage/fringe benefit package that the unlisted classification is to receive.
3. The work to be performed by the unlisted classification must not be performed by a classification that is included in the applicable prevailing wage rate determination.
4. The unlisted classification must be commonly employed in the area where the project is located.
5. The proposed wage/fringe benefit package must bear a reasonable relationship to those set forth in the applicable prevailing wage rate determination.
6. The request should be made prior to the actual performance of the work by the unlisted classification.
7. DWD must approve the use of the unlisted classification and the proposed wage/fringe benefit package. USDOL also must approve the use of the unlisted classification and the proposed wage/fringe benefit package on federal aid projects.
8. WisDOT and DWD may amend the proposed wage/fringe benefit package, as deemed necessary, and may set forth specific employment ratios and scope of work requirements in the approval document.

The approved wage/fringe benefit package shall be paid to all laborers, workers, mechanics or truck drivers performing work within the scope of that performed by the unlisted classification, from the first day on which such work is performed. In the event that work is performed by the unlisted classification prior to approval, the wage/fringe benefit package to be paid for such work must be in conformance with the wage/fringe

benefit package approved for such work. Under this arrangement a retroactive adjustment in wages and/or fringe benefits may be required to be made to the affected laborers, workers, mechanics or truck drivers by the affected employer(s).

**ANNUAL PREVAILING WAGE RATE DETERMINATION  
FOR ALL STATE HIGHWAY PROJECTS  
ASHLAND COUNTY**

Compiled by the State of Wisconsin - Department of Workforce Development  
for the Department of Transportation  
Pursuant to s. 103.50, Stats.  
Issued on May 1, 2014

**CLASSIFICATION:** Contractors are required to call the Department of Workforce Development if there are any questions regarding the proper trade or classification to be used for any worker on a public works project.

**OVERTIME:** Time and one-half must be paid for all hours worked over 10 hours per day and 40 hours per calendar week and for all hours worked on Saturday, Sunday and the following six (6) holidays: January 1; the last Monday in May; July 4; the 1st Monday in September; the 4th Thursday in November; December 25; the day before if January 1, July 4 or December 25 falls on a Saturday; the day following if January 1, July 4 or December 25 falls on a Sunday.

**FUTURE INCREASE:** If indicated for a specific trade or occupation, the full amount of such increase MUST be added to the "TOTAL" indicated for such trade or occupation on the date(s) such increase(s) becomes effective.

**PREMIUM PAY:** If indicated for a specific trade or occupation, the full amount of such pay MUST be added to the "HOURLY BASIC RATE OF PAY" indicated for such trade or occupation, whenever such pay is applicable.

**SUBJOURNEY:** Wage rates may be available for some of the classifications indicated below. Any employer that desires to use any subjourney classification on a project MUST request the applicable wage rate from the Department of Workforce Development PRIOR to the date such classification is used on such project. Form ERD-10880 is available for this purpose and can be obtained by writing to the Department of Workforce Development, Equal Rights Division, P.O. Box 8928, Madison, WI 53708.

<u>TRADE OR OCCUPATION</u>	<u>HOURLY BASIC RATE OF PAY</u>	<u>HOURLY FRINGE BENEFITS</u>	<u>TOTAL</u>
	\$	\$	\$
Bricklayer, Blocklayer or Stonemason	31.34	16.35	47.69
Carpenter	30.48	15.90	46.38
Cement Finisher	32.65	17.32	49.97
Future Increase(s): Add \$1.87 on 6/1/14; Add \$1.87 on 6/1/15; Add \$1.75 on 6/1/16.			
Premium Pay: DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.40/hr when the Wisconsin Department of Transportation or responsible governing agency requires that work be performed at night under artificial illumination with traffic control and the work is completed after sunset and before sunrise.			
Electrician	28.96	16.90	45.86
Future Increase(s): Add \$.70/hr on 6/2/2014; Add \$.75/hr on 6/1/2015.			
Premium Pay: DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.			
Fence Erector	16.00	0.17	16.17
Ironworker	34.15	22.05	56.20
Future Increase(s): Add \$1.35/hr on 5/1/2014; Add \$1.50/hr on 5/1/2015.			
Premium Pay: DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day and Christmas Day.			
Line Constructor (Electrical)	38.25	17.63	55.88
Painter	21.87	11.37	33.24
Pavement Marking Operator	30.00	0.00	30.00
Piledriver	30.98	18.75	49.73
Roofer or Waterproofer	20.75	7.15	27.90
Teledata Technician or Installer	21.89	11.85	33.74
Tuckpointer, Caulker or Cleaner	34.57	15.25	49.82
Underwater Diver (Except on Great Lakes)	34.48	15.90	50.38



<b>TRADE OR OCCUPATION</b>	<b>HOURLY BASIC RATE OF PAY</b>	<b>HOURLY FRINGE BENEFITS</b>	<b>TOTAL</b>
	<b>\$</b>	<b>\$</b>	<b>\$</b>
Heavy Equipment Operator - ELECTRICAL LINE CONSTRUCTION ONLY	34.43	15.24	49.67
Light Equipment Operator -ELECTRICAL LINE CONSTRUCTION ONLY	30.60	16.89	47.49
Heavy Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	26.78	13.58	40.36
Light Truck Driver - ELECTRICAL LINE CONSTRUCTION ONLY	24.86	12.97	37.83
Groundman - ELECTRICAL LINE CONSTRUCTION ONLY	21.75	12.70	34.45

**TRUCK DRIVERS**

Single Axle or Two Axle	34.22	19.90	54.12
Three or More Axle	24.52	17.77	42.29
Future Increase(s): Add \$1.30/hr on 6/1/2014. Premium Pay: DOT PREMIUM: Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day.			
Articulated, Euclid, Dumptor, Off Road Material Hauler	29.27	20.40	49.67
Future Increase(s): Add \$1.75/hr on 6/1/14); Add \$1.25/hr on 6/1/15); Add \$1.30/hr on 6/1/16); Add \$1.25/hr on 6/ 1/ 17. Premium Pay: DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.50/hr night work premium. See DOT'S website for details about the applicability of this night work premium at: <a href="http://www.dot.wi.gov/business/civilrights/laborwages/pwc.htm">http://www.dot.wi.gov/business/civilrights/laborwages/pwc.htm</a> .			
Pavement Marking Vehicle	23.31	17.13	40.44
Shadow or Pilot Vehicle	34.22	19.90	54.12
Truck Mechanic	23.31	17.13	40.44

**LABORERS**

General Laborer	29.04	14.63	43.67
Future Increase(s): Add \$1.60/hr on 6/1/2014. Premium Pay: Add \$.10/hr for topman, air tool operator, vibrator or tamper operator (mechanical hand operated), chain saw operator and demolition burning torch laborer; Add \$.15/hr for bituminous worker (raker and luteman), formsetter (curb, sidewalk and pavement) and strike off man; Add \$.20/hr for blaster and powderman; Add \$.25/hr for bottomman; Add \$.35/hr for line and grade specialist; Add \$.45/hr for pipelayer. DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).			
Asbestos Abatement Worker	25.36	14.39	39.75
Landscaper	29.04	14.63	43.67
Future Increase(s): Add \$1.60/hr on 6/1/14. Premium Pay: DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.25/hr for work on projects involving temporary traffic control setup, for lane and shoulder closures, when work under artificial illumination conditions is necessary as required by the project provisions (including prep time prior to and/or cleanup after such time period).			
Flagperson or Traffic Control Person	25.67	14.63	40.30
Future Increase(s): Add \$1.60/hr on 6/1/2014. Premium Pay: DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.25/hr when the Wisconsin			

<b>TRADE OR OCCUPATION</b>	<b>HOURLY BASIC RATE OF PAY</b>	<b>HOURLY FRINGE BENEFITS</b>	<b>TOTAL</b>
	<b>\$</b>	<b>\$</b>	<b>\$</b>
Department of Transportation or responsible governing agency requires that work be performed at night under artificial illumination with traffic control and the work is completed after sunset and before sunrise.			
Fiber Optic Laborer (Outside, Other Than Concrete Encased)	18.31	9.56	27.87
Railroad Track Laborer	21.31	15.28	36.59

### HEAVY EQUIPMENT OPERATORS

Crane, Tower Crane, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 176 Ft or Over; Crane, Tower Crane, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of Over 100 Tons, Self-Erecting Tower Crane With a Lifting Capacity Of Over 4,000 Lbs., Crane With Boom Dollies; Traveling Crane (Bridge Type). Future Increase(s): Add \$1.75/hr on 6/1/2014); Add \$1.25/hr on 6/1/2015); Add \$1.30/hr on 6/1/2016); Add \$1.25/hr on 6/ 1/ 2017. Premium Pay: DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.50/hr night work premium. See DOT'S website for details about the applicability of this night work premium at: <a href="http://www.dot.wi.gov/business/civilrights/laborwages/pwc.htm">http:// www.dot.wi.gov/ business/ civilrights/ laborwages/ pwc. htm</a> .	36.72	20.40	57.12
Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of 130,000 Lbs. or Over; Caisson Rig; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With Boom, Leads &/or Jib Lengths Measuring 175 Ft or Under; Crane, Tower Crane, Portable Tower, Pedestal Tower or Derrick, With or Without Attachments, With a Lifting Capacity of 100 Tons or Under, Self-Erecting Tower Crane With A Lifting Capacity Of 4,000 Lbs., & Under; Dredge (NOT Performing Work on the Great Lakes); Licensed Boat Pilot (NOT Performing Work on the Great Lakes); Pile Driver. Future Increase(s): Add \$1.75/hr on 6/1/2014); Add \$1.25/hr on 6/1/2015); Add \$1.30/hr on 6/1/2016); Add \$1.25/hr on 6/ 1/ 2017. Premium Pay: DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.50/hr night work premium. See DOT'S website for details about the applicability of this night work premium at: <a href="http://www.dot.wi.gov/business/civilrights/laborwages/pwc.htm">http:// www.dot.wi.gov/ business/ civilrights/ laborwages/ pwc. htm</a> .	36.22	20.40	56.62
Air Track, Rotary or Percussion Drilling Machine &/or Hammers, Blaster; Asphalt Heater, Planer & Scarifier; Asphalt Milling Machine; Asphalt Screed; Automatic Subgrader (Concrete); Backhoe (Track Type) Having a Mfgr.'s Rated Capacity of Under 130,000 Lbs., Backhoe (Mini, 15,000 Lbs. & Under); Bituminous (Asphalt) Plant & Paver, Screed; Boatmen (NOT Performing Work on the Great Lakes); Boring Machine (Directional, Horizontal or Vertical); Bridge (Bidwell) Paver; Bulldozer or Endloader; Concrete Batch Plant, Batch Hopper; Concrete Breaker (Large, Auto, Vibratory/Sonic, Manual or Remote); Concrete Bump Cutter, Grinder, Planing or Grooving Machine; Concrete Conveyor System; Concrete Laser/Screed; Concrete Paver (Slipform); Concrete Pump, Concrete Conveyor (Rotec or Bidwell Type); Concrete Slipform Placer Curb & Gutter Machine; Concrete Spreader & Distributor; Crane (Carry Deck, Mini) or Truck Mounted Hydraulic Crane (10 Tons or Under); Crane With a Lifting Capacity of 25 Tons or Under; Forestry Equipment, Timbco, Tree Shear, Tub Grinder, Processor; Gradall (Cruz-Aire Type); Grader or Motor Patrol; Grout Pump; Hydro-Blaster (10,000 PSI or Over); Loading Machine (Conveyor); Material or Stack Hoist; Mechanic or Welder; Milling Machine; Post Hole Digger or Driver; Roller (Over 5 Ton); Scraper (Self Propelled or Tractor	35.72	20.40	56.12

<u>TRADE OR OCCUPATION</u>	<u>HOURLY BASIC RATE OF PAY</u>	<u>HOURLY FRINGE BENEFITS</u>	<u>TOTAL</u>
	\$	\$	\$
Drawn) 5 cu yds or More Capacity; Shoulder Widener; Sideboom; Skid Rig; Stabilizing or Concrete Mixer (Self-Propelled or 14S or Over); Straddle Carrier or Travel Lift; Tractor (Scraper, Dozer, Pusher, Loader); Tractor or Truck Mounted Hydraulic Backhoe; Trencher (Wheel Type or Chain Type); Tube Finisher; Tugger (NOT Performing Work on the Great Lakes); Winches & A- Frames. Future Increase(s): Add \$1.75/hr on 6/1/2014); Add \$1.25/hr on 6/1/2015); Add \$1.30/hr on 6/1/2016); Add \$1.25/hr on 6/ 1/ 2017. Premium Pay: DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.50/hr night work premium. See DOT'S website for details about the applicability of this night work premium at: <a href="http://www.dot.wi.gov/business/civilrights/laborwages/pwc.htm">http:// www.dot.wi.gov/business/civilrights/laborwages/pwc.htm</a> .			
Belting, Burlap, Texturing Machine; Broom or Sweeper; Compactor (Self-Propelled or Tractor Mounted, Towed & Light Equipment); Concrete Finishing Machine (Road Type); Environmental Burner; Farm or Industrial Type Tractor; Fireman (Asphalt Plant, Pile Driver & Derrick NOT Performing Work on the Great Lakes); Forklift; Greaser; Hoist (Tugger, Automatic); Jeep Digger; Joint Sawyer (Multiple Blade); Launch (NOT Performing Work on the Great Lakes); Lift Slab Machine; Mechanical Float; Mulcher; Power Subgrader; Robotic Tool Carrier (With or Without Attachments); Roller (Rubber Tire, 5 Ton or Under); Self Propelled Chip Spreader; Shouldering Machine; Skid Steer Loader (With or Without Attachments); Telehandler; Tining or Curing Machine. Future Increase(s): Add \$1.75/hr on 6/1/2014); Add \$1.25/hr on 6/1/2015); Add \$1.30/hr on 6/1/2016); Add \$1.25/hr on 6/ 1/ 2017. Premium Pay: DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.50/hr night work premium. See DOT'S website for details about the applicability of this night work premium at: <a href="http://www.dot.wi.gov/business/civilrights/laborwages/pwc.htm">http:// www.dot.wi.gov/business/civilrights/laborwages/pwc.htm</a> .	35.46	20.40	55.86
Air Compressor (&/or 400 CFM or Over); Air, Electric or Hydraulic Jacking System; Augers (Vertical & Horizontal); Automatic Belt Conveyor & Surge Bin; Boiler (Temporary Heat); Concrete Proportioning Plant; Crusher, Screening or Wash Plant; Generator (&/or 150 KW or Over); Heaters (Mechanical); High Pressure Utility Locating Machine (Daylighting Machine); Mudjack; Oilier; Prestress Machine; Pug Mill; Pump (3 Inch or Over) or Well Points; Rock, Stone Breaker; Screed (Milling Machine); Stump Chipper; Tank Car Heaters; Vibratory Hammer or Extractor, Power Pack. Future Increase(s): Add \$1.75/hr on 6/1/2014); Add \$1.25/hr on 6/1/2015); Add \$1.30/hr on 6/1/2016); Add \$1.25/hr on 6/ 1/ 2017. Premium Pay: DOT PREMIUMS: 1) Pay two times the hourly basic rate on Sunday, New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day & Christmas Day. 2) Add \$1.50/hr night work premium. See DOT'S website for details about the applicability of this night work premium at: <a href="http://www.dot.wi.gov/business/civilrights/laborwages/pwc.htm">http:// www.dot.wi.gov/business/civilrights/laborwages/pwc.htm</a> .	35.17	20.40	55.57
Fiber Optic Cable Equipment.	26.69	13.05	39.74
Work Performed on the Great Lakes Including Diver; Wet Tender or Hydraulic Dredge Engineer.	38.80	20.17	58.97
Work Performed on the Great Lakes Including 70 Ton & Over Tug Operator; Assistant Hydraulic Dredge Engineer; Crane or Backhoe Operator; Hydraulic Dredge Leverman or Diver's Tender; Mechanic or Welder.	38.80	20.17	58.97
Work Performed on the Great Lakes Including Deck Equipment Operator or Machineryman (Maintains Cranes Over 50 Tons or Backhoes 115,000 Lbs. or More); Tug, Launch or Loader, Dozer or Like Equipment When Operated	34.50	20.04	54.54

<u>TRADE OR OCCUPATION</u>	<u>HOURLY BASIC RATE OF PAY</u>	<u>HOURLY FRINGE BENEFITS</u>	<u>TOTAL</u>
	\$	\$	\$
on a Barge, Breakwater Wall, Slip, Dock or Scow, Deck Machinery.			
Work Performed on the Great Lakes Including Deck Equipment Operator, Machineryman or Fireman (Operates 4 Units or More or Maintains Cranes 50 Tons or Under or Backhoes 115,000 Lbs. or Under); Deck Hand, Deck Engineer or Assistant Tug Operator; Off Road Trucks-Great Lakes ONLY.	34.50	20.04	54.54

## SCHEDULE OF ITEMS

REVISED:

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS

## SECTION 0001 CONTRACT ITEMS

0010	201.0105 CLEARING	4.000				
	STA		.		.	
0020	201.0205 GRUBBING	4.000				
	STA		.		.	
0030	203.0100 REMOVING SMALL PIPE CULVERTS	1.000				
	EACH		.		.	
0040	203.0200 REMOVING OLD STRUCTURE (STATION) 01. STA 10+00	LUMP	LUMP			.
0050	203.0200 REMOVING OLD STRUCTURE (STATION) 02. STA 25+82	LUMP	LUMP			.
0060	204.0150 REMOVING CURB & GUTTER	75.000				
	LF		.		.	
0070	204.0155 REMOVING CONCRETE SIDEWALK	130.000				
	SY		.		.	
0080	204.0180 REMOVING DELINEATORS AND MARKERS	4.000				
	EACH		.		.	
0090	204.0210 REMOVING MANHOLES	1.000				
	EACH		.		.	
0100	205.0100 EXCAVATION COMMON	3,700.000				
	CY		.		.	

## SCHEDULE OF ITEMS

REVISED:

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0110	206.2000 EXCAVATION FOR STRUCTURES CULVERTS (STRUCTURE) 01. STA 10+00	LUMP	LUMP		.	
0120	206.2000 EXCAVATION FOR STRUCTURES CULVERTS (STRUCTURE) 02. STA 25+82	LUMP	LUMP		.	
0130	208.0100 BORROW	145.000 CY	.		.	
0140	210.0100 BACKFILL STRUCTURE	2,140.000 CY	.		.	
0150	211.0200 PREPARE FOUNDATION FOR CONCRETE PAVEMENT (PROJECT) 01. 1181-11-70	LUMP	LUMP		.	
0160	213.0100 FINISHING ROADWAY (PROJECT) 01. 1181-11-70	1.000 EACH	.		.	
0170	305.0110 BASE AGGREGATE DENSE 3/4-INCH	130.000 TON	.		.	
0180	305.0120 BASE AGGREGATE DENSE 1 1/4-INCH	2,030.000 TON	.		.	
0190	350.0102 SUBBASE	440.000 CY	.		.	
0200	416.0610 DRILLED TIE BARS	275.000 EACH	.		.	

## SCHEDULE OF ITEMS

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0210	416.0620 DRILLED DOWEL BARS	1,490.000 EACH	.		.	
0220	440.4410.S INCENTIVE IRI RIDE	450.000 DOL	1.00000		450.00	
0230	455.0605 TACK COAT	31.000 GAL	.		.	
0240	465.0105 ASPHALTIC SURFACE	145.000 TON	.		.	
0250	465.0110 ASPHALTIC SURFACE PATCHING	10.000 TON	.		.	
0260	465.0125 ASPHALTIC SURFACE TEMPORARY	167.000 TON	.		.	
0270	504.0900 CONCRETE MASONRY ENDWALLS	25.000 CY	.		.	
0280	520.4018 CULVERT PIPE TEMPORARY 18-INCH	16.000 LF	.		.	
0290	520.4024 CULVERT PIPE TEMPORARY 24-INCH	16.000 LF	.		.	
0300	520.8000 CONCRETE COLLARS FOR PIPE	3.000 EACH	.		.	
0310	522.0115 CULVERT PIPE REINFORCED CONCRETE CLASS III 15-INCH	20.000 LF	.		.	

## SCHEDULE OF ITEMS

REVISED:

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0320	522.0372 CULVERT PIPE REINFORCED CONCRETE CLASS IV 72-INCH	196.000 LF	.		.	
0330	522.1015 APRON ENDWALLS FOR CULVERT PIPE REINFORCED CONCRETE 15-INCH	1.000 EACH	.		.	
0340	524.0618 APRON ENDWALLS FOR CULVERT PIPE SALVAGED 18-INCH	1.000 EACH	.		.	
0350	601.0405 CONCRETE CURB & GUTTER 18-INCH TYPE A	280.000 LF	.		.	
0360	601.0409 CONCRETE CURB & GUTTER 30-INCH TYPE A	280.000 LF	.		.	
0370	601.0411 CONCRETE CURB & GUTTER 30-INCH TYPE D	72.000 LF	.		.	
0380	602.0405 CONCRETE SIDEWALK 4-INCH	1,120.000 SF	.		.	
0390	606.0300 RIPRAP HEAVY	390.000 CY	.		.	
0400	608.0318 STORM SEWER PIPE REINFORCED CONCRETE CLASS III 18-INCH	34.000 LF	.		.	
0410	611.0430 RECONSTRUCTING INLETS	8.000 EACH	.		.	
0420	611.3230 INLETS 2X3-FT	2.000 EACH	.		.	



## SCHEDULE OF ITEMS

REVISED:

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0430	611.9710 SALVAGED INLET COVERS	2.000 EACH	.		.	
0440	612.0106 PIPE UNDERDRAIN 6-INCH	240.000 LF	.		.	
0450	612.0902.S INSULATION BOARD POLYSTYRENE (INCH) 01. 4-INCH	85.000 SY	.		.	
0460	614.0920 SALVAGED RAIL	860.000 LF	.		.	
0470	614.2300 MGS GUARDRAIL 3	887.500 LF	.		.	
0480	614.2610 MGS GUARDRAIL TERMINAL EAT	2.000 EACH	.		.	
0490	614.2620 MGS GUARDRAIL TERMINAL TYPE 2	2.000 EACH	.		.	
0500	618.0100 MAINTENANCE AND REPAIR OF HAUL ROADS (PROJECT) 01. 1181-11-70	1.000 EACH	.		.	
0510	619.1000 MOBILIZATION	1.000 EACH	.		.	
0520	625.0500 SALVAGED TOPSOIL	3,785.000 SY	.		.	
0530	627.0200 MULCHING	3,785.000 SY	.		.	

## SCHEDULE OF ITEMS

REVISED:

CONTRACT:

PROJECT(S):

FEDERAL ID(S):

20141111014

1181-11-70

N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0540	628.1504 SILT FENCE	3,130.000	.		.	
		LF				
0550	628.1520 SILT FENCE MAINTENANCE	5,280.000	.		.	
		LF				
0560	628.1905 MOBILIZATIONS EROSION CONTROL	2.000	.		.	
		EACH				
0570	628.1910 MOBILIZATIONS EMERGENCY EROSION CONTROL	2.000	.		.	
		EACH				
0580	628.2027 EROSION MAT CLASS II TYPE C	2,675.000	.		.	
		SY				
0590	628.7005 INLET PROTECTION TYPE A	10.000	.		.	
		EACH				
0600	628.7015 INLET PROTECTION TYPE C	10.000	.		.	
		EACH				
0610	628.7555 CULVERT PIPE CHECKS	8.000	.		.	
		EACH				
0620	629.0210 FERTILIZER TYPE B	2.400	.		.	
		CWT				
0630	630.0120 SEEDING MIXTURE NO. 20	103.000	.		.	
		LB				
0640	630.0200 SEEDING TEMPORARY	103.000	.		.	
		LB				

## SCHEDULE OF ITEMS

REVISED:

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0650	633.5200 MARKERS CULVERT END	6.000 EACH	.		.	
0660	634.0616 POSTS WOOD 4X6-INCH X 16-FT	8.000 EACH	.		.	
0670	637.2210 SIGNS TYPE II REFLECTIVE H	46.860 SF	.		.	
0680	637.2230 SIGNS TYPE II REFLECTIVE F	18.000 SF	.		.	
0690	638.2602 REMOVING SIGNS TYPE II	12.000 EACH	.		.	
0700	638.3000 REMOVING SMALL SIGN SUPPORTS	8.000 EACH	.		.	
0710	642.5001 FIELD OFFICE TYPE B	1.000 EACH	.		.	
0720	643.0100 TRAFFIC CONTROL (PROJECT) 01. 1181-11-70	1.000 EACH	.		.	
0730	643.0300 TRAFFIC CONTROL DRUMS	1,640.000 DAY	.		.	
0740	643.0420 TRAFFIC CONTROL BARRICADES TYPE III	1,272.000 DAY	.		.	
0750	643.0705 TRAFFIC CONTROL WARNING LIGHTS TYPE A	2,544.000 DAY	.		.	

## SCHEDULE OF ITEMS

REVISED:

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0760	643.0715 TRAFFIC CONTROL WARNING LIGHTS TYPE C	656.000 DAY	.		.	
0770	643.0900 TRAFFIC CONTROL SIGNS	1,456.000 DAY	.		.	
0780	643.1050 TRAFFIC CONTROL SIGNS PCMS	164.000 DAY	.		.	
0790	643.2000 TRAFFIC CONTROL DETOUR (PROJECT) 01. 1181-11-70	1.000 EACH	.		.	
0800	643.3000 TRAFFIC CONTROL DETOUR SIGNS	3,690.000 DAY	.		.	
0810	645.0120 GEOTEXTILE FABRIC TYPE HR	470.000 SY	.		.	
0820	646.0106 PAVEMENT MARKING EPOXY 4-INCH	1,566.000 LF	.		.	
0830	646.0600 REMOVING PAVEMENT MARKINGS	2,012.000 LF	.		.	
0840	647.0166 PAVEMENT MARKING ARROWS EPOXY TYPE 2	6.000 EACH	.		.	
0850	647.0566 PAVEMENT MARKING STOP LINE EPOXY 18-INCH	16.000 LF	.		.	
0860	647.0955 REMOVING PAVEMENT MARKINGS ARROWS	6.000 EACH	.		.	

## SCHEDULE OF ITEMS

REVISED:

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0870	649.0100 TEMPORARY PAVEMENT MARKING 4-INCH	1,958.000 LF	.		.	
0880	649.0400 TEMPORARY PAVEMENT MARKING REMOVABLE TAPE 4-INCH	3,056.000 LF	.		.	
0890	649.1200 TEMPORARY PAVEMENT MARKING STOP LINE REMOVABLE TAPE 18-INCH	166.000 LF	.		.	
0900	650.4000 CONSTRUCTION STAKING STORM SEWER	11.000 EACH	.		.	
0910	650.4500 CONSTRUCTION STAKING SUBGRADE	295.000 LF	.		.	
0920	650.5000 CONSTRUCTION STAKING BASE	945.000 LF	.		.	
0930	650.5500 CONSTRUCTION STAKING CURB GUTTER AND CURB & GUTTER	72.000 LF	.		.	
0940	650.6000 CONSTRUCTION STAKING PIPE CULVERTS	4.000 EACH	.		.	
0950	650.7000 CONSTRUCTION STAKING CONCRETE PAVEMENT	295.000 LF	.		.	
0960	650.8000 CONSTRUCTION STAKING RESURFACING REFERENCE	663.000 LF	.		.	

## SCHEDULE OF ITEMS

REVISED:

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0970	650.9910 CONSTRUCTION STAKING SUPPLEMENTAL CONTROL (PROJECT) 01. 1181-11-70	LUMP	LUMP		.	
0980	650.9920 CONSTRUCTION STAKING SLOPE STAKES	LF 295.000	.		.	
0990	690.0150 SAWING ASPHALT	LF 980.000	.		.	
1000	690.0250 SAWING CONCRETE	LF 1,530.000	.		.	
1010	715.0415 INCENTIVE STRENGTH CONCRETE PAVEMENT	DOL 500.000	1.00000		500.00	
1020	SPV.0060 SPECIAL 01. GATE VALVE AND BOX 8-INCH	EACH 2.000	.		.	
1030	SPV.0060 SPECIAL 02. CUT INTO AND CONNECT TO EXISTING WATER MAIN	EACH 2.000	.		.	
1040	SPV.0060 SPECIAL 03. INSTALL AND REMOVE TEMPORARY SERVICE FOR TESTING	EACH 2.000	.		.	
1050	SPV.0060 SPECIAL 04. CONSTRUCTION STAKING DETOUR WIDENING STAKING	EACH 3.000	.		.	
1060	SPV.0085 SPECIAL 01. WATER MAIN FITTINGS	LB 142.000	.		.	

## SCHEDULE OF ITEMS

REVISED:

CONTRACT:  
20141111014PROJECT(S):  
1181-11-70FEDERAL ID(S):  
N/A

CONTRACTOR : \_\_\_\_\_

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
1070	SPV.0090 SPECIAL 01. CONCRETE CURB & GUTTER 6-INCH SLOPED 20-INCH TYPE G MODIFIED	LF 310.000	.		.	
1080	SPV.0090 SPECIAL 02. CULVERT PIPE REINFORCED CONCRETE CLASS IV 96-INCH	LF 175.000	.		.	
1090	SPV.0090 SPECIAL 03. WATER MAIN 8-INCH	LF 160.000	.		.	
1100	SPV.0090 SPECIAL 04. CONCRETE CURB & GUTTER CURE AND SEAL TREATMENT	LF 942.000	.		.	
1110	SPV.0105 SPECIAL 01. SPECIAL STORM SEWER PROTECTION	LUMP	LUMP		.	
1120	SPV.0165 SPECIAL 01. CONCRETE SIDEWALK CURE & SEAL TREATMENT	SF 1,120.000	.		.	
1130	SPV.0180 SPECIAL 01. CONCRETE PAVEMENT REPAIR DOWELED SPECIAL	SY 225.000	.		.	
1140	SPV.0180 SPECIAL 02. CONCRETE PAVEMENT REPLACEMENT DOWELED SPECIAL	SY 2,635.000	.		.	
	SECTION 0001 TOTAL				.	
	TOTAL BID				.	





**PLEASE ATTACH SCHEDULE OF ITEMS HERE**