HIGHWAY WORK PROPOSAL

Proposal Number:

Wisconsin Department of Transportation DT1502 10/2010 s.66.29(7) Wis. Stats.

COUNTY STATE PROJECT ID FEDERAL PROJECT ID

PROJECT DESCRIPTION

HIGHWA

Milwaukee

2984-07-75

North 51st Boulevard Bridge over Lincoln Creek (B-40-0923) Local Street

This proposal, submitted by the undersigned bidder to the Wisconsin Department of Transportation, is in accordance with the advertised request for proposals. The bidder is to furnish and deliver all materials, and to perform all work for the improvement of the designated project in the time specified, in accordance with the appended Proposal Requirements and Conditions.

Proposal Guaranty Required, \$ 75,000.00	Attach Proposal Guaranty on back of this PAGE.
Payable to: Wisconsin Department of Transportation	
Bid Submittal Due	Firm Name, Address, City, State, Zip Code
Date: April 11, 2017	CAMDLE
Time (Local Time): 9:00 AM	SAMPLE
Contract Completion Time	NOT FOR BIDDING PURPOSES
December 22, 2017	NOT FOR BIBBING FOR GOLD
Assigned Disadvantaged Business Enterprise Goal	This contract is exempt from federal oversight.
0%	This contract is exempt nonrieueral oversight.

This certifies that the undersigned bidder, duly sworn, is an authorized representative of the firm named above; that the bidder has examined and carefully prepared the bid from the plans, Highway Work Proposal, and all addenda, and has checked the same in detail before submitting this proposal or bid; and that the bidder or agents, officer, or employees have not, either directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken any action in restraint of free competitive bidding in connection with this proposal bid.

Do not sign, notarize, or submit this Highway Work Proposal when s	submitting an electronic bid on the Internet.
Subscribed and sworn to before me this date	
(Signature, Notary Public, State of Wisconsin)	(Bidder Signature)
(Print or Type Name, Notary Public, State Wisconsin)	(Print or Type Bidder Name)
(Date Commission Expires)	(Bidder Title)
Notary Seal	

For Department Use Only

Type of Work			
Removal of existing structure and construction of a new concrete structure, base aggregate dense, concrete pavement approach slab,			
curb and gutter, sidewalk, street lighting.			
Notice of Award Dated	Date Guaranty Returned		

PLEASE ATTACH PROPOSAL GUARANTY HERE

Effective with November 2007 Letting

PROPOSAL REQUIREMENTS AND CONDITIONS

The bidder, signing and submitting this proposal, agrees and declares as a condition thereof, to be bound by the following conditions and requirements.

If the bidder has a corporate relationship with the proposal design engineering company, the bidder declares that it did not obtain any facts, data, or other information related to this proposal from the design engineering company that was not available to all bidders.

The bidder declares that they have carefully examined the site of, and the proposal, plans, specifications and contract forms for the work contemplated, and it is assumed that the bidder has investigated and is satisfied as to the conditions to be encountered, as to the character, quality, and quantities of work to be performed and materials to be furnished, and as to the requirements of the specifications, special provisions and contract. It is mutually agreed that submission of a proposal shall be considered conclusive evidence that the bidder has made such examination.

The bidder submits herewith a proposal guaranty in proper form and amount payable to the party as designated in the advertisement inviting proposals, to be retained by and become the property of the owner of the work in the event the undersigned shall fail to execute the contract and contract bond and return the same to the office of the engineer within fourteen (14) days after having been notified in writing to do so; otherwise to be returned.

The bidder declares that they understand that the estimate of quantities in the attached schedule is approximate only and that the attached quantities may be greater or less in accordance with the specifications.

The bidder agrees to perform the said work, for and in consideration of the payment of the amount becoming due on account of work performed, according to the unit prices bid in the following schedule, and to accept such amounts in full payment of said work.

The bidder declares that all of the said work will be performed at their own proper cost and expense, that they will furnish all necessary materials, labor, tools, machinery, apparatus, and other means of construction in the manner provided in the applicable specifications and the approved plans for the work together with all standard and special designs that may be designed on such plans, and the special provisions in the contract of which this proposal will become a part, if and when accepted. The bidder further agrees that the applicable specifications and all plans and working drawings are made a part hereof, as fully and completely as if attached hereto.

The bidder, if awarded the contract, agrees to begin the work not later than ten (10) days after the date of written notification from the engineer to do so, unless otherwise stipulated in the special provisions.

The bidder declares that if they are awarded the contract, they will execute the contract agreement and begin and complete the work within the time named herein, and they will file a good and sufficient surety bond for the amount of the contract for performance and also for the full amount of the contract for payment.

The bidder, if awarded the contract, shall pay all claims as required by Section 779.14, Statutes of Wisconsin, and shall be subject to and discharge all liabilities for injuries pursuant to Chapter 102 of the Statutes of Wisconsin, and all acts amendatory thereto. They shall further be responsible for any damages to property or injury to persons occurring through their own negligence or that of their employees or agents, incident to the performance of work under this contract, pursuant to the Standard Specifications for Road and Bridge Construction applicable to this contract.

In connection with the performance of work under this contract, the contractor agrees to comply with all applicable state and federal statutes relating to non-discrimination in employment. No otherwise qualified person shall be excluded from employment or otherwise be subject to discrimination in employment in any manner on the basis of age, race, religion, color, gender, national origin or ancestry, disability, arrest or conviction record (in keeping with s.111.32), sexual orientation, marital status, membership in the military reserve, honesty testing, genetic testing, and outside use of lawful products. This provision shall include, but not be limited to the following: employment, upgrading, demotion or transfer; recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation, and selection for training, including apprenticeship. The contractor further agrees to ensure equal opportunity in employment to all applicants and employees and to take affirmative action to attain a representative workforce.

The contractor agrees to post notices and posters setting forth the provisions of the nondiscrimination clause, in a conspicuous and easily accessible place, available for employees and applicants for employment.

If a state public official (section 19.42, Stats.) or an organization in which a state public official holds at least a 10% interest is a party to this agreement, this contract is voidable by the state unless appropriate disclosure is made to the State of Wisconsin Ethics Board.

Effective with August 2015 Letting

BID PREPARATION

Preparing the Proposal Schedule of Items

A General

- Obtain bidding proposals as specified in section 102 of the standard specifications prior to 11:45 AM of the last business day preceding the letting. Submit bidding proposals using one of the following methods:
 - 1. Electronic bid on the internet.
 - 2. Electronic bid on a printout with accompanying diskette or CD ROM.
 - 3. Paper bid under a waiver of the electronic submittal requirements.
- (2) Bids submitted on a printout with accompanying diskette or CD ROM or paper bids submitted under a waiver of the electronic submittal requirements govern over bids submitted on the internet.
- (3) The department will provide bidding information through the department's web site at: http://wisconsindot.gov/Pages/doing-bus/contractors/hcci/bid-let.aspx

The contractor is responsible for reviewing this web site for general notices as well as information regarding proposals in each letting. The department will also post special notices of all addenda to each proposal through this web site no later than 4:00 P.M. local time on the Thursday before the letting. Check the department's web site after 5:00 P.M. local time on the Thursday before the letting to ensure all addenda have been accounted for before preparing the bid. When bidding using methods 1 and 2 above, check the Bid ExpressTM on-line bidding exchange at http://www.bidx.com/after 5:00 P.M. local time on the Thursday before the letting to ensure that the latest schedule of items Expedite file (*.ebs or *.00x) is used to submit the final bid.

(4) Interested parties can subscribe to the Bid ExpressTM on-line bidding exchange by following the instructions provided at the www.bidx.com web site or by contacting:

Info Tech Inc. 5700 SW 34th Street, Suite 1235 Gainesville, FL 32608-5371 email: mailto:customer.support@bidx.com

- (5) The department will address equipment and process failures, if the bidder can demonstrate that those failures were beyond their control.
- (6) Contractors are responsible for checking on the issuance of addenda and for obtaining the addenda. Notice of issuance of addenda is posted on the department's web site at:

 http://wisconsindot.gov/Pages/doing-bus/contractors/hcci/bid-let.aspx

or by calling the department at (608) 266-1631. Addenda can ONLY be obtained from the departments web site listed above or by picking up the addenda at the Bureau of Highway Construction, Room 601, 4802 Sheboygan Avenue, Madison, WI, during regular business hours.

Addenda posted after 5:00 PM on the Thursday before the letting will be emailed to the eligible bidders for that proposal. All eligible bidders shall acknowledge receipt of the addenda whether they are bidding on the proposal or not. Not acknowledging receipt may jeopardize the awarding of the project.

B Submitting Electronic Bids

B.1 On the Internet

- (1) Do the following before submitting the bid:
 - 1. Have a properly executed annual bid bond on file with the department.
 - 2. Have a digital ID on file with and enabled by Info Tech Inc. Using this digital ID will constitute the bidder's signature for proper execution of the bidding proposal.
- (2) In lieu of preparing, delivering, and submitting the proposal as specified in 102.6 and 102.9 of the standard specifications, submit the proposal on the internet as follows:
 - 1. Download the latest schedule of items reflecting all addenda from the Bid Express web site.
 - 2. Use ExpediteTM software to enter a unit price for every item in the schedule of items.
 - 3. Submit the bid according to the requirements of ExpediteTM software and the Bid ExpressTM web site. Do not submit a bid on a printout with accompanying diskette or CD ROM or a paper bid. If the bidder does submit a bid on a printout with accompanying diskette or a paper bid in addition to the internet submittal, the department will disregard the internet bid.
 - 4. Submit the bid before the hour and date the Notice to Contractors designates.
 - 5. Do not sign, notarize, and return the bidding proposal described in 102.2 of the standard specifications.
- (3) The department will not consider the bid accepted until the hour and date the Notice to Contractors designates.

B.2 On a Printout with Accompanying Diskette or CD ROM

(1) Download the latest schedule of items from the Wisconsin pages of the Bid ExpressTM web site reflecting the latest addenda posted on the department's web site at:

http://wisconsindot.gov/Pages/doing-bus/contractors/hcci/bid-let.aspx

Use Expedite TM software to prepare and print the schedule of items. Provide a valid amount for all price fields. Follow instructions and review the help screens provided on the Bid Express Meb site to assure that the schedule of items is prepared properly.

(2) Staple an 8 1/2 by 11 inch printout of the ExpediteTM generated schedule of items to the other proposal documents submitted to the department as a part of the bidder's sealed bid. As a separate submittal not in the sealed bid envelop but due at the same time and place as the sealed bid, also provide the ExpediteTM generated schedule of items on a 3 1/2 inch computer diskette or CD ROM. Label each diskette or CD ROM with the bidder's name, the 4 character department-assigned bidder identification code from the top of the bidding proposal, and a list of the proposal numbers included on that diskette or CD ROM as indicated in the following example:

Bidder

Name

BN00

Proposals: 1, 12, 14, & 22

- (3) If bidding on more than one proposal in the letting, the bidder may include all proposals for that letting on one diskette or CD ROM. Include only submitted proposals with no incomplete or other files on the diskette or CD ROM.
- (4) The bidder-submitted printout of the ExpediteTM generated schedule of items is the governing contract document and must conform to the requirements of section 102 of the standard specifications. If a printout needs to be altered, cross out the printed information with ink or typewriter and enter the new information and initial it in ink. If there is a discrepancy between the printout and the diskette or CD ROM, the department will analyze the bid using the printout information.

- (5) In addition to the reasons specified in section 102 of the standard specifications, proposals are irregular and the department may reject them for one or more of the following:
 - 1. The check code printed on the bottom of the printout of the ExpediteTM generated schedule of items is not the same on each page.
 - The check code printed on the printout of the ExpediteTM generated schedule of items is not the same as the check code for that proposal provided on the diskette or CD ROM.
 - 3. The diskette or CD ROM is not submitted at the time and place the department designates.

C Waiver of Electronic Submittal

- (1) The bidder may request a waiver of the electronic submittal requirements. Submit a written request for a waiver in lieu of bids submitted on the internet or on a printout with accompanying diskette or CD ROM. Use the waiver that was included with the paper bid document sent to the bidder or type up a waiver on the bidder's letterhead. The department will waive the electronic submittal requirements for a bidding entity (individual, partnership, joint venture, corporation, or limited liability company) for up to 4 individual proposals in a calendar year. The department may allow additional waivers for equipment malfunctions.
- (2) Submit a schedule of items on paper conforming to section 102 of the standard specifications. The department charges the bidder a \$75 administrative fee per proposal, payable at the time and place the department designates for receiving bids, to cover the costs of data entry. The department will accept a check or money order payable to: "Wisconsin, Dept. of Transportation."
- (3) In addition to the reasons specified in section 102 of the standard specifications, proposals are irregular and the department may reject them for one or more of the following:
 - 1. The bidder fails to provide the written request for waiver of the electronic submittal requirements.
 - 2. The bidder fails to pay the \$75 administrative fee before the time the department designates for the opening of bids unless the bidder requests on the waiver that they be billed for the \$75.
 - 3. The bidder exceeds 4 waivers of electronic submittal requirements within a calendar year.
- (4) In addition to the reasons specified in section 102 of the standard specifications, the department may refuse to issue bidding proposals for future contracts to a bidding entity that owes the department administrative fees for a waiver of electronic submittal requirements.

PROPOSAL BID BOND

DT1303 1/2006

Wisconsin Department of Transportation

Proposal Number	Project Number		Letting Date
Name of Principal			
Name of Surety		State in Which Surety is	Organized

We, the above-named Principal and the above-named Surety, are held and firmly bound unto the State of Wisconsin in the sum equal to the Proposal Guaranty for the total bid submitted for the payment to be made; we jointly and severally bind ourselves, our heirs, executors, administrators, successors and assigns. The condition of this obligation is that the Principal has submitted a bid proposal to the State of Wisconsin acting through the Department of Transportation for the improvement designated by the Proposal Number and Letting Date indicated above.

If the Principal is awarded the contract and, within the time and manner required by law after the prescribed forms are presented for signature, enters into a written contract in accordance with the bid, and files the bond with the Department of Transportation to guarantee faithful performance and payment for labor and materials, as required by law, or if the Department of Transportation shall reject all bids for the work described, then this obligation shall be null and void; otherwise, it shall be and remain in full force and effect. In the event of failure of the Principal to enter into the contract or give the specified bond, the Principal shall pay to the Department of Transportation within 10 business days of demand a total equal to the Proposal Guaranty as liquidated damages; the liability of the Surety continues for the full amount of the obligation as stated until the obligation is paid in full.

The Surety, for value received, agrees that the obligations of it and its bond shall not be impaired or affected by any extension of time within which the Department of Transportation may accept the bid; and the Surety does waive notice of any such extension.

IN WITNESS, the Principal and Surety have agreed and have signed by their proper officers and have caused their corporate seals to be affixed this date: **(DATE MUST BE ENTERED)**

PRINCIPAL

(Company Name) (Affix Corpor	ate Seal)		
(Signature and Title)			
(Company Name)			
(Signature and Title)			
(Company Name)			
(Signature and Title)		(Name of Surety) (Affix Seal)	
(Company Name)		(Signature of Attorney-in-Fact)	
(Signature and Title)			
NOTARY FO	OR PRINCIPAL	NOTARY FO	R SURETY
(I)	Date)	(Dat	te)
State of Wisconsin)	State of Wisconsin)
) ss. County)) ss. _County)
On the above date, this instrument named person(s).	was acknowledged before me by the	On the above date, this instrument w named person(s).	as acknowledged before me by the
(Signature, Notary Pu	ublic, State of Wisconsin)	(Signature, Notary Publ	ic, State of Wisconsin)
(Print or Type Name, Nota	ry Public, State of Wisconsin)	(Print or Type Name, Notary Public, State of Wisconsin)	
(Date Comn	nission Expires)	(Date Commis	sion Expires)

Notary Seal Notary Seal

IMPORTANT: A certified copy of Power of Attorney of the signatory agent must be attached to the bid bond.

CERTIFICATE OF ANNUAL BID BOND

DT1305 8/2003

Wisconsin Department of Transportation

(Date)

Time Period Valid (From/To)
Name of Surety	
Name of Contracto	r
Certificate Holder	Wisconsin Department of Transportation
	y that an annual bid bond issued by the above-named Surety is currently on file with the partment of Transportation.
	is issued as a matter of information and conveys no rights upon the certificate holder mend, extend or alter the coverage of the annual bid bond.
Cancellation:	Should the above policy be cancelled before the expiration date, the issuing surety will give thirty (30) days written notice to the certificate holder indicated above.

(Signature of Authorized Contractor Representative)

March 2010

LIST OF SUBCONTRACTORS

Section 66.0901(7), Wisconsin Statutes, provides that as a part of the proposal, the bidder also shall submit a list of the subcontractors the bidder proposes to contract with and the class of work to be performed by each. In order to qualify for inclusion in the bidder's list a subcontractor shall first submit a bid in writing, to the general contractor at least 48 hours prior to the time of the bid closing. The list may not be added to or altered without the written consent of the municipality. A proposal of a bidder is not invalid if any subcontractor and the class of work to be performed by the subcontractor has been omitted from a proposal; the omission shall be considered inadvertent or the bidder will perform the work personally.

No subcontract, whether listed herein or later proposed, may be entered into without the written consent of the Engineer as provided in Subsection 108.1 of the Standard Specifications.

Name of Subcontractor	Class of Work	Estimated Value

DECEMBER 2000

CERTIFICATION REGARDING DEBARMENT, SUSPENSION, AND OTHER RESPONSIBILITY MATTERS - PRIMARY COVERED TRANSACTIONS

Instructions for Certification

- 1. By signing and submitting this proposal, the prospective contractor is providing the certification set out below.
- 2. The inability of a person to provide the certification required below will not necessarily result in denial of participation in this covered transaction. The prospective contractor shall submit an explanation of why it cannot provide the certification set out below. The certification or explanation will be considered in connection with the department or agency's determination whether to enter into this transaction. However, failure of the prospective contractor to furnish a certification or an explanation shall disqualify such person from participation in this transaction.
- 3. The certification in this clause is a material representation of fact upon which reliance was placed when the department determined to enter into this transaction. If it is later determined that the contractor knowingly rendered an erroneous certification in addition to other remedies available to the Federal Government the department may terminate this transaction for cause or default.
- 4. The prospective contractor shall provide immediate written notice to the department to whom this proposal is submitted if at any time the prospective contractor learns that its certification was erroneous when submitted or has become erroneous by reason of changed circumstances.
- 5. The terms "covered transaction," "debarred," "suspended," "ineligible," "lower tier covered transaction," "participant," "person," "primary covered transaction," "principal," "proposal," and "voluntarily excluded," as used in this clause, have the meanings set out in the Definitions and Coverage sections of the rules implementing Executive Order 12549. You may contact the department to which this proposal is being submitted for assistance in obtaining a copy of those regulations.
- 6. The prospective contractor agrees by submitting this proposal that, should this contract be entered into, it shall not knowingly enter into any lower tier covered transaction with a person who is debarred, suspended, declared ineligible, or voluntarily excluded from participation in this covered transaction, unless authorized by the department entering into this transaction.
- 7. The prospective contractor further agrees by submitting this proposal that it will include the clause titled "Certification Regarding Debarment, Suspension, Ineligibility and Voluntary Exclusion-Lower Tier Covered Transaction," which is included as an addendum to PR-1273 "Required Contract Provisions Federal Aid Construction Contracts," without

modification, in all lower tier covered transactions and in all solicitations for lower tier covered transactions.

- 8. The contractor may rely upon a certification of a prospective subcontractor/materials supplier that it is not debarred, suspended, ineligible, or voluntarily excluded from the covered transaction, unless it knows that the certification is erroneous. A contractor may decide the method and frequency by which it determines the eligibility of its principals. Each contractor may, but is not required to, check the Disapproval List (telephone # 608/266/1631).
- 9. Nothing contained in the foregoing shall be construed to require establishment of a system of records in order to render in good faith the certification required by this clause. The knowledge and information of a contractor is not required to exceed that which is normally possessed by a prudent person in the ordinary course of business dealings.
- 10. Except for transactions authorized under paragraph 6 of these instructions, if a contractor in a covered transaction knowingly enters into a lower tier covered transaction with a person who is suspended, debarred, ineligible or voluntarily excluded from participation in this transaction, in addition to other remedies available to the Federal Government, the department may terminate this transaction for cause or default.

Certification Regarding Debarment, Suspension, and Other Responsibility Matters - Primary Covered Transactions

- (1) The prospective contractor certifies to the best of its knowledge and belief, that it and its principals:
 - (a) Are not presently debarred, suspended, proposed for debarment, declared ineligible, or voluntarily excluded from covered transactions by any Federal department or agency;
 - (b) Have not within a three-year period preceding this proposal been convicted of or had a civil judgment rendered against them for commission of fraud or a criminal offense in connection with obtaining, attempting to obtain, or performing a public (Federal, State or local) transaction or contract under a public transaction; violation of Federal or State antitrust statutes or commission of embezzlement, theft, forgery, bribery, falsification or destruction of records, making false statements or receiving stolen property;
 - (c) Are not presently indicted for or otherwise criminally or civilly charged by a governmental entity (Federal, State or local) with commission of any of the offense enumerated in paragraph (1)(b) of this certification; and
 - (d) Have not within a three-year period preceding this proposal had one or more public transactions (Federal, State or local) terminated for cause or default.
- (2) Where the prospective contractor is unable to certify to any of the statements in this certification, such prospective contractor shall attach an explanation to this proposal.

Special Provisions

Table of Contents

Article	e Description	Page #
1.	General	3
2.	Scope of Work.	3
3.	Prosecution and Progress.	3
4.	Traffic.	
5.	Public Convenience and Safety.	6
6.	Holiday Work Restrictions.	6
7.	Utilities	6
8.	Environmental Protection, Aquatic Exotic Species Control.	10
9.	Construction Over or Adjacent to Navigable Waters.	
10.	Tree and Planting Area Protection.	11
11.	Notice to Contractor – Survey.	12
12.	Erosion Control Structures.	12
13.	Notice to Contractor – Contamination Beyond Construction Limits.	12
14.	Health and Safety Requirements for Workers Remediating Petroleum Contamination.	
15.	Notice to Contractor, Notification of Demolition and/or Renovation No Asbestos	
	Found.	13
16.	Notice to Contractor, Potential Lead-Based Paint.	14
17.	Removing Old Structure Over Waterway Station 8+51.50, Item 203.0500.S.01	14
18.	Excavation, Hauling, and Disposal of Petroleum Contaminated Soil, Item	1
	205.0501.S.	
19.	QMP Base Aggregate.	17
20.	Protection of Concrete.	26
21.	Concrete Aggregates.	26
22.	Concrete Masonry Bridges.	26
23.	Concrete Identification Stamping.	26
24.	Pier Construction.	27
25.	Bar Steel Reinforcement HS Stainless Structures, Item 505.0800.S	27
26.	Temporary Shoring B-40-0923, Item 511.1200.01.	29
27.	Railing Steel Type NY4 B-40-0923, Item 513.7084.01.	30
28.	Wall Gabion, Item 532.0800.S.	30
29.	Traffic Control.	
30.	Construction Staking Structure Layout	33
31.	Conduit Rigid Nonmetallic Schedule 40 2-Inch, Item 652.0225, Conduit Rigid	1
	Nonmetallic Schedule 40 2 1/2-Inch, Item 652.0230 and Conduit Rigio	1
	Nonmetallic Schedule 40 4-Inch, Item 652.0240.	
32.	Anchor Assemblies Light Poles on Structures, Item 657.6005.S.	
33.	Seismograph, Item 999.1000.S.	
34.	Inlet Screen Type M, Item SPV.0060.01; Inlet Screen Type R, Item SPV.0060.02	

2984-07-75 1 of 58

35.	Inlet Covers Type 57, Item SPV.0060.03; Manhole Covers Type 58A, Item	
	SPV.0060.04.	.37
36.	Adjusting Water Boxes, Item SPV.0060.05.	.38
37.	Installing Conduit Into Existing Manhole, Item SPV.0060.06	. 39
38.	Junction Boxes 18"x12"x8", Item SPV.0060.07	.40
39.	Bar Grate System, Item SPV.0060.08.	.41
40.	Concrete Collar, Item SPV.0060.09.	.42
41.	Adjusting TES Manhole Cover, Item SPV.0060.10.	. 42
42.	Construction Staking Curb Ramp, Item SPV.0060.11.	. 44
43.	4-Duct Conduit, Cement Encased, 4-inch Rigid Nonmetallic Conduit DB-60, Item	
	SPV.0090.01	. 44
44.	Construction Staking Concrete Sidewalk, Item SPV.0090.02	.49
45.	Temporary Routing of Storm Sewers, Item SPV.0105.01	.51
46.	Removing Vegetated Revetment Mattress Slope Protection, Item SPV.0180.01	. 52
47.	Vegetated Revetment Mattress Slope Protection, Item SPV.0180.02; Grouted	
	Revetment Mattress Slope Protection, Item SPV.0180.03.	. 53

2984-07-75 2 of 58

SPECIAL PROVISIONS

1. General.

Perform the work under this construction contract for Project 2984-07-75 North 51st Boulevard Bridge over Lincoln Creek (B-40-0923), Local Street, located in the City of Milwaukee, Milwaukee County, Wisconsin as the plans show and execute the work as specified in the State of Wisconsin, Department of Transportation, Standard Specifications for Highway and Structure Construction, 2017 Edition, as published by the department, and these special provisions.

If all or a portion of the plans and special provisions are developed in the SI metric system and the schedule of prices is developed in the US standard measure system, the department will pay for the work as bid in the US standard system. 100-005 (20160607)

2. Scope of Work.

The work under this contract shall consist of the removal of Structure P-40-0632 and constructing B-40-0923, grading, base aggregate, structural and concrete approach slab, concrete pavement, concrete curb and gutter, concrete sidewalk and all incidental items necessary to complete the work as shown on the plans and included in the proposal and contract.

104-005 (20090901)

3. Prosecution and Progress.

Begin work within ten calendar days after the engineer issues a written notice to do so.

Provide the start date to the engineer in writing within 30 days after executing the contract but at least 14 calendar days before the preconstruction conference. Upon approval, the engineer will issue the notice to proceed within 10 calendar days before the approved start date

To revise the start date, submit a written request to the engineer at least two weeks before the intended start date. The engineer will approve or deny that request based on the conditions cited in the request and its effect on the department's scheduled resources.

During construction of the bridge, close North 51st Boulevard to through traffic as shown on the traffic control plans for the entire construction period.

Refer to traffic control plans for north bound and south bound traffic detour routing.

2984-07-75 3 of 58

Notice must be submitted at least 45 days prior to the start of construction to the FAA's Obstruction Evaluation and Airport Airspace Analysis (OE/AAA) website to determine impacts on airspace safety of the adjacent Lawrence J. Timmerman Airport. The contractor is responsible for all coordination necessary to be in compliance with airspace regulations.

All instream work that could adversely impact water quality and fish migration shall be undertaken after June 15.

Migratory Birds

There is potential for bird nesting under the North 51st Boulevard Bridge. The International Migratory Bird Act protects international migratory birds such as seagulls, swallows, and terns. The Department of Natural Resources recommends that the bridge be checked twice daily and empty nests be removed. It is a violation of federal law to disturb nests if eggs or fledgling young are present. Please contact Brian Nelson, United States Department of Agriculture, Animal and Plant Health Inspection Service, Wildlife Services at (920) 324-4514 if eggs or fledgling young are present.

If swallow nests are present, do not remove or destroy them when the swallows are nesting or rearing their young. The nesting season for swallows has been established as May 1 through August 30. Apply for a depredation permit from the US Fish and Wildlife Service for work that may disturb or destroy occupied nests during the nesting period. The need for a permit may be avoided by clearing the nests from and installing a suitable netting device on the remaining existing superstructure prior to nesting activity to prevent the swallows from nesting. The cost for preventing nesting shall be included in the cost of 'Removing Old Structure over Waterway Station 8+51.50', item 203.0500.S.01.

If contractor's work does not start by May 1, 2017, the City of Milwaukee will take appropriate action to prevent nesting until the start of project construction.

Emerald Ash Borer

This project has the potential for spreading the Emerald Ash Borer (EAB) beetle. It is illegal to move or transport ash material, the emerald ash borer, and hardwood debris (i.e. firewood) from EAB quarantined areas to a non-quarantined area without a compliance agreement issued by WI Department of Agriculture, Trade and Consumer Protection. Regulated items include cut hardwood (non-coniferous) firewood, ash logs, ash mulch or bark fragments larger than on inch in diameter, or ash nursery stock (DATCP statute 21).

All construction activities should occur in an environmentally sound manner. This includes the proper disposal of all demolition material that cannot be recycled.

Northern Long-eared Bat (Myotis septentrionalis)

Northern Long-eared Bats (NLEB) have the potential to inhabit the project limits because they roost in trees. Roosts may not have been observed on this project, but conditions to support the species exist. The species and all active roosts are protected by the Federal Endangered Species Act. If an individual bat or active roost is encountered during

2984-07-75 4 of 58

construction operations, stop work and notify the engineer and the WisDOT Regional Environmental Coordinator (REC).

In accordance to the final 4(d) rule issued for the NLEB, the department has determined that the proposed activity may affect, but will not result in prohibited take of the NLEB. The activity involves tree removal, but will not occur within 0.25 miles of a known hibernacula, nor will the activity remove a known maternity roost tree or any other tree within 150 feet of a known maternity roost tree.

If additional trees need to be removed, no Clearing shall occur without prior approval from the engineer, following coordination with the WisDOT REC. Additional tree removal beyond the area originally specified will require consultation with the United States Fish and Wildlife Service (USFWS) and may require a bat presence/absence survey. Notify the engineer if additional Clearing cannot be avoided to begin coordination with the WisDOT REC. The WisDOT REC will initiate consultation with the USFWS and determine if a survey is necessary.

Submit a schedule and description of Clearing operations with the ECIP 14 days prior to any Clearing operations. The department will determine, based on schedule and scope of work, what additional erosion control measures shall be implemented prior to the start of Clearing operations, and list those additional measures in the ECIP.

Environmental Protection

Restrict the removal of vegetative cover and exposure of bare ground to the minimum amounts necessary to complete construction. Restoration of disturbed soils should take place as soon as conditions permit. If sufficient vegetative cover will not be achieved because of late season construction, the site must be properly winterized.

All temporary stock piles must be in an upland location and protected with erosion control measures (e.g. silt fence, rock filter-bag berm, etc.). Do not stockpile materials in wetlands, waterways or floodplains.

Tracking pads must be installed at any ingress/egress points to work areas to prevent tracking of sediment onto city streets. Dust from disturbed areas and/or haul roads must be controlled through contractor defined methods.

4. Traffic.

On-street parking will not be allowed on North 51st Boulevard between West Parkway Drive and West Lincoln Creek Drive during construction.

The City of Milwaukee will provide all posting of parking restrictions to facilitate construction operations. Contact Mr. Joseph Blakeman of Traffic and Lighting at (414) 286-8070, three working days prior to the start of construction operations.

Provide access for mail service, utility meter reading and garbage pick-up.

2984-07-75 5 of 58

Do not store equipment, vehicles or materials beyond the project limits without specific approval by the engineer.

5. Public Convenience and Safety.

Revise standard spec 107.8(6) as follows:

Check for and comply with local ordinances governing the hours of operation of construction equipment. Do not operate motorized construction equipment from 9:00 PM until the following 7:00 AM, unless prior written approval is obtained from the engineer. 107-001 (20060512)

6. Holiday Work Restrictions.

Do not perform work on, nor haul materials of any kind along or across any portion of the highway carrying North 51st Boulevard traffic, and entirely clear the traveled way and shoulders of such portions of the highway of equipment, barricades, signs, lights, and any other material that might impede the free flow of traffic during the following holiday periods:

- From noon Friday, May 26, 2017 to 6:00 AM Tuesday, May 30, 2017 for Memorial Day;
- From noon Monday, July 3, 2017 to 6:00 AM Wednesday, July 5, 2017 for Independence Day;
- From noon Friday, September 1, 2017 to 6:00 AM Tuesday, September 5, 2017 for Labor Day;
- From noon Wednesday, November 22, 2017 to 6:00 AM Monday, November 27, 2017 for Thanksgiving Day.

107-005 (20050502)

7. Utilities.

This contract does not come under the provision of Administrative Rule Trans 220.

The City of Milwaukee has notified the department that the following operations necessary for the construction of new facilities and/or adjustment of existing facilities will be coordinated with the contractor's construction operations by each representative utility unless otherwise noted. Coordinate construction activities with a call to Digger's Hotline or a direct call to the utilities that have facilities in the area as required by statutes. Use caution to ensure the integrity of underground facilities and maintain code clearances from overhead facilities at all times.

Note: Bidders are advised to contact each utility company listed in the plans prior to preparing their bid to obtain current information on the status of each utility company's work required in association with the project. Existing trees, street light poles, hydrants and utility poles are to remain in place during construction unless noted on plans. Conduct

2984-07-75 6 of 58

an on-site visit prior to bidding to determine any special measures required for proper clearance between the trees, hydrants, poles, other utilities and any other physical structures and the construction equipment.

A City of Milwaukee

A.1 Water

There is an existing 12" water main in 24" steel casing buried on the West side of the bridge. This utility will remain in place and active for the duration of construction. Care shall be taken during excavation in the vicinity of the water main. The proposed construction activities shall not affect the integrity of the existing water main. If damaged, the contractor will be responsible for all costs incurred to restore the water main to its original condition. Care shall be taken during sheet piling operations to avoid conflict or damage to the existing utilities. Water box adjustments will be done by the contractor.

Contact Mr. Dave Goldapp of Milwaukee Water Works at (414) 286-6301 office, or (414) 708-2695 mobile, for any questions regarding this facility.

For general questions regarding this utility contact Mr. Musa Abu-Khader of the City of Milwaukee at (414) 286-2432 office, or (414) 708-2529 mobile.

A.2 Sewer

There are four storm sewer outfalls under the existing bridge. Sewer work includes removal of 8 feet of 27" Dia. corrugated metal pipe.

The bid item 203.0200 'Removing Old Structure' (LS) includes removal of 16 feet of 42-inch diameter pipe, (Station 8+02, 32.8' LT to 8+18, 32' LT), 2 feet of 27' diameter pipe (Station 9+05, 31.4' LT to 9+07, 31.5' LT), 10 feet of 24" diameter pipe (Station 7+94, 30' RT to 8+04, 32.5' RT), and 13 feet of 15" diameter pipe (Station 8+87, 32.7' RT to Station 9+00, 32.7' RT). Coordinate all sewer work with slope paving and grading operations.

Outlets run full during heavy rainfall events. Install concrete apron and grates at each storm outlet during construction. Use flexible plastic pipe to capture and channel all flow from the outfalls to the diverted river. See 'Temporary Routing of Storm Sewers', Item SPV.0105.01.

During construction of the piers and the streambed, the waterway will be diverted as shown in the plans. A water control plan shall be developed by the contractor and approved by the engineer to divert water from the construction zone to the diverted waterway. The opposite side outfalls will drop directly into the temporary waterway. Care shall be taken during sheet piling operations to avoid conflict or damage to the existing utilities.

Two and one half feet minimum clearance from the outside edges of the sewers must be maintained during pile placement and driving operations. Pre-boring of the piles shall be performed for all piles directly adjacent to the sewers unless they are already exposed for

2984-07-75 7 of 58

replacement to an approximate elevation of 64.00 City Datum to be paid under bid item 550.0100 'Pre-Boring Unconsolidated Materials'.

Contact Mr. Musa Abu-Khader of the City of Milwaukee at (414) 286-2432 office, or (414) 708-2529 mobile, for any questions regarding this facility.

A.3 Street Lighting

There are four 2 1/2" diameter PVC schedule 40 street lighting conduits, of which two each are cast into the east and west sidewalks. Existing street lighting facilities close to the structure will be removed by the city before construction starts. Temporary overhead circuitry will be installed by the city around the existing structure 36 feet west of the city right-of-way to keep the remaining street lighting units working that are north and south of the structure. Removal and disposal of the existing conduits will be part of the bid item 'Removing Old Structure Over Waterway Station 8+51.50, Item 203.0500.S.01.

The contractor is responsible for supplying and installing conduit, junction boxes, and anchorage assemblies as detailed in the plans. The contractor shall contact the city Street Lighting Field Operations as noted below after the new conduit is installed but before concrete is poured for inspection of the installation. There must be an expansion coupler installed where ever the conduit(s) exits the structure. Each conduit that runs through the bridge structure is to be extended 3 feet beyond the bridge deck. The end of the PVC conduit is to be identified on the curb with an arrow embossed into the top of the curb. All street lighting conduits are to have a 3/8-inch nylon pull rope installed and all conduit stubs (excluding 1-inch drain) are also to be capped with a temporary cap and not duct tape.

During and after construction, permanent underground street lighting facilities and lighting units will be installed in coordination with this project by the city. The contractor is to keep Street Lighting Field Operations informed of the progress of the bridge construction.

Contact Mr. Dennis Miller of the City of Milwaukee Street Lighting Field Operations at (414) 286-5942 office, or (414) 708-4251 mobile, seven working days before construction work starts, and during construction to give a three working day notice for coordination of permanent street lighting work.

If the contractor requests the relocation of any street lighting facilities, permanent or temporary, for his convenience, he will be responsible for all costs incurred by the street lighting personnel fulfilling his request.

Report any accidental damages to street lighting facilities, as soon as possible to Street Lighting Shop Dispatcher (414) 286-5944. The contractor will be held liable for those costs.

For general questions regarding this utility contact Mr. Musa Abu-Khader of the City of Milwaukee at (414) 286-2432 office, or (414) 708-2529 mobile.

2984-07-75 8 of 58

A.4 City Underground Conduit (CUC/TES)

The City of Milwaukee has conduit located within the project limits. The City of Milwaukee has existing four 4-inch conduits hanging from the underside of the deck located approximately 16'-10" feet west from the centerline of North 51st Boulevard. Removal and disposal of the conduits shall be included under the bid item 'Removing Old Structure Over Waterway (8+51.50)'. Provide four 4-inch PVC conduits and cast into the new Structure B-40-923, and continue under the structural approach slabs as shown on the plans. Provide and install concrete encased conduit and manholes according to these specifications in the approach roadway and as shown on the plans. Install a 3/8" nylon pull rope through the conduits between manholes.

Adjust existing CUC/TES manhole covers as part of this project under the bid item "Adjusting TES Manhole Covers". Contact Karen Rogney at (414) 286-3243 seven days in advance of working on CUC facilities.

For general questions regarding this utility contact Mr. Musa Abu-Khader of the City of Milwaukee at (414) 286-2432 office, or (414) 708-2529 mobile.

A.5 Communications

The City of Milwaukee has communications cables in the existing conduit in the structure. These cables will be removed prior to construction and restored once construction is complete.

Contact Mr. David Henke at (414) 286-3248 two weeks prior to the start of construction for coordination.

For general questions regarding this utility contact Mr. Musa Abu-Khader of the City of Milwaukee at (414) 286-2432 office, or (414) 708-2529 mobile.

B WE Energies - Gas

There is an existing discontinued 4-inch steel gas main located approximately 7' to 12' off the east right-of-way line, suspended from the underside of the existing bridge. Removal and disposal of the steel pipe on the bridge shall be included under the bid item 'Removing Old Structure Over Waterway (8+51.50)'. Call We Energies Gas Dispatch (800) 261-5325 prior to removal to verify that the unmarked facilities have been discontinued. At no time is it acceptable to push, pull, cut or drill an unmarked facility without the direct explicit consent of We Energies. A new 4-inch PE main was bored under the streambed at an approximate depth of four-feet from the existing streambed elevation, and approximately 3 feet west of the east city right-of-way line that will remain in service during construction. If extensive EBS work is found to be required during construction, contact Mr. Josh Mount at (414) 935-4367 office, or (414) 218-2053 mobile.

Care shall be taken during sheet piling operations to avoid conflict or damage to the existing utilities.

2984-07-75 9 of 58

C WE Energies – Electric

There is an existing four duct package suspended under the bridge approximately 9' west of the centerline of N. 51st Boulevard. We Energies will remove this package prior to the construction and will not be reinstalled. Contact Mr. Leonard Wilson of the WE Energies-Electric at (414) 940-5690 for questions relating to this facility.

D MMSD

There is an existing 24" discontinued MIS 10-feet east of the centerline of N. 51st Boulevard at an approximate elevation of 59.00 City Datum that will not affected by construction operations.

There is a 96" MIS 1-foot 6-inches west of the centerline of N. 51st Boulevard at an approximate elevation of 34.00 City Datum that will remain in place. Three feet clearance from the outside edge of the MIS must be maintained during pile placement and driving operations. Pre-boring of the piles shall be performed for all piles directly adjacent to the MIS to an approximate elevation of 34.00 City Datum to be paid under bid item 550.0100 'Pre-Boring Unconsolidated Materials'.

The existing revetment mats upstream and downstream of the existing bridge are the property of MMSD. Any disturbance of the existing revetment mats shall be minimized and restored as shown in the plans and described in these specifications.

Contact Mr. Larry Anderson of the MMSD at (414) 225-2241 office, or (414) 617-1429 mobile, at least 14 days in advance for coordination of utility work.

8. Environmental Protection, Aquatic Exotic Species Control.

Exotic invasive organisms such as VHS, zebra mussels, purple loosestrife, and Eurasian water milfoil are becoming more prolific in Wisconsin and pose adverse effects to waters of the state. Wisconsin State Statutes 30.07, "Transportation of Aquatic Plants and Animals; Placement of Objects in Navigable Waters", details the state law that requires the removal of aquatic plants and zebra mussels each time equipment is put into state waters.

At construction sites that involve navigable water or wetlands, use the follow cleaning procedures to minimize the chance of exotic invasive species infestation. Use these procedures for all equipment that comes in contact with waters of the state and/or infested water or potentially infested water in other states.

Ensure that all equipment that has been in contact with waters of the state, or with infested or potentially infested waters, has been decontaminated for aquatic plant materials and zebra mussels prior to being used in other waters of the state. Before using equipment on this project, thoroughly disinfect all equipment that has come into contact with potentially infested waters. Use the following inspection and removal procedures (guidelines from the Wisconsin Department of Natural Resources http://dnr.wi.gov/topic/fishing/documents/vhs/disinfection protocols.pdf for disinfection:

2984-07-75 10 of 58

- 1. Prior to leaving the contaminated site, wash machinery and ensure that the machinery is free of all soil and other substances that could possibly contain exotic invasive species;
- 2. Drain all water from boats, trailers, bilges, live wells, coolers, bait buckets, engine compartments, and any other area where water may be trapped;
- 3. Inspect boat hulls, propellers, trailers and other surfaces. Scrape off any attached mussels, remove any aquatic plant materials (fragments, stems, leaves, seeds, or roots), and dispose of removed mussels and plant materials in a garbage can prior to leaving the area or invested waters; and
- 4. Disinfect your boat, equipment and gear by either:
 - a. Washing with ~212° F water (steam clean), or
 - b. Drying thoroughly for five days after cleaning with soap and water and/or high pressure water, or
 - c. Disinfecting with either 200 ppm (0.5 oz per gallon or 1 Tablespoon per gallon) Chlorine for 10-minute contact time or 1:100 solution (38 grams per gallon) of Virkon Aquatic for 20- to 30-minute contact time. Note: Virkon is not registered to kill zebra mussel veligers nor invertebrates like spiny water flea. Therefore this disinfect should be used in conjunction with a hot water (>104° F) application.

Complete the inspection and removal procedure before equipment is brought to the project site and before the equipment leaves the project site. 107-055 (20130615)

9. Construction Over or Adjacent to Navigable Waters.

Add the following to standard spec 107.19:

The Lincoln Creek is classified as a navigable waterway. 107-060 (20150630)

10. Tree and Planting Area Protection.

No tree is to be removed by the contractor.

Manually perform all cutting for the removal of sod and soil in order to establish a finished grade within 4 feet of existing trees, if necessary. Do not park or store any construction equipment, cars, trucks, and/or materials on tree borders on this project or adjacent roadways. Root foundations must remain adequate to withstand heavy windstorms. Do not cut root systems of street trees for the installation of any type of cable. Contact the Forestry Division at (414) 708-2428 for any questions relating to these issues.

Use caution during the construction process to avoid damage to the roots, trunks, and tree branches and forestry irrigation system. Damage caused to any street tree or irrigation system will be repaired by the City Forestry department at the contractor's cost.

2984-07-75 11 of 58

Refrain from placing or storing any construction materials, sand, soil, or any other materials on the surface of the soil within the root zone of existing City of Milwaukee street trees. Additionally, assure that no construction chemicals, tank rinsates, or petroleum products are deposited within the root zones of the trees. Root zone is defined as that area within the dripline of trees.

11. Notice to Contractor – Survey.

Digital design file information/existing surface data, including design surface DTMs and/or coordinate system GPS information will not be available for this project.

All survey work necessary to stake out and construct all portions of this project will be measured and paid for under the staking bid items designated in this contract.

12. Erosion Control Structures.

Within seven calendar days after the commencement of work on the bridge superstructure, place all permanent erosion control devices, including riprap, erosion mat, ditch checks, seed, fertilizer, mulch, soil stabilizer, or any other item required by the contract or deemed necessary by the engineer. These devices shall be in place in the area under the bridge and on both sides of the roadway, from the waterway to a point 100 feet behind the backwall of the abutment. Within said limits, place these devices to a height equivalent to the calculated water elevation resulting from a storm that occurs on the average of once every two years (Q2) as shown on the plan, or as directed by the engineer. Prior to initial construction operations, place turbidity barriers, silt screens, and other temporary erosion control measures as shown on the plans, and remove them after the permanent erosion control devices are in place unless directed otherwise by the engineer.

In the event that construction activity does not disturb the existing ground below the Q2 elevation, the above timing requirements for permanent erosion control shall be waived. 107-070 (20030820)

13. Notice to Contractor – Contamination Beyond Construction Limits.

The department completed testing for soil contamination within this project where excavation is required. Testing indicated that petroleum-contaminated soil which may adversely influence groundwater quality is present within the project limits.

Groundwater within the project limits is anticipated to be beyond the excavation depths necessary to complete the work under this project. Control construction operations to ensure they do not extend beyond the excavation limits indicated in the plans. If groundwater is encountered during construction, but does not require removal as a standard course of construction, it shall be allowed to remain in place. If excavation dewatering is required, notify the engineer, presume the groundwater is contaminated with petroleum unless tested and proven otherwise, and manage contaminated groundwater accordingly.

2984-07-75 12 of 58

The management of contaminated groundwater, including all labor, tools, equipment, and incidentals associated with pumping, temporary containment, and treatment and disposal, shall be considered incidental to other items in the contract.

14. Health and Safety Requirements for Workers Remediating Petroleum Contamination.

Add the following to standard spec 107.1(2):

Soil contamination with gasoline, diesel fuel, fuel oil, or other petroleum related products may be encountered during excavation activities. Prepare a site specific Health and Safety Plan complying with the Occupational Safety and Health Administration (OSHA) standard for Hazardous Waste Operation and Emergency Response (HAZWOPER), 29 CFR 1910.120.

All site workers taking part in remediation activities or who will have the reasonable probability of exposure of safety or health hazards associated with the hazardous material shall have completed Health and Safety training that meets OSHA requirements. Prior to the start of remediation work, submit to the engineer a site specific Health and Safety Plan, and written verification that workers will have completed up-to-date OSHA training.

Develop, delineate, and enforce the health and safety exclusions zones for each contaminated site location pursuant to 29 CFR 1910.120. 107-115 (20150630)

15. Notice to Contractor, Notification of Demolition and/or Renovation No Asbestos Found.

John Roelke, License Number All-119523, inspected Structure P-40-632 for asbestos on November 25, 2013. No regulated Asbestos Containing Material (RACM) was found on this structure. A copy of the inspection report is available from: DAAR Engineering, (414) 225-9817.

In accordance with NR447 and DHS159, ensure that DNR or DHS receives a completed Notification of Demolition and/or Renovation (DNR Form 4500-113 (R 4/11), or subsequent revision) via U.S. mail, hand-delivery, or using the online notification system at least 10 working days prior to beginning any construction or demolition. Pay all associated fees. Provide a copy of the completed 4500-113 form to DAAR Engineering (414) 225-9817 and DOT BTS-ESS attn: Hazardous Materials Specialist PO Box 7965, Madison, WI 53707-7965. In addition, comply with all local or municipal asbestos requirements.

2984-07-75 13 of 58

Use the following information to complete WisDNR form 4500-113:

Site Name: Structure P-40-632, N. 51st Blvd over Lincoln Creek

Site Address: 0.6M N JCT STH 145

Ownership Information: City of Milwaukee, 841 N. Broadway, Milwaukee, WI

53202

Contact: DAAR Engineering Phone: (414) 225-9817

Age: 58 years old. This structure was constructed in 1959.

Area: 8361 SF of deck

Insert the following paragraph in Section 6.g.:

If asbestos not previously identified is found or previously non-friable asbestos becomes crumbled, pulverized, or reduced to a powder, stop work immediately, notify the engineer, and the engineer will notify the department's Bureau of Technical Services at (608) 266-1476 for an emergency response according to standard spec 107.24. Keep material wet until it is abated or until it is determined to be non-asbestos containing material.

107-125 (20120615)

16. Notice to Contractor, Potential Lead-Based Paint.

Lead-based paint has been applied to the existing bridge girders, diaphragms, and railings. Use appropriate and adequate health and safety measures to protect site workers from an unsafe exposure to residual lead, and to avoid a lead release into the surrounding environment during demolition.

17. Removing Old Structure Over Waterway Station 8+51.50, Item 203.0500.S.01.

Conform to standard spec 203 as modified in this special provision.

Removal of all existing utilities as described herein is incidental to this bid item.

Add the following to standard spec 203:

203.3.6 Removals Over Waterways and Wetlands 203.3.6.1 Removing Old Structure Over Waterway

(1) Remove the existing Structure P-40-632 over the Lincoln Creek conforming to the contractor's approved structure removal and clean-up plan. Remove all reinforcing steel, all concrete, and all other debris that falls into the waterway or wetland. Remove large pieces of the structure within 36 hours. The contractor may leave limited amounts of small concrete pieces scattered over the waterway floor or wetland only if the engineer allows.

2984-07-75 14 of 58

- (2) Submit a structure removal and clean-up plan as part of the erosion control implementation plan required under standard spec 107.20. Do not start work under the structure removal and clean-up plan without the department's written approval of the plan. Include the following information in the structure removal and clean-up plan:
 - Methods and schedule to remove the structure.
 - Methods to control potentially harmful environmental impacts.
 - Methods for removing piers and abutments. If blasting in water, include restrictions that regulatory agencies and the contract require.
 - Methods for cleaning the waterway or wetlands.
- (3) If stockpiling spoil material, place it on an upland site an adequate distance from the waterway, wetland, or any open water created by excavation. Install silt fence between the spoil pile and the waterway, wetland, or excavation site.

Add the following Removing Old Structure bid item to standard spec 203.5.1:

ITEM NUMBER	DESCRIPTION	UNIT
203.0500.S.01	Removing Old Structure Over Waterway Station 8+51.50	LS

18. Excavation, Hauling, and Disposal of Petroleum Contaminated Soil, Item 205.0501.S.

A Description

A.1 General

This special provision describes excavating, loading, hauling, and disposing of contaminated soil at a DNR approved bioremediation facility. The closest DNR approved facility is the Waste Management Orchard Ridge Landfill at W124 N9355 Boundary Road, Menomonee Falls, Wisconsin, 53051. The Orchard Ridge Landfill has preliminarily approved acceptance of contaminated material from the project.

Perform this work according to standard spec 205 and with pertinent parts of Chapters NR 700-754 of the Wisconsin Administrative Code, as supplemented herein. Per NR 718.07, a solid waste collection and transportation service-operating license is required under NR 502.06 for each vehicle used to transport contaminated soil.

A.2 Notice to the Contractor – Contaminated Soil Locations

The department completed testing for soil contamination within this project where excavation is required. Testing indicated that petroleum-contaminated soil is present at the following location as shown on the plans:

1. Station 7+39 to 9+70, from construction limits left to construction limits right, and from approximately 0.5 feet below ground surface to the maximum depth of excavation.

2984-07-75 15 of 58

2. Lincoln Creek, from south bank to north bank, from construction limits left to construction limits right, and from the creek bed surface to the maximum depth of excavation

If contaminated soils are encountered elsewhere on the project, terminate excavation activities in the area and notify the engineer.

For further information regarding previous investigation and remediation activities at these locations, contact:

Contact: Holly Rutenbeck

Address: 841 N. Broadway, Milwaukee, WI 53202

Office: (414) 286-0465

Email: holly.rutenbeck@milwaukee.gov

A.3 Coordination

The contractor shall be responsible for documenting the activities associated with management of contaminated soil are in conformance with the contaminated management methods for this project as specified herein; and obtaining the necessary approvals for disposal of contaminated soil from the bioremediation facility.

The contractor shall identify the DNR approved bioremediation facility that will be used for disposal of contaminated soils, and provide this information prior to commencement of excavation activities. The contractor shall be responsible for obtaining the necessary approvals for disposal of contaminated soils from the bioremediation facility.

A.4 Health and Safety Requirements

Add the following to standard spec 107.1:

During excavation activities, expect to encounter soil contaminated with polycyclic aromatic hydrocarbons (PAHs) and other petroleum related products. Site workers taking part in activities that will result in the reasonable probability of exposure to safety and health hazards associated with hazardous materials shall have completed health and safety training that meets the Occupational Safety and Health Administration (OSHA) requirements for Hazardous Waste Operations and Emergency Response (HAZWOPER), as provided in 29 CFR 1910.120.

Prepare a site-specific Health and Safety Plan, and develop, delineate and enforce the health and safety exclusion zones for each contaminated site location as required by 29 CFR 1910.120. Submit the site-specific health and safety plan and written documentation of up-to-date OSHA training to the engineer prior to the start of work.

B (Vacant)

2984-07-75 16 of 58

C Construction

Add the following to standard spec 205.3:

Control operations in the contaminated areas to minimize the quantity of contaminated soil excavated

All excavated material will be designated as follows:

- Excavation Common consisting of clean soil and/or clean construction and demolition fill (such as clean soil, boulders, concrete, reinforced concrete, bituminous pavement, bricks, building stone, and unpainted or untreated wood), which under NR 500.08 are exempt materials, or
- Contaminated soil for bioremediation at the DNR approved bioremediation facility.

Directly load and haul soils for offsite bioremediation to the DNR approved bioremediation facility. Use loading and hauling practices that are appropriate to prevent any spills or releases of contaminated soils or residues. Prior to transport, sufficiently dewater soils designated for off-site bioremediation so as not to contain free liquids.

D Measurement

The department will measure Excavation, Hauling and Disposal of Petroleum Contaminated Soil in tons of contaminated soil accepted by the bioremediation facility as documented by weight tickets generated by the bioremediation facility.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER DESCRIPTION UNIT 205.0501.S Excavation, Hauling, and Disposal of Petroleum TON Contaminated Soil

Payment is full compensation for excavating, segregating, loading, hauling, and treatment via bioremediation of contaminated soil; obtaining solid waste collection and transportation service operating licenses; and dewatering of soils prior to transport, if necessary.

19. QMP Base Aggregate.

A Description

A.1 General

(1) This special provision describes contractor quality control (QC) sampling and testing for base aggregates, documenting those test results, and documenting related production and placement process changes. This special provision also describes department quality verification (QV), independent assurance (IA), and dispute resolution.

2984-07-75 17 of 58

- (2) Conform to standard spec 301, standard spec 305, and standard spec 310 as modified here in this special provision. Apply this special provision to material placed under all of the Base Aggregate Dense and Base Aggregate Open Graded bid items, except do not apply this special provision to material classified as reclaimed asphaltic pavement placed under the Base Aggregate Dense bid items.
- (3) Do not apply this special provision to material placed under the Aggregate Detours, Salvaged Asphaltic Pavement Base, Breaker Run, Select Crushed, Pit Run, Subbase, or Riprap bid items.
- (4) Provide and maintain a quality control program, defined as all activities related to and documentation of the following:
 - 1. Production and placement control and inspection.
 - 2. Material sampling and testing.
- (5) Chapter 8 of the department's construction and materials manual (CMM) provides additional detailed guidance for QMP work and describes required sampling and testing procedures. The contractor may obtain the CMM from the department's web site at:

http://wisconsindot.gov/Pages/doing-bus/eng-consultants/cnslt-rsrces/rdwy/default.aspx

A.2 Contractor Testing for Small Quantities

- (1) The department defines a small quantity, for each individual Base Aggregate bid item, as a plan quantity of 9000 tons or less of material as shown in the schedule of items under that bid item.
- (2) The requirements under this special provision apply equally to a small quantity for an individual bid item except as follows:
 - 1. The contractor need not submit a full quality control plan but shall provide an organizational chart to the engineer including names, telephone numbers, and current certifications of all persons involved in the quality control program for material under affected bid items.

2. Divide the aggregate into uniformly sized sublots for testing as follows:

Plan Quantity	Minimum Required Testing
≤ 1500 tons	One test from production, load-out, or
	placement at the contractor's option ^[1]
> 1500 tons and ≤ 6000 tons	Two tests of the same type, either from
	production, load-out, or placement at
	the contractor's option ^[1]
$>$ 6000 tons and \leq 9000 tons	Three placement tests ^{[2] [3]}

2984-07-75 18 of 58

- If using production tests for acceptance, submit test results to the engineer for review prior to incorporating the material into the work. Production test results are valid for a period of 3 years.
- [2] For 3-inch material, obtain samples at load-out.
- If the actual quantity overruns 9000 tons, create overrun sublots to test at a rate of one additional placement test for each 3000 tons, or fraction of 3000 tons, of overrun.
- 3. No control charts are required. Submit aggregate load-out and placement test results to the engineer within one business day of obtaining the sample. Assure that all properties are within the limits specified for each test.
- 4. Department verification testing is optional for quantities of 6000 tons or less.
- (3) Material represented by a sublot with any property outside the specification limits is nonconforming. The department may reject material or otherwise determine the final disposition of nonconforming material as specified in standard spec 106.5.

B Materials

B.1 Quality Control Plan

- (1) Submit a comprehensive written quality control plan to the engineer at or before the pre-construction meeting. Do not place base before the engineer reviews and comments on the plan. Construct the project as that plan provides.
- (2) Do not change the quality control plan without the engineer's review. Update the plan with changes as they become effective. Provide a current copy of the plan to the engineer and post in each of the contractor's laboratories as changes are adopted. Ensure that the plan provides the following elements:
 - 1. An organizational chart with names, telephone numbers, current certifications and/or titles, and roles and responsibilities of QC personnel.
 - 2. The process used to disseminate QC information and corrective action efforts to the appropriate persons. Include a list of recipients, the communication means that will be used, and action time frames.
 - 3. A list of source and processing locations, section and quarter descriptions, for all aggregate materials requiring QC testing.
 - 4. Test results for wear, sodium sulfate soundness, freeze/thaw soundness, and plasticity index of all aggregates requiring QC testing. Obtain this information from the region materials unit or from the engineer.
 - 5. Descriptions of stockpiling and hauling methods.
 - 6. Locations of the QC laboratory, retained sample storage, and where control charts and other documentation is posted.
 - 7. An outline for resolving a process control problem. Include responsible personnel, required documentation, and appropriate communication steps.

2984-07-75

B.2 Personnel

(1) Have personnel certified under the department's highway technician certification program (HTCP) perform sampling, testing, and documentation as follows:

Required Certification Level:	Sampling or Testing Roles:	
Aggregate Technician IPP		
Aggregate Sampling Technician	Aggregate Sampling ^[1]	
Aggregate Assistant Certified Technician (ACT-AGG)		
	Aggregate Gradation Testing,	
Aggregate Technician IPP	Aggregate Fractured Particle	
Aggregate Assistant Certified Technician (ACT-AGG)	Testing, Aggregate Liquid	
	Limit and Plasticity Index	
	Testing	

- Plant personnel under the direct observation of an aggregate technician certified at level one or higher may operate equipment to obtain samples.
- (2) A certified technician must coordinate and take responsibility for the work an ACT performs. Have a certified technician ensure that all sampling and testing is performed correctly, analyze test results, and post resulting data. No more than one ACT can work under a single certified technician.

B.3 Laboratory

(1) Perform QC testing at a department-qualified laboratory. Obtain information on the Wisconsin laboratory qualification program from:

Materials Management Section 3502 Kinsman Blvd. Madison, WI 53704 Telephone: (608) 246-5388

 $\underline{http://wisconsindot.gov/Pages/doing-bus/eng-consultants/cnslt-rsrces/tools/appr-prod/qual-labs.aspx}$

B.4 Quality Control Documentation

B.4.1 General

(1) Submit base aggregate placement documentation to the engineer within 10 business days after completing base placement. Ensure that the submittal is complete, neatly organized, and includes applicable project records and control charts.

B.4.2 Records

(1) Document all placement observations, inspection records, and control adjustments daily in a permanent field record. Also include all test results in the project records. Provide test results to the engineer within 6 hours after obtaining a sample. For 3-inch base, extend this 6-hour limit to 24 hours. Post or distribute tabulated results using a method mutually agreeable to the engineer and contractor.

2984-07-75 20 of 58

B.4.3 Control Charts

- (1) Plot gradation and fracture on the appropriate control chart as soon as test results are available. Format control charts according to CMM 8.30. Include the project number on base placement control charts. Maintain separate control charts for each base aggregate size, source or classification, and type.
- (2) Provide control charts to the engineer within 6 hours after obtaining a sample. For 3-inch base, extend this 6-hour limit to 24 hours. Post or distribute charts using a method mutually agreeable to the engineer and contractor. Update control charts daily to include the following:
 - 1. Contractor individual QC tests.
 - 2. Department QV tests.
 - 3. Department IA tests.
 - 4. Four-point running average of the QC tests.
- (3) Except as specified under B.8.2.1 for nonconforming QV tests, include only QC tests in the running average. The contractor may plot process control or informational tests on control charts, but do not include these tests, conforming QV tests, or IA tests in the running average.

B.5 Contractor Testing

- (1) Test gradation, fracture, liquid limit and plasticity index during placement for each base aggregate size, source or classification, and type.
- (2) Test gradation once per 3000 tons of material placed. Determine random sample locations and provide those sample locations to the engineer. Obtain samples after the material has been bladed, mixed, and shaped but before compacting; except collect 3-inch samples from the stockpile at load-out. Do not sample from material used to maintain local traffic or from areas of temporary base that will not have an overlying pavement. On days when placing only material used to maintain local traffic or only temporary base that will not have an overlying pavement, no placement testing is required.
- (3) Split each contractor QC sample and identify it according to CMM 8.30. Retain the split for 7 calendar days in a dry, protected location. If requested for department comparison testing, deliver the split to the engineer within one business day.
- (4) The engineer may require additional sampling and testing to evaluate suspect material or the technician's sampling and testing procedures.
- (5) Test fracture for each gradation test until the fracture running average is above the lower warning limit. Subsequently, the contractor may reduce the frequency to one test per 10 gradation tests if the fracture running average remains above the warning limit.

2984-07-75 21 of 58

(6) Test the liquid limit and plasticity index for the first gradation test. Subsequently, test the liquid limit and plasticity index a minimum of once per 10 gradation tests.

B.6 Test Methods

B.6.1 Gradation

(1) Test gradation using a washed analysis conforming to the following as modified in CMM 8.60:

Gradation	AASHTO T 27
Material finer than the No. 200 sieve.	AASHTO T 11

- (2) For 3-inch base, if 3 consecutive running average points for the percent passing the No. 200 sieve are 8.5 percent or less, the contractor may use an unwashed analysis. Wash at least one sample out of 10. If a single running average for the percent passing the No. 200 sieve exceeds 8.5 percent, resume washed analyses until 3 consecutive running average points are again 8.5 percent passing or less.
- (3) Maintain a separate control chart for each sieve size specified in standard spec 305 or standard spec 310 for each base aggregate size, source or classification, and type. Set control and warning limits based on the standard specification gradation limits as follows:
 - 1. Control limits are at the upper and lower specification limits.
 - 2. There are no upper warning limits for sieves allowing 100 percent passing and no lower control limits for sieves allowing 0 percent passing.
 - 3. Dense graded warning limits, except for the No. 200 sieve, are 2 percent within the upper and lower control limits. Warning limits for the No. 200 sieve are set 0.5 percent within the upper and lower control limits.
 - 4. Open graded warning limits for the 1-inch, 3/8-inch, and No. 4 sieves are 2 percent within the upper and lower control limits. Upper warning limits for the No. 10, No. 40, and No. 200 sieves are 1 percent inside the upper control limit.

B.6.2 Fracture

- (1) Test fracture conforming to CMM 8.60. The engineer will waive fractured particle testing on quarried stone.
- (2) Maintain a separate fracture control chart for each base aggregate size, source or classification, and type. Set the lower control limit at the contract specification limit, either specified in another special provision or in table 301-2 of standard spec 301.2.4.5. Set the lower warning limit 2 percent above the lower control limit. There are no upper limits.

B.6.3 Liquid Limit and Plasticity

- (1) Test the liquid limit and plasticity according to AASHTO T 89 and T 90.
- (2) Ensure the material conforms to the limits specified in standard spec table 301-2.

2984-07-75 22 of 58

B.7 Corrective Action

B.7.1 General

(1) Consider corrective action when the running average trends toward a warning limit. Take corrective action if an individual test exceeds the contract specification limit. Document all corrective actions both in the project records and on the appropriate control chart.

B.7.2 Placement Corrective Action

- (1) Do not blend additional material on the roadbed to correct gradation problems.
- (2) Notify the engineer whenever the running average exceeds a warning limit. When two consecutive running averages exceed a warning limit, the engineer and contractor will discuss appropriate corrective action. Perform the engineer's recommended corrective action and increase the testing frequency as follows:
 - 1. For gradation, increase the QC testing frequency to at least one randomly sampled test per 1000 tons placed.
 - 2. For fracture, increase the QC testing frequency to at least one test per gradation test
- (3) If corrective action improves the property in question such that the running average after 4 additional tests is within the warning limits, the contractor may return to the testing frequency specified in B.5.3. If corrective action does not improve the property in question such that the running average after 4 additional individual tests is still in the warning band, repeat the steps outlined above starting with engineer notification.
- (4) If the running average exceeds a control limit, material starting from the first running average exceeding the control limit and ending at the first subsequent running average inside the control limit is nonconforming and subject to pay reduction.
- (5) For individual test results significantly outside the control limits, notify the engineer, stop placing base, and suspend other activities that may affect the area in question. The engineer and contractor will jointly review data, data reduction, and data analysis; evaluate sampling and testing procedures; and perform additional testing as required to determine the extent of potentially unacceptable material. The engineer may direct the contractor to remove and replace that material. Individual test results are significantly outside the control limits if meeting one or more of the following criteria:
 - 1. A gradation control limit for the No. 200 sieve is exceeded by more than 3.0 percent.
 - 2. A gradation control limit for any sieve, except the No. 200, is exceeded by more than 5.0 percent.
 - 3. The fracture control limit is exceeded by more than 10.0 percent.

2984-07-75 23 of 58

B.8 Department Testing

B.8.1 General

(1) The department will conduct verification testing to validate the quality of the product and independent assurance testing to evaluate the sampling and testing. The department will provide the contractor with a listing of names and telephone numbers of all QV and IA personnel for the project, and provide test results to the contractor within two business days after the department obtains the sample.

B.8.2 Verification Testing

B.8.2.1 General

- (1) The department will have an HTCP technician, or ACT working under a certified technician, perform QV sampling and testing. Department verification testing personnel must meet the same certification level requirements specified in B.2 for contractor testing personnel for each test result being verified. The department will notify the contractor before sampling so the contractor can observe QV sampling.
- (2) The department will conduct QV tests of each base aggregate size, source or classification, and type during placement conforming to the following:
 - 1. One non-random test on the first day of placement.
 - 2. At least one random test per 30,000 tons, or fraction of 30,000 tons, placed.
- (3) The department will sample randomly, at locations independent of the contractor's QC work, collecting one sample at each QV location. The department will collect QV samples after the material has been bladed, mixed, and shaped but before compacting; except, for 3-inch aggregates, the department will collect samples from the stockpile at load-out. The department will split each sample, test half for QV, and retain half.
- (4) The department will conduct QV tests in a separate laboratory and with separate equipment from the contractor's QC tests. The department will use the same methods specified for QC testing.
- (5) The department will assess QV results by comparing to the appropriate specification limits. If QV test results conform to the specification, the department will take no further action. If QV test results are nonconforming, add the QV to the QC test results as if it were an additional QC test.

B.8.3 Independent Assurance

(1) Independence assurance is unbiased testing the department performs to evaluate the department's QV and the contractor's QC sampling and testing including personnel qualifications, procedures, and equipment. The department will perform an IA review according to the department's independent assurance program. That review may include one or more of the following:

2984-07-75 24 of 58

- 1. Split sample testing.
- 2. Proficiency sample testing.
- 3. Witnessing sampling and testing.
- 4. Test equipment calibration checks.
- 5. Reviewing required worksheets and control charts.
- 6. Requesting that testing personnel perform additional sampling and testing.
- (2) If the department identifies a deficiency, and after further investigation confirms it, correct that deficiency. If the contractor does not correct or fails to cooperate in resolving identified deficiencies, the engineer may suspend placement until action is taken. Resolve disputes as specified in B.9.

B.9 Dispute Resolution

- (1) The engineer and contractor should make every effort to avoid conflict. If a dispute between some aspect of the contractor's and the engineer's testing program does occur, seek a solution mutually agreeable to the project personnel. The department and contractor may review the data, examine data reduction and analysis methods, evaluate sampling and testing procedures, and perform additional testing. Use ASTM E 178 to evaluate potential statistically outlying data.
- (2) Production test results, and results from other process control testing, may be considered when resolving a dispute.
- (3) If the project personnel cannot resolve a dispute, and the dispute affects payment or could result in incorporating non-conforming product, the department will use third party testing to resolve the dispute. The department's central office laboratory, or a mutually agreed on independent testing laboratory, will provide this testing. The engineer and contractor will abide by the results of the third party tests. The party in error will pay service charges incurred for testing by an independent laboratory. The department may use third party test results to evaluate the quality of questionable materials and determine the appropriate payment. The department may reject material or otherwise determine the final disposition of nonconforming material as specified in standard spec 106.5.

C (Vacant)

D (Vacant)

E Payment

(1) Costs for all sampling, testing, and documentation required under this special provision are incidental to this work. If the contractor fails to perform the work required under this special provision, the department may reduce the contractor's pay. The department will administer pay reduction under the non-performance of QMP administrative item.

2984-07-75 25 of 58

(2) For material represented by a running average exceeding a control limit, the department will reduce pay by 10 percent of the contract price for the affected Base Aggregate bid items listed in subsection A. The department will administer pay reduction under the Nonconforming QMP Base Aggregate Gradation or Nonconforming QMP Base Aggregate Fracture Administrative items. The department will determine the quantity of nonconforming material as specified in B.7.2. 301-010 (20151210)

20. Protection of Concrete.

Supplement standard spec 415.3.14 as follows:

Provide for a minimum of one concrete finisher to remain on the project site after final finishing of all concrete surfaces until such time as the concrete has hardened sufficiently to resist surface scarring caused by footprints, handprints, or any other type of imprint, malicious or otherwise. Finisher must actively and continuously patrol on foot the newly placed concrete and repair any damage to the surface that might be sustained as described above.

Include the cost for providing the finisher(s), the necessary equipment, and materials in the contract unit price for each concrete item.

21. Concrete Aggregates.

Add the following to standard spec 501.2.5.4.5(4) Size Requirements:

Course aggregate for Concrete Grade A must consist entirely of size No. 1 when used in curb, curb and gutter, driveways, sidewalks or steps.

22. Concrete Masonry Bridges.

Perform this work according to standard spec 502, except as otherwise provided in the plans or in these special provisions. The exterior face of the concrete slabs, walks, curbs, piers, abutments, and wingwalls shall receive a sack-rubbed surface finish.

Supplement standard spec 501.3.1.3 of the standard specification as follows:

The grade of concrete used in the superstructure shall be Grade A-FA or A-S. The chosen grade is to be used for all components of the superstructure.

23. Concrete Identification Stamping.

Stamp ends of all monolithic Portland cement concrete surfaces with a stamp bearing the contractor's name and the year of construction. Make all letters 2 inches in height.

2984-07-75 26 of 58

Include the cost of this work in the contract unit price for other Portland cement concrete items and no additional payment will be made.

24. Pier Construction.

Determine the method of construction, and observe the following conditions:

- 1. If a cofferdam is used, build the cofferdam of non-erodable material.
- 2. Concrete poured under water will be allowed; pour the concrete according to standard spec 502.3.5.3. Ensure that the forms are tight to prevent leakage of concrete into the stream. Treat all displaced water by filtration, settling basin, or other means sufficient to reduce the cement content before discharging the water into the stream.
- 3. Excavated material from the stream may be utilized in the fill slopes so long as it is covered with other suitable material to prevent it from eroding back into the stream.

502-010 (20050502)

25. Bar Steel Reinforcement HS Stainless Structures, Item 505.0800.S.

A Description

This special provision describes furnishing and placing stainless steel reinforcing bars.

Conform to standard spec 505 as modified in this special provision.

B Materials

B.1 General

Furnish stainless steel reinforcing bars conforming to ASTM A955 and to one of the following Unified Numbering System (UNS) designations: S31653, S31803, S32205, or S32304. Supply grade 60 bars, all of the same UNS designation. Conform to the chemical composition specified for the given UNS designation in ASTM A276 table 1.

Supply bars that are free of dirt, mill scale, oil, and debris by pickling to a bright or uniform light finish. The department may reject bars displaying rust/oxidation, questionable blemishes, or lack of a bright or uniform pickled surface.

Furnish chairs or continuous supports made of stainless steel or recycled plastic to support high-strength stainless bar steel reinforcement subject to the plastic chair restriction stated in standard spec 505.3.4(1).

Furnish tie wire made from one of the UNS alloys allowed for bar steel or from an engineer-approved plastic or nonmetallic material. Ensure that stainless steel tie wire is dead soft annealed.

2984-07-75 27 of 58

B.2 Fabrication

Before fabrication, supply test results from an independent testing agency certifying that the reinforcement meets the requirements of Annex A1 of ASTM A955.

Bend bars conforming to standard spec 505.3.2 and according to ASTM A955. Bend and cut bars using equipment thoroughly cleaned or otherwise modified to prevent contamination from carbon steel or other contaminants. Use tools dedicated solely to working with stainless steel.

B.3 Control of Material

Identify reinforcement bars delivered to the project site with tags bearing the identification symbols used in the plans. Include the UNS designation, heat treat condition, heat number, grade corresponding to minimum yield strength level, and sufficient documentation to track each bar bundle to a mill test report.

Provide samples for department testing and acceptance according to CMM 8-50 Exhibit 1 requirements for concrete masonry reinforcement for uncoated bar steel.

Provide mill test reports for the project that do the following:

- 1. Verify that sampling and testing procedures and test results conform to ASTM A955, ASTM A276 table 1, and these contract requirements.
- 2. Include a chemical analysis with the UNS designation, heat lot identification, and the source of the metal.
- 3. Include tensile strength, yield strength, and elongation tests results conforming to ASTM A955 for each size furnished.
- 4. Certify that the bars have been pickled to a bright or uniform light finish.

C Construction

C.1 General

Ship, handle, store, and place the stainless steel reinforcing as follows:

- 1. Separate from regular reinforcement during shipping. Pad points of contact with steel chains or banding, or secure with non-metallic straps.
- 2. Store on wooden cribbing separated from regular reinforcement. Cover with tarpaulins if stored outside.
- 3. Handle with non-metallic slings.
- 4. Do not flame cut or weld. Protect from contamination when cutting, grinding, or welding other steel products above or near the stainless steel during construction.
- 5. Place on plastic or stainless steel bar chairs. If placing stainless steel chairs on steel beams, use chairs with plastic-coated feet.
- 6. Tie with stainless steel wire or an engineer-approved plastic or nonmetallic material

2984-07-75 28 of 58

Do not tie stainless steel reinforcing bars to, or allow contact with, uncoated reinforcing bars or galvanized steel. Maintain at least 1-inch clearance between stainless steel bars or dowels and uncoated or galvanized steel. Where 1-inch clearance is not possible, sleeve bars with a continuous polyethylene or nylon tube at least 1/8-inch thick extending at least 1 inch in each direction and bind with nylon or polypropylene cable ties. Sleeves are not required between stainless steel bars and shear studs. Stainless steel bars can be in direct contact with undamaged epoxy-coated bars.

Cut flush with the top flange or remove uncoated fasteners, anchors, lifting loops, or other protrusions into a bridge deck before casting the deck on prestressed concrete beams.

C.2 Splices

Splice as the plans show.

If increasing or altering the number or type of bar splices the plans show, provide revised plan sheets to the engineer showing the reinforcement layout, type, length, and location of revised bar splices and revised bar lengths. Obtain engineer approval for the location of new lap splices or substitution of mechanical bar couplers before fabrication. Ensure that new lap splices are at least as long as those the plans show.

D Measurement

The department will measure Bar Steel Reinforcement HS Stainless Structures by the pound acceptably completed, computed from the nominal weights of corresponding sizes for carbon steel deformed bars in AASHTO M31 regardless of stainless steel alloy provided. The department will not measure extra material used if the contractor alters the reinforcement layout as allowed under C.2, extra material for splices or couplers the plans do not show, or the weight of devices used to support or fasten the steel in position.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER DESCRIPTION UNIT 505.0800.S Bar Steel Reinforcement HS Stainless Structures LB

Payment for Bar Steel Reinforcement HS Stainless Structures is full compensation for furnishing and placing stainless steel reinforcing bars, including supports.

26. Temporary Shoring B-40-0923, Item 511.1200.01.

Perform this work according to standard spec 511, except as otherwise provided in the plans or these special provisions.

The temporary channel of each stage shall be lined with plastic or other non-erodible material and weighted down with clean stone. The temporary channel must be capable of carrying a two-year storm event as shown in the plans. The temporary channel must also allow the passage of migrating fish and aquatic species. Fish that become stranded in

2984-07-75 29 of 58

dewatered areas or temporary channels shall be captured and returned to the active channel immediately. All methods shall be outline in the ECIP.

27. Railing Steel Type NY4 B-40-0923, Item 513.7084.01.

Perform this work according to standard spec 513, except as otherwise provided in the plans or these special provisions.

Paint finish color: Colors will be selected by the city from drawdowns submitted by the contractor. Tint the primer to match the finish coat; the two coats shall be compatible with each other. Provide three drawdowns of each of the following colors:

- Federal Standard 595B 14090 green, semi gloss finish
- Federal Standard 595B 14062 green, semi gloss finish
- Federal Standard 595B 14066 green, semi gloss finish

The City of Milwaukee will either approve of the colors, or request for three drawdowns of an additional color.

28. Wall Gabion, Item 532.0800.S.

A Description

This special provision describes furnishing materials and constructing a retaining wall as shown on the plans. The wall shall be soundly constructed of rectangular baskets made of polyvinyl chloride (PVC) coated and heavily galvanized steel wire mesh filled with rock as indicated on the plans.

B Materials

Provide wire mesh gabion baskets that are manufactured from welded wire mesh according to the requirements of ASTM A974 or from twisted/woven mesh according to the requirements of ASTM A975. The wire mesh gabion baskets shall have a mesh opening of not less than 9 square inches for gabions and not less than 4.5 square inches for mattresses, and shall meet the following requirements:

- 1. All wire mesh will be formed from wire having a minimum diameter of 0.105 inches for gabions and a minimum diameter of 0.086 inches for mattresses with fuse-bonded PVC coating and galvanizing that is according to the applicable requirements of ASTM A974 and ASTM A975.
- 2. Additionally coat all galvanized steel wire with gray polyvinyl chloride that shall resist destructive effects of immersion in acidic, salt or polluted water, and exposure to ultra-violet light and abrasion, when subjected to 20,000 hours of testing according to ASTM specification B-117-73.
- 3. All other aspects of the wire mesh and fastening systems, including the galvanizing and PVC coating, shall meet the pertinent requirements of ASTM A974 and A975.

2984-07-75 30 of 58

Provide lacing and stay wires for gabion diaphragms and for securing tops according to the wire specifications for the mesh, except the diameter shall not be less than 0.086 inch. Mechanical fasteners made of galvanized steel with zinc coating (as described above) or stainless steel and supplied by the gabion manufacturer may be used in lieu of the lacing wire, with the approval of the engineer.

Provide rock, which will be used inside of the gabions, that is hard durable gravel or stone and is free of organic matter, lumps of clay, shale or other deleterious substances. Provide rock that is graded in size between 4 inches and 8 inches.

C Construction

Tightly close mechanical fasteners and space the fasteners as recommended by the manufacturer, the spacing between fasteners shall not exceed 6 inches.

Securely fasten individual gabions to adjacent gabions along the top, bottom, and vertical edges, and fill and place stone inside of the gabions in such a manner that conforms to specifications and details shown in the plan. Carefully place the stone in layers and densely pack the stone into the gabions. Layers of stone shall be approximately 12 inches thick. Use internal connecting wires between each stone layer to stiffen the basket and to ensure rectangular basket configurations after filling. Use a minimum of two internal connecting wires per stone layer for each 3 linear feet of wall length. Uniformly overfill the top layer of stone in each basket 1 to 2 inches to compensate for future rock settlement; allow for proper closing of the lid and for providing an even surface that is uniform in appearance. After closing, securely attach the lid to the surrounding baskets.

Prior to beginning wall construction, the engineer shall inspect the compacted wall foundation soils to determine if the foundation is adequate for the intended loads. Any required foundation improvements will be paid for at the appropriate bid prices for the items. Place the wall units to the lines, elevations and batter shown in the plans. Place wall units in horizontal layers, unless otherwise specified in the plan. Stagger basket-to-basket end joints in relation to adjacent layer basket end joints. Maintain the design wall face batter as wall construction proceeds. Do not place subsequent layers of baskets until the backfill has been placed and compacted behind all lower basket layers. Use backfill that is specified in the plans.

Compact all backfill behind the wall as specified in standard spec 207.3.6. For all walls with a maximum height of over 6 feet, perform compaction testing on the backfill. The minimum frequency of testing will be 1 test per basket layer per 200 linear feet of wall, or portion thereof. Compact the backfill to 95 percent of its maximum density as determined by AASHTO T-99, Method C. Perform compaction testing of the wall backfill. When performing nuclear testing, use a nuclear gauge from the department's approved list, ensure that the operator is a HTCP certified Nuclear Density Technician I, and conform to CMM 8.15 for testing and gauge monitoring methods. The cost of compaction testing shall be considered incidental to the cost of the wall.

2984-07-75 31 of 58

Place geotextile fabric between the fill and gabion wall as shown on the plans.

D Measurement

The department will measure Wall Gabion for payment in volume by the cubic yard of wall, completed according to the contract and accepted, with no deductions made for pipe openings.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNIT532.0800.SWall GabionCY

Payment is full compensation for excavating and preparing the bed; disposing of unnecessary excavated material; providing backfill material, backfilling, compacting the backfill, and performing compaction testing of the backfill when required; furnishing, hauling, and placing the gabion baskets and rock; filling baskets with rock; and for furnishing, hauling, and placing geotextile fabric.

29. Traffic Control.

Supplement standard spec 643 with the following:

Permanently label each barricade, sign or other traffic control device with the name and telephone number for 24-hour emergency service, printed in letters at least ³/₄ inches in height.

During the life of this contract, provide 24 hour-a-day availability of equipment and forces to promptly restore barricades, lights, signs or other traffic control devices that are damaged or disturbed. In no case may any barricade, light, sign or other traffic control device be out of service for more than 2 hours. The cost to maintain and restore the above items is incidental to the bid item Traffic Control and no additional payment will be made therefore

Mask out all traffic control signs and have flags removed when not in use.

The traffic requirements are subject to change at the direction of the engineer in the event of an emergency.

Receive prior approval from the engineer for the location of egress or ingress for construction vehicles to prosecute the work.

Park or store equipment and materials only at work sites approved by the engineer. Do not disturb, remove, or obliterate any traffic control signs, advisory signs, shoulder delineators, or beam guard in place along the traveled roadways without the approval of the engineer.

2984-07-75 32 of 58

30. Construction Staking Structure Layout.

Supplement standard spec 650 with the following:

Stake each plan grade at the ends of the deck so that the form-setters and inspector can check the grade and alignment. The bidwell will be unable to reach the end of deck due to clearance of the lighting blisters, so strike off of the deck to the form at the appropriate plan grade will be necessary.

31. Conduit Rigid Nonmetallic Schedule 40 2-Inch, Item 652.0225, Conduit Rigid Nonmetallic Schedule 40 2 1/2-Inch, Item 652.0230 and Conduit Rigid Nonmetallic Schedule 40 4-Inch, Item 652.0240.

Perform this work according to standard spec 652 except as otherwise provided in the plans or hereinafter provided.

Furnish and install a total of four 2-inch diameter PVC conduits, 2 1/2-inch diameter PVC conduits and four 4-inch diameter PVC conduits. One 2-inch conduit will run from each junction box into the adjacent lighting blister. Two 2 ½-inch conduits will be installed in the east sidewalk and two 2 ½-inch conduits in the west sidewalk. The four 4-inch conduit package will be located inside the bridge deck 16'-10" LT of the centerline of N. 51st Boulevard. Install the conduits as shown in the plans, according to the pertinent requirements of standard spec 652, and as hereinafter provided. Installation will require integration with existing field conditions. Appropriate adjustment on conduit locations may be made if the field conditions are such that the pipes cannot be installed at the specified locations with approval by the engineer.

Furnish schedule 40 polyvinyl chloride (PVC) conduits. The City will accept the conduit on the basis of the manufacturer's Certificate of Compliance and field inspection by the engineer upon delivery to the project.

PVC conduit and all fittings shall conform to the requirements for Smooth-Wall Poly Vinyl Chloride (PVC) Conduit and Fittings for Underground Installation, ASTM Designation: F512 (latest edition).

Direct all material questions regarding the City conduits to the engineer.

- Placing of duct: Inspect all ducts before placing to see that the bores are clean and free from mud, sand, and detritus. Only use ducts with a smooth bore, free from burrs, and rough projections. Smooth off burrs or other rough areas found in the duct that is likely to damage cable. Smooth them off by rasping or scraping.
- Install a standard expansion coupling on all ducts at all locations as indicated on the plans.
- Place end caps on all ducts terminating outside of the bridge and tape caps in place.
- A 3/8-inch nylon pull rope is to be installed in each pipe.

2984-07-75 33 of 58

- All TE and ES conduits are to be extended beyond the bridge by three feet. If the conduit terminated under a sidewalk area there is to be an indication stamped into the curb at the end of the pipe. There is to be a box out of a 3-feet by 5-feet centered over the pipe ending, with the long dimension running parallel with the curb

Inspection: Contact George Berdine, (414) 708-4245 cell / (414) 286-5943 office, Thomas Hughes (414) 708-3175 cell / (414) 286-3457 office, or Dennis Miller at (414) 708-4251 cell / (414) 286-5942 office. If neither Mr. Berdine nor Mr. Miller is available, then the contractor shall contact the dispatcher at (414) 286-5944.

Plan changes must be approved by the City of Milwaukee's electrical services supervisor. The primary contact is Mr. Dennis Miller, Street Lighting Operations Supervisor, (414) 286-5942 office, (414) 708-4251 mobile.

Provide two sets of red lined as-built plans to the City of Milwaukee electric services supervisor upon completion of conduit installation. The plan sets are incidental to the conduit installation, and no extra payment will be made by the city.

32. Anchor Assemblies Light Poles on Structures, Item 657.6005.S.

A Description

This special provision describes furnishing and installing anchor bolt assemblies for light poles as shown on the plans, and as hereinafter provided.

B Materials

Furnish anchors of the size and spacing as given on the plans, and that conform to ASTM A449 or AASHTO M314 GR 55. The upper 8 inches of the bolts, nuts, and washers shall be hot-dipped galvanized according to ASTM A153, Class C. Provide enlarged threads on nuts for proper fit after galvanizing.

C Construction

Provide two nuts and two washers per anchor bolt, and install per light standard manufacturer's recommendations.

D Measurement

The department will measure Anchor Assemblies Light Poles on Structures as a unit for each individual anchor bolt assembly, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER DESCRIPTION UNIT 657.6005.S Anchor Assemblies Light Poles on Structures Each

Payment is full compensation for furnishing and installing the anchorages. 657-060 (20100709)

2984-07-75 34 of 58

33. Seismograph, Item 999.1000.S.

A Description

This special provision describes furnishing a seismograph and employing trained operators to continuously monitor building vibration.

B Material

Use seismographs as specified in ILHR 7.63, and are continuous strip recorders supplied with all the accessories necessary for making seismographic observations.

C Construction

Monitoring procedures shall be as specified in ILHR 7.64 and the following: Take seismograph readings prior to construction activities to establish an ambient index.

Place the seismograph to continuously monitor all construction activities or as directed by the engineer. If construction activities generate ground vibration in excess of the Peak Particle Velocity Limits as shown in ILHR 7.64, stop the construction operation in progress and consider and implement alternate construction methods.

D Measurement

The department will measure Seismograph as a single complete lump sum unit of work, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNIT999.1000.SSeismographLS

Payment is full compensation for furnishing and operating a seismograph, an operator, and accessories.

999-005 (20150630)

34. Inlet Screen Type M, Item SPV.0060.01; Inlet Screen Type R, Item SPV.0060.02.

A Description

This special provision describes furnishing, installing, and maintaining proper inlet screens as directed by the engineer, as shown on the drawings, and as hereinafter provided.

2984-07-75 35 of 58

B Materials

Use woven filtration geotextile fabric with the following physical properties:

Test	Method	Value
Grab Tensile Strength	ASTM D-4632	180 min.
(lbs)		
Mullen Burst (lbs/in ²)	ASTM D-3786	200 min.
Equivalent Sieve Size	ASTM D-4751	US No. 30 max.
Water Flow Rate	ASTM D-4491	140 min.
(gpm/ft ²)		
Permitivity (Sec ⁻¹)	ASTM D-4491	1.9 min.
Permeability (cm/sec)	ASTM D-4491	0.14 min.

C Construction

C.1 Installation

The control of soil erosion requires flexibility to accommodate changing conditions as the construction project progresses. In general, install the erosion control device at locations as described on the plan.

At all inlet locations, install a Type M screen. If the inlet being protected has a side inlet box, seal the inlet box until inlet protection is no longer needed. These screens must be in place prior to the start of any work, including sawing.

On reconstruction projects, install Type M screens at all inlets and storm or combined sewer manholes. Install these screens, or some other device or method acceptable to the engineer, for preventing infiltration of solids into the sewer system, on the day that removal takes place. When it becomes necessary to remove a brick from a drainage structure in order to drain the subgrade filter screen, use approximately the size and shape of one-half of the Type R screen. Pay for the cost of providing this protection, as well as that required for storage piles of earth, gravel, stone, or other debris. Should the frame on the structure be removed or an opening occurs beneath the frame, install additional erosion control in the form of Type R as part of maintaining erosion control.

C.2 Maintenance

Continue cleaning and repair of all types of control devices until the engineer accepts the work. All such cleaning and repair, as well as the eventual removal of the devices, is the responsibility of the contractor.

Completely clean out manholes into which dirt or other debris has fallen before the end of each work day. Should the contractor not perform the cleaning as required, his operation may be shut down until the situation is corrected.

Protect all control measures protruding above the normal paved and/or ground surface where vehicular and/or pedestrian traffic is being maintained by barricades with flashing lights.

2984-07-75 36 of 58

Inspect the inlet basket within 24 hours after each rainfall or daily during extended periods of precipitation. Make repairs immediately, as necessary, to prevent particles from reaching the sewerage system and/or causing the surface flooding.

Remove sediment deposits after each storm event or as often as the fabric becomes clogged. Failure to maintain clean, debris free inlet baskets may result in the contractor's operations being shut down.

D Measurement

The department will measure Inlet Screens, Type M and Type R by each unit, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNITSPV.0060.01Inlet Screen Type MEachSPV.0060.02Inlet Screen Type REach

Payment is full compensation for supplying, installing and properly maintaining the devices. The inlet screens shall become the property of the contractor when no longer needed in the contract work.

35. Inlet Covers Type 57, Item SPV.0060.03; Manhole Covers Type 58A, Item SPV.0060.04.

A Description

This special provision describes furnishing and installing Inlet Covers Type 57 and Manhole Covers Type 58A.

Perform work under these items according to the requirements of standard spec 611 and the details as shown on the plans.

B Materials

Furnish materials conforming to the requirements of standard spec 611.

C Construction

Perform work according to the requirements of standard spec 611.

D Measurement

The department will measure Inlet Covers Type 57 and Manhole Covers Type 58A by each unit in place, furnished, installed, and acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

2984-07-75 37 of 58

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.03	Inlet Covers Type 57	EACH
SPV.0060.04	Manhole Covers Type 58A	EACH

Payment is full compensation for furnishing and installing the manhole covers, inlet covers and inlets.

36. Adjusting Water Boxes, Item SPV.0060.05.

A Description

This special provision describes adjusting, protecting and maintaining accessibility for the duration of the paving project, to all City of Milwaukee water service boxes and water valve boxes within the project limits.

B Materials

All material for the adjustment of these facilities must meet City of Milwaukee specifications and will be provided by the City of Milwaukee by contacting Jesse Hernandez, Milwaukee Water Works, at (414) 708-2670 (or Dave Goldapp, Milwaukee Water Works at (414) 286-6301).

If there is contractor damage, the materials must still be provided by the City of Milwaukee, however, in this case, the Contractor will be charged for all materials. Materials furnished by the City of Milwaukee and not used on the project shall be delivered back to DPW Field Headquarters – Infrastructure, Operations, Water Works at 3850 North 35th Street.

C Construction

The contractor shall contact Milwaukee Water Works prior to the start of construction. The City will locate, mark, inspect and repair all water service boxes and water valve boxes within the limits of the project prior to commencement of work on the project.

All water service boxes and water valve boxes within the project limits shall be adjusted to proposed elevations by the contractor using materials meeting city specifications.

Throughout the duration of the project, the contractor must ensure that all water service boxes and water valve boxes are adequately located and identified by blue paint, and that at all times, all water appurtenances remain accessible for operation by city forces. Exercise caution working adjacent to water facilities to avoid damage and ensure accessibility.

Upon completion of the contract, the city will inspect all water facilities to ensure the water boxes are clean, properly aligned, and accessible. The contractor shall be responsible to make identified repairs and adjustments, and if any repairs or adjustments are made by the city, the cost will be charged to the contractor.

2984-07-75 38 of 58

D Measurement

The department will measure Adjusting Water Boxes as each individual unit, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNITSPV.0060.05Adjusting Water BoxesEACH

Payment is full compensation for furnishing all excavation, backfilling, disposal of surplus materials, water box adjustments and clean-out, and restoration of the work site.

37. Installing Conduit Into Existing Manhole, Item SPV.0060.06.

A Description

This special provision describes locating existing conduit system manholes and installing new conduit into those manholes at the locations shown on the plans. The contractor shall verify existing conduit manhole locations with the City of Milwaukee, and shall maintain any existing conductors, fibers, and conduit paths without interruption or damage. Repair and restoration of all disturbed areas resulting from the work shall be according to the pertinent provisions of the standard specifications, and as hereinafter provided.

B Materials

Conduit, as provided and paid for under other items in this contract. All materials shall conform to the pertinent provisions of the standard specifications unless otherwise noted.

C Construction

Carefully expose the outside of the existing structure without disturbing any existing conduits or cabling.

Drill the appropriate sized hole in a concrete structure or saw and remove full sections of block or bricks from the existing structure for the entering of conduit at a location within the structure that will not disturb the existing cabling and will not hinder the installation of new cabling within the installed conduit. This work may include the removal of the existing abandoned conduit from the structure to allow for the installation of the new conduits as indicated on the plans.

Fill any void area between the drilled hole and conduit with an engineer-approved filling material to protect against conduit movement and entry of fill material into the structure.

Carefully tamp backfill into place. All disturbed areas shall be repaired and restored in kind.

D Measurement

The department will measure Installing Conduit Into Existing Manhole by each unit, acceptably installed. Up to six conduits entering a structure per entry point into the

2984-07-75 39 of 58

existing structure will be considered a single unit. Conduits in excess of six, or conduits entering at significantly different entry points into the existing manhole will constitute multiple units.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNITSPV.0060.06Installing Conduit Into Existing ManholeEACH

Payment is full compensation for drilling holes; removing blocks: removing bricks: removing abandoned conduit; furnishing and installing all materials, including bricks, and coarse aggregate; for excavation, bedding and backfilling, including any sand or other required materials; furnishing and placing topsoil, fertilizer, seed, and mulch in disturbed areas; for disposal of surplus materials; for making inspections.

38. Junction Boxes 18"x12"x8", Item SPV.0060.07.

A Description

Furnish and install 18" x 12" x 8" electrical boxes for use as pull boxes on 2 1/2-inch rigid nonmetallic schedule 40 conduit installations.

B Materials

Furnish junction boxes made by an approved cast iron manufacturer and having hot dipped galvanized coating. The covers and removable flanges shall be cast iron with a hot dipped galvanized coating and designed for sidewalk applications. The covers and flanges shall be interchangeable to permit replacement without disturbing the box or conduit system. Furnish covers with a cross checked pattern for pedestrian traffic and equipped with pry bar slots, neoprene gasket and recessed stainless steel cover screws.

Supply a stainless steel '4" x 18" grounding lug on all boxes on a side of box opposite the entering conduit.

Direct all materials questions to Mr. Dennis Kozelek at (414) 286-3252.

C Construction

Furnish and install all junction boxes. Provide 1-inch nonmetallic drains in the bottom of all junction boxes through the slab as shown on the plans. Cut junction box conduit and elbow holes in field.

D Measurement

The department will measure Junction Boxes 18" x 12" x 8" by each individual box, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

2984-07-75 40 of 58

ITEM NUMBER SPV.0060.07 DESCRIPTION
Junction Boxes 18" x 12" x 8"

UNIT EACH

Payment is full compensation for providing all materials, drains and fittings, including the junction box and cover, grounding lug and stainless steel mounting hardware; for properly disposing of surplus materials.

39. Bar Grate System, Item SPV.0060.08.

A Description

This special provision describes removing and disposing of the existing grates, providing and installing a new bar grate system as shown on the plans and as hereafter provided. Work in these items shall be according to sewer and water construction as described in the standard spec 2017 edition and the City of Milwaukee's Standard Special Provisions for Sewer Construction current edition and all subsequent addenda, and details as shown in the plans.

B Materials

Furnish a custom fabricated steel grate at the outlets of the four storm sewers as per the details in the plan. Paint the entire grate with white vinyl paint prior to installation. The painting shall meet the steel structures painting council's (SSPC) specifications SSPC-SP-10. The surface preparation shall meet SSPC-SP-11. Apply paint according to the most recent editions of the SSPC Volume I. Alternate coating systems shall consist of a coat of an epoxy organic zinc rich primer, a coat of high build epoxy, and urethane protective coat. These approved painting systems may be substituted for the vinyl paint system listed above.

Provide steel bars conforming to A29/A29M-15, and A123/A123M specifications covering individual steel pieces as well as assemblies of various classes of materials. It shall be the responsibility of the fabricator to ensure that proposed grate systems are properly built and processed before shipping to the project site for installation.

C Construction

The contractor shall ensure proper disposal of all accumulated debris and materials in environmental compliance with all federal, state, and local regulations.

The new bar grate system shall be completed as shown on the plan details. Steel castings shall conform to ASTM A27/A27M-13.

D Measurement

The department will measure Bar Grate System by each individual unit, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

2984-07-75 41 of 58

ITEM NUMBER DESCRIPTION UNIT SPV.0060.08 Bar Grate System EACH

Payment is full compensation for fabrication and furnishing all required materials, removal and disposal of the existing bar grates, and the removal and proper disposal of the existing grates and debris.

40. Concrete Collar, Item SPV.0060.09.

A Description

This special provision describes providing and installing concrete collars as shown on the plans and as hereafter provided.

B Materials

Furnish concrete masonry and material that is according to standard spec 501 and 611.

C Construction

Build a concrete collar at each storm sewer connection point where pipe diameters change in size as shown on the plans.

Cut and remove only the minimum amount of wall necessary around the existing junction chamber wall to make a new connection. Do not damage the existing junction chamber while making a connection.

D Measurement

The department will measure Concrete Collar by each individual unit, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNITSPV.0060.09Concrete CollarEACH

Payment is full compensation for furnishing, hauling, and placing of materials; for excavation, backfilling, and properly disposing of excess materials.

41. Adjusting TES Manhole Cover, Item SPV.0060.10.

A Description

This special provision describes adjusting the existing chimney of the block, precast, or brick round manholes; furnishing, installing and removing protection of the cables in the manhole during adjustment operations. Perform work according to the standard specifications, the provisions of the article Adjusting Manhole Covers, as shown on the plans, and as hereinafter specified.

2984-07-75 42 of 58

B Material

Furnish and install materials that conform to the requirements of standard spec 519. Salvage and reinstall existing covers on the manholes. The city will supply covers designated for replacement. Contractor shall contact Ricardo Lopez, Inventory Clerk at (414) 286-6123 prior to obtaining the frames and lids from the DPW Field Headquarters at 3850 N. 35th St. Contractor must have the "Castings Requisitions Form" which shall be supplied by the City at the Preconstruction Meeting to obtain the covers.

C Construction

Report any pre-existing problems to Ms. Karen Rogney of City Underground Conduits Section at (414) 286-3243 three working days in advance of any construction on manholes.

Before removing the pavement around the manhole, the contractor shall place a ¾-inch plywood cover or equal over existing active Street Lighting, Traffic Control, Communication or private vendor electrical cables. This cover shall be properly supported to/at the manhole floor.

Break out and remove pavement around manhole. Remove existing covers and store and secure them properly. Any damaged, lost, or stolen covers shall be the responsibility of the contractor and shall be replaced at contractor's expense.

Remove existing chimney to surface of concrete roof slab. If manhole does not have an existing concrete roof slab, remove sufficient chimney as to provide adequate corbel to fit new cast iron frame and cover.

Adjust manhole cover to proposed grade using bricks or concrete rings as necessary. Completely underpin entire flange area of manhole frame with mortar, bricks and/or concrete rings. Remove wedges/shims. Fill voids with grout. Do not back plaster inside walls.

After completion of paving, remove the temporary ³/₄-inch plywood cover or equal which is over the existing electrical cables in the manhole as mentioned above.

Notify Ms. Rogney three working days in advance of completion of each manhole adjustment, for inspection and acceptance of work performed. The contractor will receive no payment until the above work is approved by City Underground Conduits.

D Measurement

The department will measure Adjusting TES Manhole Cover by each unit, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNITSPV.0060.10Adjusting TES Manhole CoverEACH

2984-07-75 43 of 58

Payment is full compensation for furnishing all required materials, exclusive of frames, grates, or lids available and designated for adjusting; for removing, reinstalling and adjusting the covers. Covers to be adjusted and which are rendered unfit for use by the contractor through the contractor's operations will be replaced by the contractor in kind at the contractor's own cost and expense.

42. Construction Staking Curb Ramp, Item SPV.0060.11.

A Description

Perform this work according to the applicable provisions of standard spec 650.

B (Vacant)

C Construction

Set and maintain construction stakes or marks as necessary to achieve the required accuracy and to support the method of operations. Set additional construction stakes as necessary to establish location and grade of the curb map including points of change in alignment grade. Locate stakes to within 0.02 feet horizontally and establish the grade elevation to within 0.01 feet vertically.

D Measurement

The department will measure Construction Staking Curb Ramp as each individual curb ramp, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNITSPV.0060.11Construction Staking Curb RampEACH

Payment is full compensation for locating and setting all construction stakes; and for relocating and resetting damaged or missing construction stakes.

43. 4-Duct Conduit, Cement Encased, 4-inch Rigid Nonmetallic Conduit DB-60, Item SPV.0090.01.

A Description

This work consists of furnishing and installing cement encased multiple duct conduit packages below grade as shown on the plans and as hereinafter described.

B Materials

B.1 Conduit

Furnish and install DB-60 polyvinyl chloride (PVC) conduit. Conduit will be accepted on the basis of a Manufacturer's Certificate of Compliance and WISDOT field inspection upon delivery to a project.

2984-07-75 44 of 58

PVC conduit and fittings shall conform to the requirements of Standard Specifications for Smooth-Wall Poly (Vinyl Chloride) (PVC) Conduit and Fittings for Underground Installation, ASTM Designation: F512 (latest edition).

B.2 Conduit Spacers

Furnish and install nonmetallic interlocking base spacers and intermediate spacers that provide a 1" vertical and 1" horizontal separation between PVC pipes. The base spacers shall proved a 3" vertical separation from the trench bed to the bottom of the PVC pipes.

B.3 Conduit Bed

Furnish and install a minimum 2" conduit bed of stone chips or crushed stone screenings conforming to the following:

3/8 Inch Crus	hed Stone Chips
Q: Q:	0/ D: 1 W/-:-1-4

Sieve Sizes	% Passing by Weight
1/2"	100
3/8"	90-100
No. 8	0-15
No. 30	0-3

Crushed Stone Screenings

Sieve Sizes	% Passing by Weight
1/2"	100
No. 4	75-100
No. 100	10-25

B.4 Concrete

The type of concrete mix to be used to encase the ducts will be:

Type I Cement	280 lbs
Fly Ash	100 lbs
Sharp Torpedo Sand	3100 lbs
Water	35 gals
Chryso Air 260 or approved equal	2.0 ozs
Chryso Plast 209 or approved equal	7.0 ozs
Air	5%

Mix the materials to provide an approximate 3 inch slump

2984-07-75 45 of 58

B.5 Slurry Backfill

Aggregate slurry backfill consists of No. 1 concrete aggregate Class 'C' concrete mix with the cement deleted.

Fly Ash (Class C)	75 lbs.
Concrete Sand (Damp)	1830 lbs.
No. 1 Concrete Aggregate	1830 lbs.

Mix the materials with water to inundate the aggregate sufficiently to provide an approximate 3 inch slump. Deposit the mix in the trench directly from a concrete transit mix truck.

B.6 Pull Rope

Pull rope specifications will be:

- Flat construction (7/16" to 5/8" wide)
- 100% woven aramid fiber (may include tracer wire)
- 1500 lbs. Minimum pull strength prelubricated
- Sequential footage markings for location

For any questions on materials, contact Ms. Karen Rogney at (414) 286-3243.

C Construction

C.1 Excavation

The excavation shall have the minimum or maximum dimensions shown on the plans and as follows:

Number of	Minimum	Maximum
Ducts Wide	(Inches)	(Inches)
1	8 1/2	11
2	14 1/8	16 5/8
3	19 3/4	22 1/4
4	25 3/8	27 7/8
5	31	33 1/2
6	36 5/8	39 1/8
7	42 1/4	44 3/4
8	47 7/8	50 3/8

These minimum and maximum trench widths apply to standard 4 inch PVC electrical duct only. When required, the excavation may be widened for the handling and placing of materials.

Sheath and brace open-cut trenches as required by code and as necessary to maintain safety. The cost of furnishing, placing and removing of sheathing and bracing shall be included in the unit bid for the work.

2984-07-75 46 of 58

The dimensions of the excavation will be governed by the number, configuration and the grade (cover) to which the conduit is to be installed as shown on the plan. The walls of the excavation shall be clean and true

Prior to excavating trenches, expose the existing manhole and conduit lines. The object of this is to permit adjustments in line and grade to avoid special construction methods. Protect the exposed manhole and conduit from damage.

Lay the conduit at a depth so that sufficient protection from damage is provided. Allowable covers shall be as follows:

The standard cover for mainline conduit is 39 inches and the minimum cover acceptable is 28 inches.

Maintain the standard cover wherever possible and any deviation less than the minimum cover requires the approval of the engineer.

Grade the trench to have a minimum pitch of 3 inches per 100 feet. When an obstruction is encountered in the trench and it is necessary to excavate a deeper trench than would otherwise be required, in order to obtain drainage, refer the matter to the engineer to determine whether the extra excavation should be made.

In grading a trench for mainline conduit, there are three general practices for direction of pitch.

- (a) When grading a trench in a street with a level grade, the high point of the trench bottom should ordinarily be centered between manholes and pitched downward equally toward each manhole.
- (b) Where the street slopes in one direction, locate the high point of the trench bottom approximately 30 feet from the end wall of the higher manhole and grade toward both manholes.
- (c) Where a steep grade is encountered, grade the trench at the minimum pitch from the end wall of the higher manhole to a point 20 feet plus or minus toward the lower manhole. From this point, follow the street grade at the standard cover to a point 20 feet plus or minimum away from the end wall of the lower manhole. From this point, the remainder of the section shall be laid at the normal pitch.

After the rough excavation is completed, prepare the bottom of the trench to receive the conduit. Bring the duct bed to the final grade by grading uniformly from the high point to the low or drainage points. Use stone chips or crushed stone screenings to grade the trench. The duct bed shall be a minimum of 2" in depth.

2984-07-75 47 of 58

C.2 Placing of Duct

Proceed with placing the ducts as soon as the duct bed has been completed. Inspect all ducts before placing to see that the bores are clean and free from mud, sand, etc. Use only ducts with a smooth bore, free from burrs, rough projections etc. Smooth off burrs or other rough areas likely to damage cable are found in the duct by rasping or scraping.

Place the duct on base spacers with the ends staggered so no two couplings are adjacent. This may be accomplished by the use of the short lengths in stock or cutting back full length sections to the desired lengths. If cut pieces are used, place the cut end at the manhole. Locate the base spacers within 2 feet of the end of each duct and one base spacer located in the middle of the duct.

Use full length pieces for the balance of the conduit line.

Formations of two ducts or more in height are to be carried forward in full formation, that is, as each tier of 20 foot lengths is laid, the next higher tier of ducts shall then be placed on the intermediate spacers. Place these intermediate spacers on top of the base spacers located within two feet from each duct end and one in the middle of each duct. Place the intermediate spacers and ducts for the remaining tiers. Glue each length into the adjoining coupling. A twist and push on the duct being placed will suffice for a water tight joint. Exercise caution in the driving operation, so that neither the coupling nor the duct will be split or damaged in any way. After the full formation has been completed, place wood trench and duct bracing on the ducts to prevent shifting or floating while the concrete envelope is being placed and during driving operation.

This procedure shall be followed with succeeding lengths, providing spacers at the proper intervals, until sufficient trench footage of completed formation has been placed and is ready to receive concrete encasement.

The terminating point for mainline conduit will be the inside manhole wall. Install a standard end bell fitting flush with the wall on all duct access points.

Install a #10 copper tracer wire along and above the centerline of the duct for encasement in the concrete. The wire shall be 4 feet longer than the run of conduit and be at least 2 feet long at each access point.

Install a pull rope in each run of conduit, as laid. The rope shall be 4 feet longer than the run of conduit and shall be doubled back at least 2 feet at each raceway access point. Anchor the pull rope at each access point in a manner acceptable to the engineer.

C.3 Concreting

Begin concreting after sufficient conduit has been laid and the trench and duct have been inspected. The minimum concrete encasement of the ducts is 3 inches on the top, 2 inches on the sides, and 3 inches on the bottom. After placing, puddle the concrete with a splicing bar or similar tool so that complete duct encasement is accomplished. Remove wood

2984-07-75 48 of 58

braces used to keep the conduit from floating before the concrete sets completely and the resultant encasement voids filled with concrete.

Allow the concrete encasement to set for a minimum of 6 hours before backfilling is commenced.

C.4 Slurry Backfill

Slurry Backfill. Commence backfilling of the conduit immediately after the duct has been inspected, approved and has set to withstand the load.

An aggregate slurry as specified shall be used to backfill the concrete encased conduit. The trench shall be backfilled to the proposed or existing subgrade. The mix shall be deposited in the trench directly from a concrete transit mix truck.

D Measurement

The department will measure 4-Duct Cement Encased, 4-Inch Rigid Non-Metallic Conduit DB-60, furnished and installed at the locations on the plans, by the linear foot, acceptably installed. The measured quantity will equal the linear feet of encased duct, based on the distance along the centerline of duct between ends of conduit. City of Milwaukee shall have final acceptance.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER DESCRIPTION UNIT SPV.0090.01 4-Duct Conduit Cement Encased 4-Inch Rigid LF

Nonmetallic Conduit DB-60

Payment is full compensation for furnishing the conduit, conduit bodies, conduit fittings, conduit spacers, end caps and trace wire; for excavating, bedding, encasement and backfilling including any concrete, stone, aggregate slurry, bracing, or other related materials; for disposing of surplus materials; and for making inspections, for installing the conduit.

44. Construction Staking Concrete Sidewalk, Item SPV.0090.02.

A Description

This special provision describes furnishing and setting construction stakes or control points, including all calculations required, necessary to establish the horizontal and vertical position of the concrete sidewalk as shown on the plans.

B (Vacant)

C Construction

Obtain or calculate benchmark data, grades, and alignment from data in the plan and verify with the engineer prior to beginning the work. The engineer will furnish horizontal

2984-07-75 49 of 58

alignment, horizontal alignment ties and control point data. This work shall include reestablishing the plan horizontal roadway alignment, alignment ties, and control points.

Obtain approval from the engineer prior to beginning the work for methods of survey and prior to beginning the work. The degree of accuracy used in the survey work shall be consistent with third order, class II. Establish additional benchmarks and control points as necessary or as directed by the engineer. Check plan dimensions, alignment, and elevations for accuracy with existing field conditions. Immediately call to the engineer's attention any errors and apparent discrepancies for correction or interpretation prior to proceeding with the work.

Maintain neat, orderly and complete survey notes and computations used in establishing the lines and grades. Make the survey notes and computations available to the engineer within 24 hours upon request as the work progresses.

Place construction stakes for concrete sidewalk at intervals of 25 feet. A minimum of three stakes per cross section is required. Set and maintain as necessary additional stakes per cross section to achieve the required accuracy and to satisfy the contractors' method of operations. Set additional stakes as necessary to establish location and grade along intersecting road radii, vertical curves, horizontal curves, and curve transitions. Locate all construction stakes to within 0.25 ft. of the true horizontal position and establish the grade elevation to within 0.01 ft. of the true vertical position.

D Measurement

The department will measure Construction Staking, Concrete Sidewalk by the linear foot along each roadway centerline or reference line. When sidewalk occurs on both sides of the roadway, the quantity of Construction Staking, Concrete Sidewalk, will be measured by the linear foot along the centerline or reference line of each side of the roadway.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER DESCRIPTION UNIT SPV.0090.02 Construction Staking Concrete Sidewalk LF

Payment is full compensation for furnishing all survey work necessary to locate and set all concrete sidewalk construction stakes including additional stakes per cross section set to achieve the required accuracy and to satisfy the contractors' method of operations including intersecting road radii, auxiliary lanes, vertical curves, horizontal curves, and curve transitions; for resetting damaged or missing concrete sidewalk construction stakes; and for furnishing all stakes, lath, flags, equipment and incidentals necessary to complete the work for staking concrete sidewalk.

2984-07-75 50 of 58

45. Temporary Routing of Storm Sewers, Item SPV.0105.01.

A Description

Design and provide temporary pumps, pipes, grates, dikes, curbwalls, ditches, sumps, other means, and all other materials necessary to divert all water at outfalls in staged work areas to the staged waterway in addition to providing and designing the temporary shoring. The cost of design, furnishing, installing, maintaining, and removing temporary water control system is incidental to this bid item.

All required drainage, pumping, treatment, and disposal shall be done without damage to the adjacent property or structures and without interference with the operations of other contractors, or the rights of public and private owners, or pedestrian and vehicular traffic.

The contractor at the engineer's discretion shall modify the water control system at his own expense if, after installation and while in operation, it causes or threatens to cause damage to adjacent property.

All stormwater discharge to storm sewers, watercourses, and wetlands shall conform to the requirements of local, state, and Federal regulations.

B Materials

In addition to shoring design for diverting the river during each stage of substructure and slope protection construction, submit to the department for approval the water control plans at least 30 days prior to installation of water control systems.

Use water control methods that are appropriate, as determined by the contractor and engineer, to permit construction and accommodate all existing and proposed ground conditions, construction operations, and requirements of these plans and specifications.

Water control plan as a minimum shall include:

- Descriptions of proposed surface water control facilities including, but not limited to, equipment; methods; installation, standby equipment and power supply, pollution control facilities; discharge locations; removal of water control systems as required by this section.
- The contractor shall submit shop drawings showing locations, dimensions, and relationship of elements of each system. The submittal shall include design calculations demonstrating adequacy of proposed water control or isolation systems and their components. The contractor shall provide manufacturer's literature describing installation, operation, and maintenance procedures for all components of water control system for transporting water from the outfalls of work zone to the temporary channel of the diverted waterway.

If system is modified during installation or operation, revise or amend and resubmit water control plan.

2984-07-75 51 of 58

C Construction

These outfalls run full during rainfall events, and receives a small amount of surface flow from nearby street drains.

Perform work according to the Standard Specifications for Sewer and Water Construction in Wisconsin 2017 edition. Coordinate all sewer work and staging with the bridge construction and waterway staging.

Provide temporary water control measures during working and non-working hours to keep the outfall storm sewers in service. If necessary, install a temporary cofferdam for construction work at the piers and steel sheet piling (temporary shoring) for waterway staging. Installation, use and dewatering operations shall follow all applicable requirements of the Wisconsin DNR Technical Standards.

Remove temporary facilities no longer needed unless the engineer allows it to remain in place.

D Measurement

The department will measure Temporary Routing of Storm Sewers, completed according to the contract and accepted, as a single complete lump sum unit of work.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNITSPV.0105.01Temporary Routing of Storm SewersLS

Payment is full compensation for design of a water control plan, furnishing and installing all materials for implementation of the approved water control plan, maintenance during operation, modifications during usage, dewatering of the construction zone.

46. Removing Vegetated Revetment Mattress Slope Protection, Item SPV.0180.01.

A Description

This special provision describes removal, salvage, grading and reinstallation of existing revetment mattress slope protection upstream and downstream of the bridge as shown in contour plans.

B Materials

Salvage and securely store as much existing material as possible to complete the re-grading necessary to provide a smooth transition to the new vegetated revetment mattress slope protection under the new bridge. Any damaged or lost materials must be provided by the contactor to replace in kind.

2984-07-75 52 of 58

Contractor shall thoroughly inspect all removed materials for reuse, and inventory all material salvaged with the inspector for re-installation. Materials damaged by the contractor during removal or lost prior to re-installation shall be furnished at the contractor's sole expense. Conform to requirements of the plans and SPV.0180.02 for materials deemed by the engineer and inspector as unsalvageable to replace. Cost incurred for replacing unsalvageable material will be paid under bid item 'Vegetated Revetment Mattress Slope Protection'.

C Construction

Follow the requirements of bid items 'Vegetated Revetment Mattress Slope Protection', Item SPV.0180.02 and 'Temporary Routing of Storm Sewers' Item SPV.0105.01 for grading within the limits as shown in the plans.

D Measurement

The department will measure Removing Vegetated Revetment Mattress Slope Protection by the square yard, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBERDESCRIPTIONUNITSPV.0180.01Removing Vegetated Revetment MattressSY

Slope Protection

Payment is full compensation for removing, salvaging, storing, performing inventory, grading, for properly disposing of surplus materials, for reinstalling.

47. Vegetated Revetment Mattress Slope Protection, Item SPV.0180.02; Grouted Revetment Mattress Slope Protection, Item SPV.0180.03.

A Description

This special provision describes furnishing and installing vegetated revetment mattress slope protection and grouted revetment mattress slope protection for the Lincoln Creek and storm sewer outfalls as shown on the plans, and as hereinafter provided.

B Materials

B.1 Backfill

Granular backfill shall be used in areas of voids below the required area of the revetment mattress, and be part of bid item 210.2100 'Backfill Structure Type B'.

B.2 Filter Fabric

Filter fabric shall generally conform to standard spec 645 for Type DF (Drainage Filtration) Schedule C Geotextile Fabric.

2984-07-75 53 of 58

Wood stakes, as shown in the plans, shall be used to anchor filter fabric. Stakes shall be a minimum of 14 inches long and shall have a top (head) dimension of at least 1.5 inches on one axis (thickness) and 3 inches on the second axis (width). Stakes shall be constructed by rip-cutting nominally dimensioned 2"x4" common lumber diagonally from top to bottom to the proper dimensions. Wood stakes shall not be treated with preservative.

B.3 Stone Fill

Stone for watercourse construction shall be used as fill. All stone shall be clean, hard, and durable quarry stone or natural stone with less than 35 percent wear when tested for resistance to abrasion in conformance to ASTM C535. Bulk density shall not be less than 160 pounds per dry cubic foot. Size of stone shall range from 3-5 inches.

B.4 Topsoil

Imported topsoil must be used in lieu of native topsoil due to the presence of contamination. Imported topsoil shall meet the following mechanical criteria: 100 percent shall pass the 1-inch screen; 97-100 percent shall pass the 1.5-inch screen; and 40-60 percent shall pass the No. 100 mesh sieve. Topsoil must be suitable sandy loam from an approved source, which possesses friability and a high degree of fertility. It shall be free of clods, roots, gravel, and other inert material. It shall be free of quackgrass, cattail, buckthorn, thistle, garlic mustard, reed canary grass and other noxious vegetation and seed. Should such regenerative material be present in the soil, the contractor shall remove, at his expense and in a manner satisfactory to the engineer, all such growth, both surface and root, which may appear in the imported topsoil.

B.5 Seed MixSeed mix used on vegetated revetment mattresses shall conform to the following table:

Vegetated Revetment Mattress Seed Mix		
Latin Name	Common Name	Rate/Acre
Elymus Canadensis	Canada Wild Rye	3 oz
Sporobolus heterolepis	Prairie Dropseed	1 lb
Schizachrium scoparium	Little Bluestem	2 lbs
Ratibidia pinnata	Yellow Coneflower	3 oz
Penstemon digitalis	Smooth Penstemon	2oz
Cover Crop		
Elymus virginiana	Virginia Wild Rye	3 lbs
Panicum virgatum	Switchgrass	3 lbs

Seed shall be clean, delivered in original, unopened packages, and bearing an analysis of the contents, guaranteed pure and conform to all State of Wisconsin and Federal laws. All seed is to be from genotypes within 300 miles of the project site.

Seed mixes shall be healthy and vigorous and free of noxious weed seeds. Seed that is wet, moldy, or otherwise damaged or does not meet the Specifications will not be acceptable and shall be removed from the job, as directed by the engineer and at no cost to the Owner.

2984-07-75 54 of 58

B.6 Erosion Fabric

Heavy grade erosion control fabric shall be used as a component of the Vegetated Revetment mattress. The fabric will be non-woven coir with polypropylene netting. Generally, this fabric will allow temporary stabilization of exposed areas not subject to the watercourse and sufficient vegetative cover will be established within one growing season.

The minimum permissible properties shall be:

Property	ASTM Designation	Result
Mass Per Unit Area	ASTM D-3776	8 oz/sy
Thickness	ASTM D-1777	.25 in
Tensile Strength (dry)	ASTM D-4595	230 x 138 lb/ft
Permissible Shear Stress		3 lb/sf

Erosion Control Fabric – Heavy Grade shall be North American Green C125 BN or BonTerra CS2 or engineer approved equivalent.

B.7 Wire Mesh

Revetment mattress basket units shall be of non-raveling construction. All wire mesh shall be manufactured and installed in strict compliance with ASTM Designation A974 and A975— Standard Specifications for Double-Twisted Hexagonal Mesh Gabions and Revetment Mattresses; Metallic- coated steel wire with PVC coating Classification Style-3. The wire mesh shall have a mesh opening of not less than 3.5 square inches and shall meet the following requirements:

- 1. All wire mesh will be formed from wire having a minimum diameter of 0.086 inches for mattresses with fuse-bonded PVC coating and galvanizing that is according to the applicable requirements of ASTM A974 and ASTM A975.
- 2. Additionally coat all galvanized steel wire with gray polyvinyl chloride that shall resist destructive effects of immersion in acidic, salt or polluted water, and exposure to ultra-violet light and abrasion, when subjected to 20,000 hours of testing according to ASTM specification B-117-73.
- 3. All other aspects of the wire mesh and fastening systems, including the galvanizing and PVC coating, shall meet the pertinent requirements of ASTM A974 and A975.

Provide lacing and stay wires for securing tops according to the wire specifications for the mesh, the diameter shall not be less than 0.086 inch. Mechanical fasteners made of galvanized steel with zinc coating (as described above) or stainless steel and supplied by the manufacturer may be used in lieu of the lacing wire, with the approval of the engineer.

B.8 Grout

Furnish an air-entrained mortar or concrete to fill the voids between revetment stones in grouted revetment mattress. Conform to the physical requirements for component materials as specified in standard spec 501.2 except furnish fine aggregate or a combination of fine and coarse aggregate with a gradation that results in a grout with a consistency that allows complete filling of the voids.

2984-07-75 55 of 58

Certify that the grout conforms to the following mixture requirements:

- Contains 470 pounds or more of portland cement per cubic yard of grout. The contractor may substitute class C fly ash for up to 30% of the required portland cement
- Contains only enough water to achieve a 3-inch slump. Any additional workability required to completely fill the revetment voids must be achieved with admixture without increasing the w/cm ratio.
- Contains 9% or more air for mixes with a nominal top size aggregate less than 3/8 inch or 7% or more air for a mix with 3/8 inch or larger aggregate.

C Construction

C.1 Backfill

Place backfill in areas of voids below the required area of the revetment mattress in maximum 6-inch lifts and compact each lift to 95 percent of relative density as determined by ASTM D 2049. Any required foundation improvements will be paid for at the appropriate bid prices for the items.

C.2 Filter Fabric

Place filter fabric throughout extent of required revetment mattress area over native soil or backfill. Provide 18-inch minimum overlap at all seams. Any holes or tears shall be patched with fabric pieces that provide a minimum 18-inch overlap beyond the hole or tear in every direction. Anchor fabric to the sideslope with wood stakes placed along the upper edge of the fabric, and in conformance to the fabric joint details as shown in the plans. Care shall be taken to prevent wrinkles, folding, and tearing of the fabric during placement of the backfill. Comply with all installation requirements of the fabric manufacturer.

C.3 Stone Fill

Place stone fill carefully to the lines and grade shown on the Plans. Carefully place the stone in layers and densely pack the stone into the mattress. Layers of stone shall be approximately 12 inches thick. Intermix the sizes of stone material to provide uniform gradation throughout the revetment mattress. Uniformly overfill the top layer of stone 1 to 2 inches to compensate for future rock settlement; allow for providing an even surface that is uniform in appearance. Surface elevations of stone materials shall be measured at the average surface height, which is defined as the elevations midway between the lowest and highest points on the surface.

C.4 Topsoil

Topsoil shall extend 2 inches downwards within the voids of the vegetated revetment mattress fill and extend 2 inches over the topmost layer of the fill. Prior to rolling the topsoil, the revetment mattress seed mix shall be installed according to Section 33.C.5. Topsoil shall be compacted by roller to promote vegetation growth. The contractor shall make every effort to keep topsoil out of the channel bed.

2984-07-75 56 of 58

C.5 Seed Mix

Seed mix shall be applied to the vegetated revetment mattress by broadcast seeding with approved hand-operated seeding devices at the required seeding rate specified in the table in Section 33.B.5. Any areas to be seeded shall be seeded in two directions to ensure even application. The first phase shall proceed from the downstream end of a given section of lift, to the upstream end. The second phase shall proceed from the top of the flood channel to the bottom of the flood channel. All seed mixes shall be well-mixed before and during application. Following seeding, seed shall be hand-raked into topsoil and topsoil shall be compacted as described in Section 33.C.4.

C.6 Erosion Fabric

Following the compaction of the topsoil, erosion fabric shall be placed to cover the entire upper surface of the topsoil such that no topsoil is visible of the vegetated revetment mattress. Joints in erosion fabric shall have a minimum of a 1-foot overlap.

C.6 Wire Mesh

Revetment mattress wire shall lie firmly and directly upon the surface of the revetment mattress erosion fabric of the vegetated revetement mattress, and directly on the stone fill of the grouted revetment mattress. Installation of revetment mattresses must be in compliance with ASTM Designation A975-97 standard specification for Double-Twisted Hexagonal Mesh. Tightly close mechanical fasteners and space the fasteners as recommended by the manufacturer, the spacing between fasteners shall not exceed 6 inches.

C.7 Grouted Revetment Mattress

Revetment mattress must be grouted in the area around storm sewer outfalls. Grouted revetment mattress shall conform to standard spec 606 for Grouted Riprap except that broken concrete or recycled construction products will not be allowed unless specifically approved in writing by the engineer. The revetment to be grouted shall be the size shown on the plans and shall be placed according to the specifications. The spaces between the stones shall be filled with cement mortar. Sufficient mortar shall be used to completely fill all voids, except that the face surface of the stone shall be left exposed. Grout shall be placed from the bottom to top and the surface swept with a stiff broom. After grouting is complete, the surface shall be cured by the using a method approved by the engineer.

D Measurement

The department will measure Vegetated Revetment Mattress Slope Protection and Grouted Revetment Mattress Slope Protection by the square yard, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid items:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0180.02	Vegetated Revetment Mattress Slope Protection	SY
SPV.0180.03	Grouted Revetment Mattress Slope Protection	SY

2984-07-75 57 of 58

Payment of Vegetated Revetment Mattress Slope Protection is full compensation for providing all materials, surface grading, filter fabric, wood stakes, aggregate, erosion fabric, wire mesh, soils, seeding, for properly disposing of surplus materials.

Payment of Grouted Revetment Mattress Slope Protection is full compensation for providing all materials, surface grading, filter fabric, wood stakes, aggregate, wire mesh, grout, finishing, for properly disposing of surplus materials.

2984-07-75 58 of 58

November 2013 ASP-4

ADDITIONAL SPECIAL PROVISION 4

Payment to First-Tier Subcontractors

Within 10 calendar days of receiving a progress payment for work completed by a subcontractor, pay the subcontractor for that work. The prime contractor may withhold payment to a subcontractor if, within 10 calendar days of receipt of that progress payment, the prime contractor provides written notification to the subcontractor and the department documenting "just cause" for withholding payment.

The prime contractor may also withhold routine retainage from payments due subcontractors.

Payment to Lower-Tier Subcontractors

Ensure that subcontracting agreements at all tiers provide prompt payment rights to lower-tier subcontractors that parallel those granted first-tier subcontractors in this provision.

Release of Routine Retainage

After granting substantial completion the department may reduce the routine retainage withheld from the prime contractor to 75 percent of the original total amount retained.

When the Department sends the semi-final estimate the department may reduce the routine retainage withheld from the prime contractor to 10 percent of the original total amount retained.

Within 30 calendar days of receiving the semi-final estimate from the department, submit written certification that subcontractors at all tiers are paid in full for acceptably completed work and that no routine retainage is being withheld. The department will pay the prime contractor in full and reduce the routine retainage withheld from the prime contractor to zero when the department approves the final estimate.

This special provision does not limit the right of the department, prime contractor, or subcontractors at any tier to withhold payment for work not acceptably completed or work subject to an unresolved contract dispute.

ADDITIONAL SPECIAL PROVISION 6 ASP 6 - Modifications to the standard specifications

Make the following revisions to the standard specifications:

440.3.5.2 Corrective Actions for Localized Roughness

Replace paragraph two with the following effective with the September 2016 letting:

(2) The engineer will not direct corrective action or assess a pay reduction for an area of localized roughness without physically riding that work. The engineer will not direct corrective action on bridges without authorization from the department's bureau of structures.

450.3.1.1.4 Recording Truck Loads

Replace the entire text with the following effective with the December 2016 letting:

- (1) If not using automatic batch recording, install a digital recorder as part of the platform truck or storage silo scales. Ensure that the recorder can produce a printed digital record of at least the gross or net weights of delivery trucks. Provide gross, tare, net weights, load count, and the cumulative tonnage; the date, time, ticket number, WisDOT project ID, and mix 250 number; and the mix type including the traffic, binder, and mix designation codes specified in 460.3.1. Ensure that scales cannot be manually manipulated during the printing process. Provide an interlock to prevent printing until the scales come to rest. Size the scales and recorder to accurately weigh the heaviest loaded trucks or tractor-trailers hauling asphaltic mixture. Ensure that recorded weights are accurate to within 0.1 percent of the nominal capacity of the scale.
- (2) Ensure that tickets identify additives not included in the mix design submittal. Indicate on the ticket if the mixture will be placed under a cold weather paving plan and identify the warm mix additive and dosage rate required under 450.3.2.1.2.2.

455.3.2.1 General

Replace paragraph one with the following effective with the December 2016 letting:

(1) Apply tack coat only when the air temperature is 32 F or more unless the engineer approves otherwise in writing. Before applying tack coat ensure that the surface is reasonably free of loose dirt, dust, or other foreign matter. Do not apply to surfaces with standing water. Do not apply if weather or surface conditions are unfavorable or before impending rains.

460.2.1 General

Replace the entire text with the following effective with the December 2016 letting:

- (1) Furnish a homogeneous mixture of coarse aggregate, fine aggregate, mineral filler if required, SMA stabilizer if required, recycled material if used, warm mix asphalt additive or process if used, and asphaltic material. Design mixtures conforming to table 460-1 and table 460-2 to 4.0% air voids to establish the aggregate structure.
- (2) Determine the target JMF asphalt binder content for production from the mix design data corresponding to 3.0% air voids (97% Gmm) target at the design the number of gyrations (Ndes). Add liquid asphalt to achieve the required air voids at Ndes.
- (3) For SMA, determine the target JMF asphalt binder content for production from the mix design data corresponding to 4.0% air voids (96% Gmm) target at Ndes.

460.2.8.2.1.5 Control Limits

Replace paragraph one with the following effective with the December 2016 letting:

(1) Conform to the following control limits for the JMF and warning limits based on a running average of the last 4 data points:

ITEM	JMF LIMITS	WARNING LIMITS
Percent passing given sieve:		
37.5-mm	+/- 6.0	+/- 4.5
25.0-mm	+/- 6.0	+/- 4.5
19.0-mm	+/- 5.5	+/- 4.0
12.5-mm	+/- 5.5	+/- 4.0
9.5-mm	+/- 5.5	+/- 4.0
2.36-mm	+/- 5.0	+/- 4.0
75-µm	+/- 2.0	+/- 1.5
Asphaltic content in percent	- 0.3	- 0.2
Air voids in percent ^[1]	+1.3/-1.0	+1.0/-0.7
VMA in percent ^[2]	- 0.5	- 0.2

^[1] For SMA, JMF limits are +/-1.3 and warning limits are +/-1.0.

460.2.8.2.1.6 Job Mix Formula Adjustment

Replace paragraph one with the following effective with the December 2016 letting:

(1) The contractor may request adjustment of the JMF according to CMM 8-36.6.13.1. Have an HMA technician certified at a level appropriate for process control and troubleshooting or mix design submit a written JMF adjustment request. Ensure that the resulting JMF is within specified master gradation bands. The department will have a certified Hot Mix Asphalt, Mix Design, Report Submittals technician review the proposed adjustment and, if acceptable, issue a revised JMF.

460.2.8.3.1.6 Acceptable Verification Parameters

Replace paragraph one with the following effective with the December 2016 letting:

- (1) The engineer will provide test results to the contractor within 2 mixture-production days after obtaining the sample. The quality of the product is acceptably verified if it meets the following limits:
 - Va is within a range of 2.0 to 4.3 percent. For SMA, Va is within a range of 2.7 to 5.3 percent.
 - VMA is within minus 0.5 of the minimum requirement for the mix design nominal maximum aggregate size.

^[2] VMA limits based on minimum requirement for mix design nominal maximum aggregate size in table 460-1.

460.3.3.1 Minimum Required Density

Replace paragraph one with the following effective with the December 2016 letting:

(1) Compact all layers of HMA mixture to the density table 460-3 shows for the applicable mixture, location, and layer.

TABLE 460-3 MINIMUM REQUIRED DENSITY[1]

		PERCENT	OF TARGET MAXIMUM DE	ENSITY
LOCATION LAYER		MIXTURE TYPE		
		LT and MT	HT	SMA ^[5]
TRAFFIC LANES[2]	LOWER	93.0 ^[3]	93.0 ^[4]	
TRAFFIC LAINES	UPPER	93.0	93.0	
SIDE ROADS,	LOWER	93.0 ^{3]}	93.0 ^[4]	
CROSSOVERS, TURN LANES, & RAMPS	UPPER	93.0	93.0	
SHOULDERS &	LOWER	91.0	91.0	
APPURTENANCES	UPPER	92.0	92.0	

^[1] The table values are for average lot density. If any individual density test result falls more than 3.0 percent below the minimum required target maximum density, the engineer may investigate the acceptability of that material.

460.5.2.1 General

Replace paragraph six with the following effective with the December 2016 letting:

(6) If during a QV dispute resolution investigation the department discovers mixture with 1.5 > Va > 5.0 or VMA more than 1.0 below the minimum allowed in table 460-1, and the engineer allows that mixture to remain in place, the department will pay for the quantity of affected material at 50 percent of the contract price.

460.5.2.3 Incentive for HMA Pavement Density

Replace paragraph one with the following effective with the December 2016 letting:

(1) If the lot density is greater than the minimum specified in table 460-3 and all individual air voids test results for that mixture placed during the same day are within 2.5 - 4.0 percent, the department will adjust pay for that lot as follows:

INCENTIVE PAY ADJUSTMENT FOR HMA PAVEMENT DENSITY[1]

PERCENT LOT DENSITY ABOVE SPECIFIED MINIMUM
From -0.4 to 1.0 inclusive
From 1.1 to 1.8 inclusive
More than 1.8

\$0.40
\$0.80

^[2] Includes parking lanes as determined by the engineer.

^[3] Minimum reduced by 2.0 percent for a lower layer constructed directly on crushed aggregate or recycled base courses.

^[4] Minimum reduced by 1.0 percent for a lower layer constructed directly on crushed aggregate or recycled base courses.

^[5] The minimum required densities for SMA mixtures are determined according to CMM 8-15.

^[1] SMA pavements are not eligible for density incentive.

^[2] The department will prorate the pay adjustment for a partial lot.

501.2.6 Fly Ash

Replace the entire subsection with the following effective with the December 2016 letting:

501.2.6.1 General

- (1) Fly ash is defined as a finely divided residue resulting from the combustion of coal in a base loaded electric generating plant, transported from the boiler by flue gases, and later collected, generally by precipitators. Use fly ash in concrete manufactured by facilities and processes known to provide satisfactory material.
- (2) Test fly ash using a recognized laboratory, as defined in 501.2.2(1), starting at least 30 days before its proposed use, and continuing at ASTM-required frequencies as the work progresses. The manufacturer shall test the chemical and physical properties listed in tables 1 and 2 of ASTM C618 at the frequencies and by the test methods prescribed in ASTM C311.
- (3) Use only one source of fly ash for a bid item of work under the contract, unless the engineer directs or allows otherwise in writing.
- (4) Prequalify any proposed fly ash source as follows: The contractor shall obtain a copy of the certified report of tests or analysis made by a qualified independent laboratory, recognized by the department under 501.2.2, showing full and complete compliance with the above specification from the fly ash manufacturer and furnish it to the engineer. Provide this report to the engineer at least 14 calendar days before using the fly ash.
- (5) The manufacturer shall retain test records for at least 5 years after completing the work, and provide these records upon request.

501.2.6.2 Class C Ash

(1) Conform to ASTM C618 class C except limit the loss on ignition to a maximum of 2 percent.

501.2.6.3 Class F Ash

(2) Furnish a class F fly ash from a source listed on the department's approved product list, and conform to ASTM C618 class F except limit the loss on ignition to a maximum of 2 percent.

502.3.7.8 Floors

Replace paragraph sixteen with the following effective with the September 2016 letting:

(16) The finished bridge floor shall conform to the surface test specified in 415.3.10. The engineer will not direct corrective grinding without authorization from the department's bureau of structures.

503.3.2.1.1 Tolerances

<u>Increase the "length of beam" max tolerance for prestressed concrete I-type girders from 3/4" to 1 1/2"</u> effective with the December 2016 letting:

PRESTRESSED CONCRETE I-TYPE GIRDERS

517.3.1.7.3 Epoxy System Intermediate and Protective Coats

Replace paragraph one with the following effective with the December 2016 letting:

- (1) Mask the faying surfaces of bolted field splices and the top of the top flanges where welding the stud shear connectors during coat application. On all other areas including the outside surfaces of splice plates, ensure that the dry film thickness conforms to the following:
 - 1. For the white intermediate coat, 3.5 mils to 8 mils.
 - 2. For the protective coat, sufficient thickness to provide a uniform color and appearance but not less than 3 mil or more than 6 mils.

Errata

Make the following corrections to the standard specifications:

Throughout the contract:

Update all references to the construction rental rate "Blue Book" to reference "EquipmentWatch" rates.

105.13.4 Content of Claim

- (1) Include the following 5 items in the claim.
 - 1. A concise description of the claim.
 - 2. A clear contractual basis for the claim. This should include reference to 104.2 on revisions to the contract and as appropriate, specific reference to contract language regarding the bid items in question.
 - 3. Other facts the contractor relies on to support the claim.
 - 4. A concise statement of the circumstances surrounding the claim and reasons why the department should pay the claim. Explain how the claimed work is a change to the contract work.
 - 5. A complete breakdown of the costs used to compile the claim. Include copies of all EquipmentWatch equipment rental rate sheets used, with the applicable number highlighted.

109.4.5.5.1 General

(2) The department will pay for use of contractor-owned equipment the engineer approves for force account work at published rates. The department will pay the contractor expense rates, as modified in 109.4.5.5, given in EquipmentWatch Cost Recovery (formerly Rental Rate Blue Book). Base all rates on revisions effective on January 1 for all equipment used in that calendar year.

http://equipmentwatch.com/estimator/

109.4.5.5.2 Hourly Equipment Expense Rates (Without Operators)

(1) The contractor shall determine, and the department will confirm, hourly equipment expense rates as follows:

 $HEER = [RAF \times ARA \times (R/176)] + HOC$

Where:

HEER = Hourly equipment expense rate.

RAF = EquipmentWatch regional adjustment factor.

ARA = EquipmentWatch age rate adjustment factor.

R = Current EquipmentWatch monthly rate.

HOC = EquipmentWatch estimated hourly operating cost.

(2) The EquipmentWatch hourly operating cost represents all costs of equipment operation, including fuel and oil, lubrication, field repairs, tires, expendable parts, and supplies.

109.4.5.5.3 Hourly Equipment Stand-By Rate

(1) For equipment that is in operational condition and is standing-by with the engineer's approval, the contractor shall determine, and the department will confirm, the hourly stand-by rate as follows:

 $HSBR = RAF \times ARA \times (R/176) \times (1/2)$

Where:

HSBR = Hourly stand-by rate.

RAF = EquipmentWatch regional adjustment factor.

ARA = EquipmentWatch age rate adjustment factor.

R = Current EquipmentWatch monthly rate.

(2) The department will limit payment for stand-by to 10 hours or less per day up to 40 hours per week. The department will not pay the contractor for equipment that is inoperable due to breakdown. The department will not pay for idle equipment if the contractor suspends work or if the contractor is maintaining or repairing the equipment.

109.4.5.5.4 Hourly Outside-Rented Equipment Rate

(1) If the contractor rents or leases equipment from a third party for force account work, the contractor shall determine, and the department will confirm, the hourly outside-rented equipment rate as follows:

HORER = HRI + HOC

Where:

HORER = Hourly outside-rented equipment rate

HRI = Hourly rental invoice costs prorated for the actual number of hours

that rented equipment is operated solely on force account work

HOC = EquipmentWatch hourly operating cost.

109.2 Scope of Payment

Correct errata to clarify that work under the contract is included in payment unless specifically excluded.

- (2) The department will pay for the quantity of work acceptably completed and measured for payment as the measurement subsection for each bid item specifies. Within the contract provide means to furnish and install the work complete and in-place. Payment is full compensation for everything required to perform the work under the contract including, but not limited to, the work elements listed in the payment subsection. Payment also includes all of the following not specifically excluded in that payment subsection:
 - 1. Furnishing and installing all materials as well as furnishing the labor, tools, supplies, equipment, and incidentals necessary to perform the work.
 - 2. All losses or damages, except as specified in 107.14, arising from one or more of the following:
 - The nature of the work.
 - The action of the elements.
 - Unforeseen difficulties encountered during prosecution of the work.
 - 3. All insurance costs, expenses, and risks connected with the prosecution of the work.
 - 4. All expenses incurred because of an engineer-ordered suspension, except as specified in 104.2.2.3.
 - 5. All infringements of patents, trademarks, or copyrights.
 - 6. All other expenses incurred to complete and protect the work under the contract.

204.3.2.2.1 General

Correct errata by removing the reference to 490 which was deleted effective with the 2017 spec.

(1) Under the Removing Pavement bid item, remove concrete pavements, concrete alleys, concrete driveways, or rigid base including all surfaces or other pavements superimposed on them.

657.2.2.1.1 General

Correct errata by eliminating the reference to department provided arms in the last sentence.

(1) Furnish shop drawings as specified in 506.3.2, except submit 5 copies with the materials list. Ensure the drawings contain sufficient detail to allow satisfactory review and show the outside diameters of the pole at the butt, top, and splice locations the plans show. Show the width, depth, length, and thickness of all material, and list pertinent ASTM specification designations and metal alloy designations together with the tensile strength of metallic members. Provide tightening procedures for arm-to-pole connections on the shop drawings.

657.2.2.1.4 Poles Designed Under Legacy Standards

Correct errata by deleting the entire subsection to eliminate redundant language.

657.2.2.2 Trombone Arms

Correct errata by changing the reference from 657.2.2.1.3 to 657.2.2.1.2.

(1) Design aluminum trombone arms as specified in 657.2.2.1.2 based on the completed maximum loading configuration the plans show. Furnish shop drawings conforming to 657.2.2.1.1 that show the width, depth, length, and thickness of all members. Also list the ASTM alloy designation and strength of each aluminum member on the shop drawings.

ADDITIONAL SPECIAL PROVISION 7

- A. Reporting 1st Tier and DBE Payments During Construction
 - 1. Comply with reporting requirements specified in the department's Civil Rights Compliance, Contractor's User Manual, Sublets and Payments.
 - 2. Report payments to all DBE firms within 10 calendar days of receipt of a progress payment by the department or a contractor for work performed, materials furnished, or materials stockpiled by a DBE firm. Report the payment as specified in A(1) for all work satisfactorily performed and for all materials furnished or stockpiled.
 - 3. Report payments to all first tier subcontractor relationships within 10 calendar days of receipt of a progress payment by the department for work performed. Report the payment as specified in A(1) for all work satisfactorily performed.
 - 4. All tiers shall report payments as necessary to comply with the DBE payment requirement as specified in A(2).
 - 5. Require all first tier relationships, DBE firms and all other tier relationships necessary to comply with the DBE payment requirement in receipt of a progress payment by contractor to acknowledge receipt of payment as specified in A(1), (2), (3) and (4).
 - 6. All agreements made by a contractor shall include the provisions in A(1), (2), (3), (4) and (5), and shall be binding on all first tier subcontractor relationships and all contractors and subcontractors utilizing DBE firms on the project.
- B. Costs for conforming to this special provision are incidental to the contract.

ADDITIONAL SPECIAL PROVISION 9 Electronic Certified Payroll Submittal

(1) Use the department's Civil Rights Compliance System (CRCS) to submit certified payrolls electronically. Details are available online through the department's highway construction contractor information (HCCI) site on the Labor, Wages, and EEO Information page at:

http://wisconsindot.gov/Pages/doing-bus/civil-rights/labornwage/default.aspx

- (2) Ensure that all tiers of subcontractors, as well as all trucking firms, submit their weekly certified payrolls electronically through CRCS. These payrolls are due within seven calendar days following the close of the payroll period. Every firm providing physical labor towards completing the project is a subcontractor under this special provision.
- (3) Upon receipt of contract execution, promptly make all affected firms aware of the requirements under this special provision and arrange for them to receive CRCS training as they are about to begin payrolls. The department will provide training either in a classroom setting at one of our regional offices or by telephone. Contact Paul Ndon at (414) 438-4584 to schedule the training.
- (4) The department will reject all paper submittals of forms DT-1816 and DT-1929 for information required under this special provision. All costs for conforming to this special provision are incidental to the contract.
- (5) Firms wishing to export payroll data from their computer system into CRCS should have their payroll coordinator contact Paul Ndon. Not every contractor's payroll system is capable of producing export files. For details, see pages 17-22 of the CRCS System Background Information manual available online on the Labor, Wages, and EEO Information page at:

http://wisconsindot.gov/Documents/doing-bus/civil-rights/labornwage/crcs-payroll-manual.pdf

Non-discrimination Provisions

During the performance of this contract, the contractor, for itself, its assignees, and successors in interest (hereinafter referred to as the "contractor") agrees as follows:

- **1. Compliance with Regulations:** The contractor (hereinafter includes consultants) will comply with the Acts and the Regulations relative to Non-discrimination in Federally-assisted programs of the U.S. Department of Transportation, Federal Highway Administration, as they may be amended from time to time, which are herein incorporated by reference and made a part of this contract.
- **2. Non-discrimination:** The contractor, with regard to the work performed by it during the contract, will not discriminate on the grounds of race, color, or national origin in the selection and retention of subcontractors, including procurements of materials and leases of equipment. The contractor will not participate directly or indirectly in the discrimination prohibited by the Acts and the Regulations, including employment practices when the contract covers any activity, project, or program set forth in Appendix B of 49 CFR Part 21.
- **3. Solicitations for Subcontracts, Including Procurements of Materials and Equipment:** In all solicitations, either by competitive bidding, or negotiation made by the contractor for work to be performed under a subcontract, including procurements of materials, or leases of equipment, each potential subcontractor or supplier will be notified by the contractor of the contractor's obligations under this contract and the Acts and the Regulations relative to Non-discrimination on the grounds of race, color, or national origin.
- **4. Information and Reports:** The contractor will provide all information and reports required by the Acts, the Regulations, and directives issued pursuant thereto and will permit access to its books, records, accounts, other sources of information, and its facilities as may be determined by the Recipient or the Federal Highway Administration to be pertinent to ascertain compliance with such Acts, Regulations, and instructions. Where any information required of a contractor is in the exclusive possession of another who fails or refuses to furnish the information, the contractor will so certify to the Recipient or the Federal Highway Administration, as appropriate, and will set forth what efforts it has made to obtain the information.
- **5. Sanctions for Noncompliance:** In the event of a contractor's noncompliance with the Non-discrimination provisions of this contract, the Recipient will impose such contract sanctions as it or the Federal Highway Administration may determine to be appropriate, including, but not limited to:
 - a. Withholding payments to the contractor under the contract until the contractor complies; and/or
 - b. Cancelling, terminating, or suspending a contract, in whole or in part.

6. Incorporation of Provisions: The contractor will include the provisions of paragraphs one through six in every subcontract, including procurements of materials and leases of equipment, unless exempt by the Acts, the Regulations and directives issued pursuant thereto. The contractor will take action with respect to any subcontract or procurement as the Recipient or the Federal Highway Administration may direct as a means of enforcing such provisions including sanctions for noncompliance. Provided, that if the contractor becomes involved in, or is threatened with litigation by a subcontractor, or supplier because of such direction, the contractor may request the Recipient to enter into any litigation to protect the interests of the Recipient. In addition, the contractor may request the United States to enter into the litigation to protect the interests of the United States.

During the performance of this contract, the contractor, for itself, its assignees, and successors in interest (hereinafter referred to as the "contractor") agrees to comply with the following non-discrimination statutes and authorities; including but not limited to:

Pertinent Non-Discrimination Authorities:

- Title VI of the Civil Rights Act of 1964 (42 U.S.C. § 2000d et seq., 78 stat. 252), (prohibits discrimination on the basis of race, color, national origin); and 49 CFR Part 21.
- The Uniform Relocation Assistance and Real Property Acquisition Policies Act of 1970, (42 U.S.C. § 4601), (prohibits unfair treatment of persons displaced or whose property has been acquired because of Federal or Federal-aid programs and projects);
- Federal-Aid Highway Act of 1973, (23 U.S.C. § 324 et seq.), (prohibits discrimination on the basis of sex);
- Section 504 of the Rehabilitation Act of 1973, (29 U.S.C. § 794 et seq.), as amended, (prohibits discrimination on the basis of disability); and 49 CFR Part 27;
- The Age Discrimination Act of 1975, as amended, (42 U.S.C. § 6101 et seq.), (prohibits discrimination on the basis of age);
- Airport and Airway Improvement Act of 1982, (49 USC § 471, Section 47123), as amended, (prohibits discrimination based on race, creed, color, national origin, or sex);
- The Civil Rights Restoration Act of 1987, (PL 100-209), (Broadened the scope, coverage and applicability of Title VI of the Civil Rights Act of 1964, The Age Discrimination Act of 1975 and Section 504 of the Rehabilitation Act of 1973, by expanding the definition of the terms "programs or activities" to include all of the programs or activities of the Federal-aid recipients, sub-recipients and contractors, whether such programs or activities are Federally funded or not);
- Titles II and III of the Americans with Disabilities Act, which prohibit discrimination on the basis of disability in the operation of public entities, public and private transportation systems, places of public accommodation, and certain testing entities (42 U.S.C. §§ 12131-12189) as implemented by Department of Transportation regulations at 49 C.F.R. parts 37 and 38;
- The Federal Aviation Administration's Non-discrimination statute (49 U.S.C. § 47123) (prohibits discrimination on the basis of race, color, national origin, and sex);

- Executive Order 12898, Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations, which ensures Non-discrimination against minority populations by discouraging programs, policies, and activities with disproportionately high and adverse human health or environmental effects on minority and low-income populations;
- Executive Order 13166, Improving Access to Services for Persons with Limited English Proficiency, and resulting agency guidance, national origin discrimination includes discrimination because of Limited English proficiency (LEP). To ensure compliance with Title VI, you must take reasonable steps to ensure that LEP persons have meaningful access to your programs (70 Fed. Reg. at 74087 to 74100);
- Title IX of the Education Amendments of 1972, as amended, which prohibits you from discriminating because of sex in education programs or activities (20 U.S.C. 1681 et seq).

Effective August 2015 letting

BUY AMERICA PROVISION

All steel and iron materials permanently incorporated in this project shall be domestic products and all manufacturing and coating processes for these materials from smelting forward in the manufacturing process must have occurred within the United States. Coating includes epoxy coating, galvanizing, painting and any other coating that protects or enhances the value of a material subject to the requirements of Buy America. The exemption of this requirement is the minimal use of foreign materials if the total cost of such material permanently incorporated in the product does not exceed one-tenth of one percent (1/10 of 1%) of the total contract cost or \$2,500.00, whichever is greater. For purposes of this paragraph, the cost is that shown to be the value of the subject products as they are delivered to the project. The contractor shall take actions and provide documentation conforming to CMM 2-28.5 to ensure compliance with this "Buy America" provision.

http://wisconsindot.gov/rdwy/cmm/cm-02-28.pdf

Upon completion of the project certify to the engineer, in writing using department form WS4567, that all steel, iron, and coating processes for steel or iron incorporated into the contract work conform to these "Buy America" provisions. Attach a list of exemptions and their associated costs to the certification form. Department form WS4567 is available at:

http://wisconsindot.gov/hcciDocs/contracting-info/ws4567.doc

1 of 1

Effective with February 2017 Letting

WISCONSIN DEPARTMENT OF TRANSPORTATION DIVISION OF TRANSPORTATION AND SYSTEM DEVELOPMENT

SUPPLEMENTAL REQUIRED CONTRACT PROVISIONS

- I. Prevailing Wage Rates, Hours of Labor, and Payment of Wages
- **II.** Payroll Requirements
- **III.** Postings at the Site of the Work
- IV. Wage Rate Distribution
- V. Additional Classifications

I. PREVAILING WAGE RATES, HOURS OF LABOR AND PAYMENT OF WAGES

The U.S. Department of Labor (Davis-Bacon Minimum Wage Rates) attached hereto and made a part hereof furnishes the prevailing wage rates pursuant to Section 84.062 of the Wisconsin Statutes. These wage rates are the minimum required to be paid to the laborers, workers, mechanics and truck drivers employed by contractors and subcontractors on the construction work embraced by the contract and subject to prevailing hours and wages under Section 84.062, Stats. Apprentices shall be paid at rates not less than those prescribed in their apprenticeship contract.

While the wage rates shown are the minimum rates required by the contract to be paid during its life, this is not a representation that labor can be obtained at these rates. It is the responsibility of bidders to inform themselves as to the local labor conditions and prospective changes or adjustments of wage rates. No increase in the contract price shall be allowed or authorized on account of the payment of wage rates in excess of those listed herein

Pursuant to Section 16.856 of the Wisconsin Statutes, the prevailing hours of labor have been determined to be up to 10 hours per day and 40 hours per calendar week Monday through Friday. If any laborer, worker, mechanic or truck driver is permitted or required to work more than the prevailing number of hours per day or per calendar week on this contract, they shall be paid for all hours in excess of the prevailing hours at a rate of at least one and one-half (1 1/2) times their hourly base rate of pay. All work on Saturday, Sunday and the following holidays is to be paid at time and a half:

January 1
Last Monday in May
July 4
First Monday in September
Fourth Thursday in November
December 25
The day before if January 1. July

The day before if January 1, July 4 or December 25 falls on a Saturday, and

The day following if January 1, July 4 or December 25 falls on a Sunday.

All laborers, workers, mechanics and truck drivers shall be paid unconditionally not less often than once a week. Persons who own and operate their own trucks must receive the prevailing truck driver rate for the applicable type of truck (i.e. 2 axle, 3 or more axle, articulated, euclid or dumptor) he or she operates, plus an agreed upon amount for the use of his or her truck. Every owner-operator MUST be paid separately for their driving and for the use of their truck.

II. PAYROLL REQUIREMENTS

All contractors and subcontractors must submit weekly Certified Payrolls and Compliance Statement verifying that all laborers, workers, mechanics and truckdrivers working on the project have been paid the prevailing wage rates for all workperformed under the contract required by Section 84.062 of the Wisconsin Statutes.

III. POSTINGS AT THE SITE OF THE WORK

In addition to the required postings furnished by the Department, the contractor shall post the following in at least one conspicuous and accessible place at the site of work:

- a. "NOTICE TO EMPLOYEES," which provides information required to be posted by the provisions of Section 84.062 of the Wisconsin Statutes.
- b. A copy of the U.S. Department of Labor (Davis-Bacon, Minimum Wage Rates).
- c. A copy of the contractor's Equal Employment Opportunity Policy.

All required documents shall be posted by the first day of work and be accurate and complete. Postings must be readable, in an area where they will be noticed, and maintained until the last day of work.

IV. WAGE RATE REDISTRIBUTION

A contractor or subcontractor performing work subject to a Davis-Bacon wage determination may discharge its minimum wage obligations for the payment of both straight time wages and fringe benefits by (1) paying both in cash, (2) making payments or incurring costs for bona fide fringe benefits, or (3) by a combination thereof. Thus, under the Davis-Bacon a contractor may offset an amount of monetary wages paid in excess of the minimum wage required under the determination to satisfy its fringe benefit obligations. *See* 40 USC 3142(d) and 29 CFR 5.31.

V. ADDITIONAL CLASSIFICATIONS

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5(a)(1)(ii)). The contracting officer shall require that any class of laborers or mechanics, including helpers, which is not listed in the wage determination and which is to be employed under the contract shall be classified in conformance with the wage determination.

The contracting officer shall approve an additional classification and wage rate and fringe benefits therefore only when the following criteria have been met:

- a. The work to be performed by the classification requested is not performed by a classification in the wage determination; and
- b. The classification is utilized in the area by the construction industry; and
- c. The proposed wage rate, including any bona fide fringe benefits, bears a reasonable relationship to the wage rates contained in the wage determination.

General Decision Number: WI170010 02/24/2017 WI10

Superseded General Decision Number: WI20160010

State: Wisconsin

Construction Type: Highway

Counties: Wisconsin Statewide.

HIGHWAY, AIRPORT RUNWAY & TAXIWAY CONSTRUCTION PROJECTS (does not include bridges over navigable waters; tunnels; buildings in highway rest areas; and railroad construction)

Note: Under Executive Order (EO) 13658, an hourly minimum wage of \$10.20 for calendar year 2017 applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2015. If this contract is covered by the EO, the contractor must pay all workers in any classification listed on this wage determination at least \$10.20 (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on the contract in calendar year 2017. The EO minimum wage rate will be adjusted annually. Additional information on contractor requirements and worker protections under the EO is available at www.dol.gov/whd/govcontracts.

Modification Numbe	r Publication Date
0	01/06/2017
1	02/03/2017
2	02/10/2017
3	02/24/2017

BRWI0001-002 06/01/2016

CRAWFORD, JACKSON, JUNEAU, LA CROSSE, MONROE, TREMPEALEAU, AND VERNON COUNTIES

	Rates	Fringes
BRICKLAYER	.\$ 31.84	20.95
BRWI0002-002 06/01/2016		

ASHLAND, BAYFIELD, DOUGLAS, AND IRON COUNTIES

	Rates	Fringes	
BRICKLAYER	\$ 37.04	19.70	
BRWI0002-005 06/01/2016			

ADAMS, ASHLAND, BARRON, BROWN, BURNETT, CALUMET, CHIPPEWA, CLARK, COLUMBIA, DODGE, DOOR, DUNN, FLORENCE, FOND DU LAC, FOREST, GREEN LAKE, IRON, JEFFERSON, KEWAUNEE, LANGLADE, LINCOLN, MANITOWOC, MARATHON, MARINETTE, MARQUETTE, MENOMINEE, OCONTO, ONEIDA, OUTAGAMIE, POLK, PORTAGE, RUSK, ST CROIX, SAUK, SHAWANO, SHEBOYGAN, TAYLOR, VILAS, WALWORTH, WAUPACA, WAUSHARA, WINNEBAGO, AND WOOD COUNTIES

Fringes
20.51
OCONTO COUNTIES
Fringes
20.57

Rates Fringes

KENOSHA, RACINE, AND WALWORTH COUNTIES

BRICKLAYER	\$ 36.59	21.49
BRWI0006-002 06/01/2016		
ADAMS, CLARK, FOREST, LANGLADE ONEIDA, PORTAGE, PRICE, TAYLOR		
	Rates	Fringes
BRICKLAYER	\$ 33.04	19.75
BRWI0007-002 06/01/2016		
GREEN, LAFAYETTE, AND ROCK COU	NTIES	
	Rates	Fringes
BRICKLAYER	\$ 33.53	20.95
BRWI0008-002 06/01/2016		
MILWAUKEE, OZAUKEE, WASHINGTON	, AND WAUKESHA	COUNTIES
	Rates	Fringes
BRICKLAYER BRWI0011-002 06/01/2016	\$ 36.98	20.62
CALUMET, FOND DU LAC, MANITOWO	C, AND SHEBOYG	AN COUNTIES
	Rates	Fringes
BRICKLAYER	\$ 32.22	20.57
BRWI0019-002 06/01/2016		
BARRON, BUFFALO, BURNETT, CHIP PIERCE, POLK, RUSK, ST. CROIX,		
	Rates	Fringes
BRICKLAYER	\$ 31.98	20.81
BRWI0034-002 06/01/2015		
COLUMBIA AND SAUK COUNTIES		
	Rates	Fringes
BRICKLAYER		17.22
* CARP0087-001 05/01/2016		
BURNETT (W. of Hwy 48), PIERCE 35, 48 & 65), AND ST. CROIX (W	(W. of Hwy 29 . of Hwy 65) C), POLK (W. of Hwys OUNTIES
	Rates	Fringes
Carpenter & Piledrivermen	\$ 36.85	18.39
CARP0252-002 06/01/2016		
ADAMS, BARRON, BAYFIELD (Eas BURNETT (E. of Hwy 48), CALUME' CRAWFORD, DANE, DODGE, DOOR, D' area bordering Michigan State GRANT, GREEN, GREEN LAKE, IOWA JUNEAU, KEWAUNEE, LA CROSSE, L. MANITOWOC, MARATHON, MARINETTE MENOMINEE, MONROE, OCONTO, ONE of Hwys 29 & 65), POLK (E. of PRICE, RICHLAND, ROCK, RUSK, S. ST CROIX (E. of Hwy 65), TAYLO	T, CHIPPEWA, C UNN, EAU CLAIR Line), FOND DU , IRON, JACKSO AFAYETTE, LANG (except N.E. IDA, OUTAGAMIE Hwys 35, 48 &	LARK, COLUMBIA, E, FLORENCE (except LAC, FOREST, N, JEFFERSON, LADE, LINCOLN, corner), MARQUETTE, , PEPIN, PIERCE (E. 65), PORTAGE,

	Rates	Fringes
CARPENTER CARPENTER. MILLWRIGHT. PILEDRIVER.	\$ 35.08	18.00 18.35 18.00
CARP0252-010 06/01/2016		
ASHLAND COUNTY		
	Rates	Fringes
Carpenters CarpenterMillwrightPile Driver	\$ 35.08	18.00 18.35 18.00
CARP0264-003 06/01/2008		
KENOSHA, MILWAUKEE, OZAUKEE, RACI COUNTIES	NE, WAUKESHA, A	ND WASHINGTON
	Rates	Fringes
CARPENTER	\$ 30.52	14.41
BAYFIELD (West of Hwy 63) AND DOU	JGLAS COUNTIES	
· · · · · · · · · · · · · · · · · · ·	Rates	Fringes
CARPENTER	\$ 34.57	18.16
CARP2337-001 06/01/2008		
ZONE A: MILWAUKEE, OZAUKEE, WAUKE	SHA AND WASHING	TON
ZONE B: KENOSHA & RACINE		
	Rates	Fringes
PILEDRIVERMAN	Races	ringes
Zone B		19.46 19.46
ELEC0014-002 05/30/2016		
ASHLAND, BARRON, BAYFIELD, BUFFAI (except Maryville, Colby, Unity, Sherwood), CRAWFORD, DUNN, EAU CI CROSSE, MONROE, PEPIN, PIERCE, PC CROIX, SAWYER, TAYLOR, TREMPEALER COUNTIES	Sherman, Fremon AIRE, GRANT, IR DLK, PRICE, RICH	t, Lynn & ON, JACKSON, LA LAND, RUSK, ST
	Rates	Fringes
Electricians:	\$ 32.00	19.28
ELEC0014-007 05/30/2016		
REMAINING COUNTIES		
	Rates	Fringes
Teledata System Installer Installer/Technician	\$ 24.35	13.15
Low voltage construction, instaremoval of teledata facilities including outside plant, telephinterconnect, terminal equipmentiber optic cable and equipment bypass, CATV, WAN (wide area networks), and ISDN (integrated	(voice, data, a none and data in nt, central offi c, micro waves, etworks), LAN (1	nd video) side wire, ces, PABX, V-SAT, ocal area

ELEC0127-002 06/01/2016

KENOSHA COUNTY

Rates Fringes

Electricians:.....\$ 37.71 30%+10.02

ELEC0158-002 05/30/2016

BROWN, DOOR, KEWAUNEE, MANITOWOC (except Schleswig), MARINETTE(Wausuakee and area South thereof), OCONTO, MENOMINEE (East of a ine 6 miles West of the West boundary of Oconto County), SHAWANO (Except Area North of Townships of Aniwa and Hutchins) COUNTIES

Rates Fringes

Electricians:.....\$ 30.50 29.50% + 9.57

ELEC0159-003 05/30/2016

COLUMBIA, DANE, DODGE (Area West of Hwy 26, except Chester and Emmet Townships), GREEN, LAKE (except Townships of Berlin, Seneca, and St. Marie), IOWA, MARQUETTE (except Townships of Neshkoka, Crystal Lake, Newton, and Springfield), and SAUK COUNTIES

Rates Fringes

Electricians:.....\$ 36.50 20.39

ELEC0219-004 06/01/2015

FLORENCE COUNTY (Townships of Aurora, Commonwealth, Fern, Florence and Homestead) AND MARINETTE COUNTY (Township of Niagara)

Rates Fringes

Electricians:
 Electrical contracts over \$180,000......\$ 31.16 18.34 Electrical contracts under \$180,000......\$ 28.96 18.26

ELEC0242-005 05/29/2016

DOUGLAS COUNTY

Rates Fringes

Electricians:.....\$34.92 25.05

ELEC0388-002 06/01/2013

ADAMS, CLARK (Colby, Freemont, Lynn, Mayville, Sherman, Sherwood, Unity), FOREST, JUNEAU, LANGLADE, LINCOLN, MARATHON, MARINETTE (Beecher, Dunbar, Goodman & Pembine), MENOMINEE (Area West of a line 6 miles West of the West boundary of Oconto County), ONEIDA, PORTAGE, SHAWANO (Aniwa and Hutchins), VILAS AND WOOD COUNTIES

Rates Fringes

Electricians:.....\$ 28.96 24.85% + 9.70

ELEC0430-002 06/01/2016

RACINE COUNTY (Except Burlington Township)

Rates Fringes
Electricians:.....\$36.07 21.84

ELEC0494-005 06/01/2016

MILWAUKEE, OZAUKEE, WASHINGTON, AND WAUKESHA COUNTIES

	Races	ringes	
Electricians:	\$ 36.01	24.00	
FI.FC0494-006 06/01/2014			

CALUMET (Township of New Holstein), DODGE (East of Hwy 26 including Chester Township), FOND DU LAC, MANITOWOC (Schleswig), and SHEBOYGAN COUNTIES

	Rates	Fringes	
Electricians:	\$ 29.64	20.54	
TT TG0 40 4 01 3 06 /01 /001 F			

ELEC0494-013 06/01/2015

DODGE (East of Hwy 26 including Chester Twp, excluding Emmet Twp), FOND DU LAC (Except Waupuin), MILWAUKEE, OZAUKEE, MANITOWOC (Schleswig), WASHINGTON, AND WAUKESHA COUNTIES

	Rates	Fringes
Sound & Communications		
Installer	\$ 16.47	14.84
Technician	\$ 26.00	17.70

Installation, testing, maintenance, operation and servicing of all sound, intercom, telephone interconnect, closed circuit TV systems, radio systems, background music systems, language laboratories, electronic carillion, antenna distribution systems, clock and program systems and low-voltage systems such as visual nurse call, audio/visual nurse call systems, doctors entrance register systems. Includes all wire and cable carrying audio, visual, data, light and radio frequency signals. Includes the installation of conduit, wiremold, or raceways in existing structures that have been occupied for six months or more where required for the protection of the wire or cable, but does not mean a complete conduit or raceway system. work covered does not include the installation of conduit, wiremold or any raceways in any new construction, or the installation of power supply outlets by means of which external electric power is supplied to any of the foregoing equipment or products

ELEC0577-003 05/30/2016

CALUMET (except Township of New Holstein), GREEN LAKE (N. part including Townships of Berlin, St Marie, and Seneca), MARQUETTE (N. part including Townships of Crystal Lake, Neshkoro, Newton, and Springfield), OUTAGAMIE, WAUPACA, WAUSHARA, AND WINNEBAGO COUNTIES

	Rates	Fringes
Electricians:	\$ 30.68	17.28
ELEC0890-003 06/01/2016		

DODGE (Emmet Township only), GREEN, JEFFERSON, LAFAYETTE, RACINE (Burlington Township), ROCK AND WALWORTH COUNTIES

	Rates		Fringes
Electricians:	\$ 32.45	26.10%	+ \$10.56
ELEC0953-001 07/01/2015			
	Rates		Fringes
Line Construction:			

Line Construction:

(1) Lineman....\$ 42.14 32% + 5.00

(2) Heavy Equipment

Operator\$	40.03	32% + 5.00
(3) Equipment Operator\$	33.71	32% + 5.00
(4) Heavy Groundman Driver\$	26.78	14.11
(5) Light Groundman Driver\$	24.86	13.45
(6) Groundsman\$	23.18	32% + 5.00

ENGI0139-005 06/01/2016

	Rates	Fringes
Power Equipment Operator	± 22 25	01 00
Group 1	\$ 39.27	21.80
Group 2	\$ 38.77	21.80
Group 3		21.80
Group 4	\$ 38.01	21.80
Group 5		21.80
Group 6	\$ 31.82	21.80

HAZARDOUS WASTE PREMIUMS:

EPA Level "A" protection - \$3.00 per hour EPA Level "B" protection - \$2.00 per hour EPA Level "C" protection - \$1.00 per hour

POWER EQUIPMENT OPERATORS CLASSIFICATIONS

GROUP 1: Cranes, tower cranes, and derricks with or without attachments with a lifting capacity of over 100 tons; or cranes, tower cranes, and derricks with boom, leads and/or jib lengths measuring 176 feet or longer.

GROUP 2: Cranes, tower cranes and derricks with or without attachments with a lifting capacity of 100 tons or less; or cranes, tower cranes, and derricks with boom, leads, and/or jibs lengths measuring 175 feet or under and Backhoes (excavators) weighing 130,000 lbs and over; caisson rigs; pile driver; dredge operator; dredge engineer; Boat Pilot.

GROUP 3: Mechanic or welder - Heavy duty equipment; cranes with a lifting capacity of 25 tons or under; concrete breaker (manual or remote); vibratory/sonic concrete breaker; concrete laser screed; concrete slipform paver; concrete batch plant operator; concrete pvt. spreader heavy duty (rubber tired); concrete spreader & distributor; automatic subgrader (concrete); concrete grinder & planing machine; concrete slipform curb & gutter machine; slipform concrete placer; tube finisher; hydro blaster (10,000 psi & over); bridge paver; concrete conveyor system; concrete pump; Rotec type Conveyor; stabilizing mixer
(self-propelled); shoulder widener; asphalt plant engineer; bituminious paver; bump cutter & grooving machine; milling machine; screed (bituminous paver); asphalt heater, planer & scarifier; Backhoes (excavators) weighing under 130,000 lbs; grader or motor patrol; tractor (scraper, dozer, pusher, loader); scraper - rubber tired (single or twin engine); endloader; hydraulic backhoe (tractor type); trenching machine; skid rigs; tractor, side boom (heavy); drilling or boring machine (mechanical heavy); roller over 5 tons; percussion or rotary drilling machine; air track; blaster; loading machine (conveyor); tugger; boatmen; winches & A-frames; post driver; material hoist.

GROUP 4: Greaser, roller steel (5 tons or less); roller (pneumatic tired) - self propelled; tractor (mounted or towed compactors & light equipment); shouldering machine; self- propelled chip spreader; concrete spreader; finishing machine; mechanical float; curing machine; power subgrader; joint sawer (multiple blade) belting machine; burlap machine; texturing machine; tractor endloader (rubber tired) - light; jeep digger; forklift; mulcher; launch operator; fireman, environmental burner

GROUP 5: Air compressor; power pack; vibrator hammer and extractor; heavy equipment, leadman; tank car heaters; stump chipper; curb machine operator; Concrete proportioning plants; generators; mudjack operator; rock breaker; crusher or screening plant; screed (milling machine); automatic belt conveyor and surge bin; pug mill operator; Oiler, pump (over 3 inches); Drilling Machine Tender.

GROUP 6: Off-road material hauler with or without ejector.

IRON0008-002 06/01/2016 BROWN, CALUMET, DOOR, FOND DU LAC, KEWAUNEE, MANITOWOC, MARINETTE, OCONTO, OUTAGAMI, SHAWANO, SHEBOYGAN, AND WINNEBAGO Rates Fringes IRONWORKER....\$ 30.86 Paid Holidays: New Year's Day, Memorial Day, July 4th, Labor Day, Thanksgiving Day & Christmas Day. IRON0008-003 06/01/2016 KENOSHA, MILWAUKEE, OZAUKEE, RACINE, WALWORTH (N.E. 2/3), WASHINGTON, AND WAUKESHA COUNTIES Rates Fringes IRONWORKER....\$ 33.15 Paid Holidays: New Year's Day, Memorial Day, July 4th, Labor Day, Thanksgiving Day & Christmas Day. IRON0383-001 06/01/2015 ADAMS, COLUMBIA, CRAWFORD, DANE, DODGE, FLORENCE, FOREST, GRANT, GREENE, (Excluding S.E. tip), GREEN LAKE, IOWA, JEFFERSON, JUNEAU, LA CROSSE, LAFAYETTE, LANGLADE, MARATHON, MARQUETTE, MENOMINEE, MONROE, PORTAGE, RICHLAND, ROCK (Northern

area, vicinity of Edgerton and Milton), SAUK, VERNON, WAUPACA, WAUSHARA, AND WOOD COUNTIES

Rates Fringes IRONWORKER.....\$ 32.85 21.84 IRON0498-005 06/01/2008

GREEN (S.E. 1/3), ROCK (South of Edgerton and Milton), and WALWORTH (S.W. 1/3) COUNTIES:

Rates Fringes IRONWORKER.....\$ 34.34 25.72 IRON0512-008 05/01/2015

BARRON, BUFFALO, CHIPPEWA, CLARK, DUNN, EAU CLAIRE, JACKSON, PEPIN, PIERCE, POLK, RUSK, ST CROIX, TAYLOR, AND TREMPEALEAU COUNTIES

Rates Fringes IRONWORKER.....\$ 35.50 23.45 IRON0512-021 05/01/2015

ASHLAND, BAYFIELD, BURNETT, DOUGLAS, IRON, LINCOLN, ONEIDA, PRICE, SAWYER, VILAS AND WASHBURN COUNTIES

Rates Fringes IRONWORKER.....\$ 31.04 LABO0113-002 06/01/2016

MILWAUKEE AND WAUKESHA COUNTIES

Rates Fringes

LABORER Group 1 Group 2 Group 3 Group 4 Group 5 Group 6	\$ 27.66 \$ 27.86 \$ 28.01 \$ 28.16	20.35 20.35 20.35 20.35 20.35 20.35
LABORERS CLASSIFICATIONS		
GROUP 1: General Laborer; Tree Toemolition and Wrecking Laborer; Bridge Builder; Landscaper; Mult Stone Handler; Bituminous Worker Utility Man); Batch Truck Dumper Bituminous Worker (Dumper, Irone Concrete Handler	Guard Rail, Fer Liplate Culvert A (Shoveler, Load or Cement Hand	nce, and Assembler; der, and Ler;
GROUP 2: Air Tool Operator; Joseph (Pavement); Vibrator or Tamper (Operated); Chain Saw Operator; I Laborer	Operator (Mechan:	ical Hand
GROUP 3: Bituminous Worker (Rak (Curb, Sidewalk, and Pavement);	ker and Luteman) Strike Off Man	Formsetter
GROUP 4: Line and Grade Specialis	st	
GROUP 5: Blaster and Powderman		
GROUP 6: Flagperson; traffic cont	crol person	
LABO0113-003 06/01/2016		
OZAUKEE AND WASHINGTON COUNTIES		
OZAUKEE AND WASHINGION COUNTIES		
OZAUREE AND WASHINGTON COUNTIES	Rates I	Fringes
LABORER Group 1	\$ 26.76 \$ 26.86 \$ 26.91 \$ 27.11 \$ 26.96	20.35 20.35 20.35 20.35 20.35 20.35 20.35
LABORER Group 1	\$ 26.76 \$ 26.86 \$ 26.91 \$ 27.11 \$ 26.96	20.35 20.35 20.35 20.35 20.35
LABORER Group 1 Group 2 Group 3 Group 4 Group 5 Group 6	26.76 26.86 26.91 27.11 26.96 23.85 Trimmer; Conduit Guard Rail, Fer ciplate Culvert A	20.35 20.35 20.35 20.35 20.35 20.35 Layer; nce, and Assembler; der, and
Group 1	26.76 26.86 26.91 27.11 26.96 23.85 Trimmer; Conduit Guard Rail, Fer ciplate Culvert A c (Shoveler, Load or or Cement Handler, Smoother, and	20.35 20.35 20.35 20.35 20.35 20.35 c Layer; nce, and Assembler; der, and Ler; d Tamper);
Group 1	Trimmer; Conduit Guard Rail, Fer Guard Rail, Fer Guard Rail, Fer Conduit Guard Rail Guard	20.35 20.35 20.35 20.35 20.35 20.35 20.35 Layer; nce, and Assembler; der, and ler; d Tamper);
Group 1	Trimmer; Conduit 26.96 23.85 Trimmer; Conduit Guard Rail, Fer ciplate Culvert a (Shoveler, Loac or Cement Handler, Smoother, and er, Smoo	20.35 20.35 20.35 20.35 20.35 20.35 20.35 Layer; nce, and Assembler; der, and ler; d Tamper);
Group 1	Trimmer; Conduit 26.96 23.85 Trimmer; Conduit Guard Rail, Fer ciplate Culvert a (Shoveler, Loac or Cement Handler, Smoother, and er, Smoo	20.35 20.35 20.35 20.35 20.35 20.35 20.35 Layer; nce, and Assembler; der, and ler; d Tamper);
Group 1	Trimmer; Conduits Guard Rail, Fertiplate Culvert Act (Shoveler, Load or Cement Handler, Smoother, and Conduits Sawer and Fill Operator (Mechanist Strike Off Man	20.35 20.35 20.35 20.35 20.35 20.35 20.35 Layer; nce, and Assembler; der, and ler; d Tamper);
Group 1	Trimmer; Conduits Guard Rail, Fertiplate Culvert Act (Shoveler, Load or Cement Handler, Smoother, and Conduits Sawer and Fill Operator (Mechanist Strike Off Man	20.35 20.35 20.35 20.35 20.35 20.35 20.35 Layer; nce, and Assembler; der, and ler; d Tamper);
Group 1	Trimmer; Conduits Guard Rail, Fertiplate Culvert Act (Shoveler, Load or Cement Handler, Smoother, and Conduits Sawer and Fill Operator (Mechanist Strike Off Man	20.35 20.35 20.35 20.35 20.35 20.35 20.35 Layer; nce, and Assembler; der, and ler; d Tamper);

 $https://www.wdol.gov/wdol/scafiles/davisbacon/wi10.dvb [3/3/2017\ 6:56:36\ AM]$

Group 1......\$ 26.57 Group 2......\$ 26.72

LABORER

Rates Fringes

20.35 20.35

Group 3\$ 26	6.92 2	0.35
Group 4\$ 26	6.89 2	0.35
Group 5\$ 25	7.22 2	0.35
Group 6\$ 23	3.71 2	0.35

LABORERS CLASSIFICATIONS:

GROUP 1: General laborer; Tree Trimmer; Conduit Layer; Demolition and Wrecking Laborer; Guard Rail, Fence, and Bridge Builder; Landscaper; Multiplate Culvert Assembler; Stone Handler; Bituminous Worker (Shoveler, Loader, and Utility Man); Batch Truck Dumper or Cement Handler; Bituminous worker (Dumper, Ironer, Smoother, and Tamper); Concrete Handler

GROUP 2: Air Tool Operator; Joint Sawer and Filler (Pavement); Vibrator or Tamper Operator (Mechanical Hand Operated); Chain Saw Operator; Demolition Burning Torch Laborer

GROUP 3: Bituminous Worker (Raker and Luteman); Formsetter (Curb, Sidewalk, and Pavement); Strike Off Man

GROUP 4: Line and Grade Specialist

GROUP 5: Blaster and Powderman

GROUP 6: Flagman; traffic control person

LABO0140-002 06/01/2016

ADAMS, ASHLAND, BARRON, BAYFIELD, BROWN, BUFFALO, BURNETT, CALUMET, CHIPPEWA, CLARK, COLUMBIA, CRAWFORD, DODGE, DOOR, DOUGLAS, DUNN, EAU CLAIRE, FLORENCE, FOND DU LAC, FOREST, GRANT, GREEN, GREEN LAKE, IRON, JACKSON, JUNEAU, IOWA, JEFFERSON, KEWAUNEE, LA CROSSE, LAFAYETTE, LANGLADE, LINCOLN, MANITOWOC, MARATHON, MARINETTE, MARQUETTE, MENOMINEE, MONROE, OCONTO, ONEIDA, OUTAGAMIE, PEPIN, PIERCE, POLK, PORTAGE, PRICE, RICHLAND, ROCK, RUSK, SAUK, SAWYER, SHAWANO, SHEBOYGAN, ST. CROIX, TAYLOR, TREMPEALEAU, VERNON, VILLAS, WALWORTH, WASHBURN, WAUPACA, WAUSHARA, WINNEBAGO, AND WOOD COUNTIES

		Rates	Fringes
LABORER			
Group	1\$	30.67	16.55
Group	2	30.77	16.55
	3		16.55
Group	4	31.02	16.55
Group	5	30.87	16.55
Group	6	27.30	16.55

LABORER CLASSIFICATIONS

GROUP 1: General Laborer; Tree Trimmer; Conduit Layer; Demolition and Wrecking Laborer; Guard Rail, Fence, and Bridge Builder; Landscaper; Multiplate Culvert Assembler; Stone Handler; Bitminous Worker (Shoveler, Loader, and Utility Man); Batch Truck Dumper or Cement Handler; Bituminous Worker (Dumper, Ironer, Smoother and Tamper); Concrete Handler

GROUP 2: Air Tool Operator; Joint Sawer and Filler (Pavement); Vibrator or Tamper Operator (Mechanical Hand Operated); Chain Saw Operator, Demolition Burning Torch Laborer

GROUP 3: Bituminous Worker (Raker and Luteman); Formsetter (Curb, Sidewalk and Pavement); Strike Off Man

GROUP 4: Line and Grade Secialist

GROUP 5: Blaster; powderman

GROUP 6: Flagperson; Traffic Control

LABO0464-003 06/01/2016

2.2.2	Rates	Fringes
LABORER		5
Group 1 Group 2 Group 3 Group 4 Group 5 Group 6	.\$ 31.10 .\$ 31.30	16.41 16.41 16.41 16.41 16.41 16.41
LABORERS CLASSIFICATIONS:		
GROUP 1: General Laborer; Tre Demolition and Wrecking Labore Bridge Builder; Landscaper; Mu Stone Handler; Bituminous Work Utility Man); Batch Truck Dump Bituminious Worker (Dumper, Ir Concrete Handler	r; Guard Rail, I ltiplate Culvert er (Shoveler, Lo er or Cement Har	Fence, and Assembler; Dader, and Daller;
GROUP 2: Air Tool Operator; J (Pavement); Vibrator or Tamper Operated); Chain Saw Operator; Laborer	Operator (Mecha	anical Hand
GROUP 3: Bituminous Worker (R (Curb, Sidewalk, and Pavement)		
GROUP 4: Line and Grade Special	ist	
GROUP 5: Blaster; Powderman		
GROUP 6: Flagperson and Traffic	Control Person	
PAIN0106-008 05/02/2016		
ASHLAND, BAYFIELD, BURNETT, AND	DOUGLAS COUNTIES	5
	Rates	Fringes
Painters: New: Brush, Roller Spray, Sandblast, Steel Repaint:	.\$ 29.86 .\$ 30.46	16.35 16.35
Brush, Roller Spray, Sandblast, Steel	.\$ 28.96	16.35 16.35
PAIN0108-002 06/01/2016		
RACINE COUNTY		
	Rates	Fringes
Painters: Brush, Roller Spray & Sandblast	.\$ 33.74	18.70 18.70
PAIN0259-002 05/01/2008		
BARRON, CHIPPEWA, DUNN, EAU CLAI SAWYER, ST. CROIX, AND WASHBURN		CE, POLK, RUSK,
	Rates	Fringes
PAINTER	.\$ 24.11	12.15
PAIN0259-004 05/01/2015		
BUFFALO, CRAWFORD, JACKSON, LA C VERNON COUNTIES	ROSSE, MONROE, 5	FREMPEALEAU, AND
	Rates	Fringes
PAINTER		12.45

JEFFERSON, MILWAUKEE, OZAUKEE, WA	SHINGTON, AND W	AUKESHA COUNTIES
	Rates	Fringes
Painters: Bridge Brush Spray & Sandblast	\$ 30.07	22.19 22.19 22.19
PAIN0802-002 06/01/2016		
COLUMBIA, DANE, DODGE, GRANT, GREROCK, AND SAUK COUNTIES	EN, IOWA, LAFAY	ETTE, RICHLAND,
	Rates	Fringes
PAINTER Brush	\$ 27.50	17.72
PREMIUM PAY: Structural Steel, Spray, Bridge hour.	s = \$1.00 add	itional per
PAIN0802-003 06/01/2016		
ADAMS, BROWN, CALUMET, CLARK, DOO: LAKE, IRON, JUNEAU, KEWAUNEE, LAN MARATHON, MARINETTE, MARQUETTE, M. OUTAGAMIE, PORTAGE, PRICE, SHAWAN WAUSHARA, WAUPACA, WINNEBAGO, AND	GLADE, LINCOLN, ENOMINEE, OCON O, SHEBOYGAN,	MANITOWOC, TO, ONEIDA,
	Rates	Fringes
PAINTER	\$ 24.39	11.72
PAIN0934-001 06/01/2016		
KENOSHA AND WALWORTH COUNTIES		
	Rates	Fringes
	Races	riiiges
Painters: Brush	\$ 33.74	18.70 18.70 18.70
PAIN1011-002 06/01/2016		
FLORENCE COUNTY		
	Rates	Fringes
Painters:		11.93
PLAS0599-010 06/01/2016		
	Rates	Fringes
CEMENT MASON/CONCRETE FINISHER Area 1	\$ 35.07 \$ 35.61 \$ 34.70 \$ 36.27	17.17 19.75 19.40 20.51 18.73 22.99

AREA DESCRIPTIONS

AREA 1: BAYFIELD, DOUGLAS, PRICE, SAWYER, AND WASHBURN COUNTIES

AREA 2: ADAMS, ASHLAND, BARRON, BROWN, BURNETT, CALUMET, CHIPPEWA, CLARK, COLUMBIA, DODGE, DOOR, DUNN, FLORENCE, FOND DU LAC, FOREST, GREEN LAKE, IRON, JEFFERSON, KEWAUNEE, LANGLADE, LINCOLN, MANITOWOC, MARATHON, MARINETTE, MARQUETTE, MENOMINEE, OCONTO, ONEIDA, OUTAGAMIE, POLK,

PORTAGE, RUSK, ST CROIX, SAUK, SHAWANO, SHEBOYGAN, TAYLOR, VILAS, WALWORTH, WAUPACA, WAUSHARA, WINNEBAGO, AND WOOD COUNTIES

AREA 3: BUFFALO, CRAWFORD, EAU CLAIRE, JACKSON, JUNEAU, LA CROSSE MONROE, PEPIN, PIERCE, RICHLAND, TREMPEALEAU, AND VERNON COUNTIES

AREA 4: MILWAUKEE, OZAUKEE, WASHINGTON, AND WAUKESHA COUNTIES

AREA 5: DANE, GRANT, GREEN, IOWA, LAFAYETTE, AND ROCK COUNTIES

AREA 6: KENOSHA AND RACINE COUNTIES

TTRANSCOOK 001 06 /01 /0016

TEAM0039-001 06/01/2016

	Rates	Fringes
TRUCK DRIVER 1 & 2 Axles 3 or more Axles; Euclids Dumptor & Articulated,	.\$ 26.63	19.85
Truck Mechanic	.\$ 26.78	19.85
WELL DRILLER	.\$ 16.52	3.70

WELDERS - Receive rate prescribed for craft performing operation to which welding is incidental.

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at www.dol.gov/whd/govcontracts.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (ii)).

The body of each wage determination lists the classification and wage rates that have been found to be prevailing for the cited type(s) of construction in the area covered by the wage determination. The classifications are listed in alphabetical order of "identifiers" that indicate whether the particular rate is a union rate (current union negotiated rate for local), a survey rate (weighted average rate) or a union average rate (weighted union average rate).

Union Rate Identifiers

A four letter classification abbreviation identifier enclosed in dotted lines beginning with characters other than "SU" or "UAVG" denotes that the union classification and rate were prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2014. PLUM is an abbreviation identifier of the union which prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number

where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing the wage determination. 07/01/2014 is the effective date of the most current negotiated rate, which in this example is July 1, 2014.

Union prevailing wage rates are updated to reflect all rate changes in the collective bargaining agreement (CBA) governing this classification and rate.

Survey Rate Identifiers

Classifications listed under the "SU" identifier indicate that no one rate prevailed for this classification in the survey and the published rate is derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As this weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SULA2012-007 5/13/2014. SU indicates the rates are survey rates based on a weighted average calculation of rates and are not majority rates. LA indicates the State of Louisiana. 2012 is the year of survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. 5/13/2014 indicates the survey completion date for the classifications and rates under that identifier.

Survey wage rates are not updated and remain in effect until a new survey is conducted.

Union Average Rate Identifiers

Classification(s) listed under the UAVG identifier indicate that no single majority rate prevailed for those classifications; however, 100% of the data reported for the classifications was union data. EXAMPLE: UAVG-OH-0010 08/29/2014. UAVG indicates that the rate is a weighted union average rate. OH indicates the state. The next number, 0010 in the example, is an internal number used in producing the wage determination. 08/29/2014 indicates the survey completion date for the classifications and rates under that identifier.

A UAVG rate will be updated once a year, usually in January of each year, to reflect a weighted average of the current negotiated/CBA rate of the union locals from which the rate is based.

WAGE DETERMINATION APPEALS PROCESS

- 1.) Has there been an initial decision in the matter? This can be:
- * an existing published wage determination
- * a survey underlying a wage determination
- * a Wage and Hour Division letter setting forth a position on a wage determination matter
- * a conformance (additional classification and rate) ruling

On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour Regional Office for the area in which the survey was conducted because those Regional Offices have responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

Branch of Construction Wage Determinations Wage and Hour Division U.S. Department of Labor 200 Constitution Avenue, N.W. Washington, DC 20210

2.) If the answer to the question in 1.) is yes, then an

interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator U.S. Department of Labor 200 Constitution Avenue, N.W. Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board U.S. Department of Labor 200 Constitution Avenue, N.W. Washington, DC 20210

4.) All decisions by the Administrative Review Board are final.

END OF GENERAL DECISION

General Decision Number: WI170015 02/24/2017 WI15

Superseded General Decision Number: WI20160015

State: Wisconsin

Construction Type: Heavy

Counties: Wisconsin Statewide.

HEAVY CONSTRUCTION PROJECTS (Excluding Tunnel, Sewer, and Water

Lines).

Note: Under Executive Order (EO) 13658, an hourly minimum wage of \$10.20 for calendar year 2017 applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2015. If this contract is covered by the EO, the contractor must pay all workers in any classification listed on this wage determination at least \$10.20 (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on the contract in calendar year 2017. The EO minimum wage rate will be adjusted annually. Additional information on contractor requirements and worker protections under the EO is available at www.dol.gov/whd/govcontracts.

Modification I	Number	Publication	Date
0		01/06/2017	
1		02/03/2017	
2		02/10/2017	
3		02/24/2017	

BOIL0107-001 01/01/2016

	Rates	Fringes
BOILERMAKER Boilermaker Small Boiler Repair (under	.\$ 34.65	29.20
25,000 lbs/hr)	.\$ 26.91	16.00

BRWI0001-002 06/01/2016

CRAWFORD, JACKSON, JUNEAU, LA CROSSE, MONROE, TREMPEALEAU, AND VERNON COUNTIES

	Rates	Fringes	
BRICKLAYER	\$ 31.84	20.95	
BRWI0002-002 06/01/2016			

ASHLAND, BAYFIELD, DOUGLAS, AND IRON COUNTIES

	Rates	Fringes
BRICKLAYER	\$ 37.04	19.70
BRWI0002-005 06/01/2016		

ADAMS, ASHLAND, BARRON, BROWN, BURNETT, CALUMET, CHIPPEWA, CLARK, COLUMBIA, DODGE, DOOR, DUNN, FLORENCE, FOND DU LAC, FOREST, GREEN LAKE, IRON, JEFFERSON, KEWAUNEE, LANGLADE, LINCOLN, MANITOWOC, MARATHON, MARINETTE, MARQUETTE, MENOMINEE, OCONTO, ONEIDA, OUTAGAMIE, POLK, PORTAGE, RUSK, ST CROIX, SAUK, SHAWANO, SHEBOYGAN, TAYLOR, VILAS, WALWORTH, WAUPACA, WAUSHARA, WINNEBAGO, AND WOOD COUNTIES

	Rates	Fringes
CEMENT MASON/CONCRETE FINISHER.	\$ 35.07	20.51
BRWI0003-002 06/01/2016		

BROWN, DOOR, FLORENCE, KEWAUNEE, MARINETTE, AND OCONTO COUNTIES

Rates Fringes

BRICKLAYER		
	\$ 32.22	20.57
BRWI0004-002 06/01/2016		
KENOSHA, RACINE, AND WALWORTH	COUNTIES	
	Rates	Fringes
BRICKLAYER		21.49
BRWI0006-002 06/01/2016		
ADAMS, CLARK, FOREST, LANGLADE ONEIDA, PORTAGE, PRICE, TAYLOR		
	Rates	Fringes
BRICKLAYER	\$ 33.04	19.75
BRWI0007-002 06/01/2016		
GREEN, LAFAYETTE, AND ROCK COU	JNTIES	
	Rates	Fringes
BRICKLAYER		20.95
BRWI0008-002 06/01/2016		
MILWAUKEE, OZAUKEE, WASHINGTON	N, AND WAUKESHA	COUNTIES
	Rates	Fringes
BRICKLAYER	\$ 36.98	20.62
BRWI0009-001 06/01/2016		
GREEN LAKE, MARQUETTE, OUTAGAM AND WINNEBAGO COUNTIES	MIE, SHAWANO, W	AUPACA, WASHARA,
	Rates	Fringes
		5
BRICKLAYER	\$ 32.22	20.57
BRICKLAYER BRWI0011-002 06/01/2016	\$ 32.22	
BRWI0011-002 06/01/2016		20.57
BRWI0011-002 06/01/2016		20.57
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO	OC, AND SHEBOYG Rates	20.57 AN COUNTIES
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO	OC, AND SHEBOYG Rates	20.57 AN COUNTIES Fringes
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO BRICKLAYER	CC, AND SHEBOYG Rates	20.57 AN COUNTIES Fringes
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO BRICKLAYER	CC, AND SHEBOYG Rates	20.57 AN COUNTIES Fringes
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO BRICKLAYER	Rates\$ 32.22 ND COUNTIES Rates\$ 32.86	20.57 AN COUNTIES Fringes 20.57 Fringes 17.22
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO BRICKLAYER	Rates\$ 32.22 ND COUNTIES Rates\$ 32.86	20.57 AN COUNTIES Fringes 20.57 Fringes
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO BRICKLAYER BRWI0013-002 06/01/2015 DANE, GRANT, IOWA, AND RICHLAN BRICKLAYER BRICKLAYER BRWI0019-002 06/01/2016 BARRON, BUFFALO, BURNETT, CHIE	Rates\$ 32.22 ND COUNTIES Rates\$ 32.86	20.57 AN COUNTIES Fringes 20.57 Fringes 17.22
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO BRICKLAYER BRWI0013-002 06/01/2015 DANE, GRANT, IOWA, AND RICHLAN BRICKLAYER BRWI0019-002 06/01/2016 BARRON, BUFFALO, BURNETT, CHIE	Rates\$ 32.22 ND COUNTIES Rates\$ 32.86	20.57 AN COUNTIES Fringes 20.57 Fringes 17.22
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO BRICKLAYER	Rates \$ 32.22 ND COUNTIES Rates \$ 32.86 PPEWA, DUNN, EAR SAWYER AND WAS Rates \$ 31.98	20.57 AN COUNTIES Fringes 20.57 Fringes 17.22 U CLAIRE, PEPIN, SHBURN COUNTIES Fringes 20.81
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO BRICKLAYER	Rates \$ 32.22 ND COUNTIES Rates \$ 32.86 PPEWA, DUNN, EAR SAWYER AND WAS Rates \$ 31.98	20.57 AN COUNTIES Fringes 20.57 Fringes 17.22 U CLAIRE, PEPIN, SHBURN COUNTIES Fringes
BRWI0011-002 06/01/2016 CALUMET, FOND DU LAC, MANITOWO BRICKLAYER	Rates \$ 32.22 ND COUNTIES Rates \$ 32.86 PPEWA, DUNN, EAR SAWYER AND WAS Rates \$ 31.98	20.57 AN COUNTIES Fringes 20.57 Fringes 17.22 U CLAIRE, PEPIN, SHBURN COUNTIES Fringes 20.81
BRICKLAYER BRWI0013-002 06/01/2015 DANE, GRANT, IOWA, AND RICHLAN BRICKLAYER BRWI0019-002 06/01/2016 BARRON, BUFFALO, BURNETT, CHIPPIERCE, POLK, RUSK, ST. CROIX,	Rates \$ 32.22 ND COUNTIES Rates \$ 32.86 PPEWA, DUNN, EAR SAWYER AND WAS Rates \$ 31.98	20.57 AN COUNTIES Fringes 20.57 Fringes 17.22 U CLAIRE, PEPIN, SHBURN COUNTIES Fringes 20.81

COLUMBIA AND SAUK COUNTIES		
	Rates	Fringes
BRICKLAYER	\$ 32.86	17.22
* CARP0087-001 05/01/2016		
BURNETT (W. of Hwy 48), PIERCE (35, 48 & 65), AND ST. CROIX (W.	(W. of Hwy 29 of Hwy 65)	9), POLK (W. of Hwys COUNTIES
	Rates	Fringes
Carpenter & Piledrivermen	\$ 36.85	18.39
CARP0252-002 06/01/2016		
ADAMS, BARRON, BAYFIELD (Easter BURNETT (E. of Hwy 48), CALUMET, CRAWFORD, DANE, DODGE, DOOR, DUNATE BOTTON OF THE BOTTON OF THE BURNET, GREEN, GREEN LAKE, IOWA, JUNEAU, KEWAUNEE, LA CROSSE, LAE MANITOWOC, MARATHON, MARINETTE (MENOMINEE, MONROE, OCONTO, ONEIN OF Hwys 29 & 65), POLK (E. of Hwy PRICE, RICHLAND, ROCK, RUSK, SAU ST CROIX (E. of Hwy 65), TAYLOR, WALWORTH, WASHBURN, WAUPACA, WALCOUNTIES	CHIPPEWA, ON, EAU CLAID IN, EAU CLAID INON, JACKSOFAYETTE, LANGOR OUTAGAMIN VYS 35, 48 & JK, SAWYER, TREMPEALEAU	CLARK, COLUMBIA, RE, FLORENCE (except U LAC, FOREST, ON, JEFFERSON, GLADE, LINCOLN, corner), MARQUETTE, E, PEPIN, PIERCE (E. 65), PORTAGE, SHAWANO, SHEBOYGAN, U, VERNON, VILAS,
	Rates	Fringes
CARPENTER CARPENTER. MILLWRIGHT. PILEDRIVER.	\$ 33.56 \$ 35.08 \$ 34.12	18.00 18.35 18.00
CARP0252-010 06/01/2016		
ASHLAND COUNTY		
	Rates	Fringes
Carpenters Carpenter Millwright Pile Driver	\$ 33.56 \$ 35.08 \$ 34.12	18.00 18.35 18.00
CARP0264-003 06/01/2008		
KENOSHA, MILWAUKEE, OZAUKEE, RAC COUNTIES	CINE, WAUKES	HA, AND WASHINGTON
	Rates	Fringes
CARPENTER	\$ 30.52	14.41
CARP0361-004 05/01/2016		
BAYFIELD (West of Hwy 63) AND DO	OUGLAS COUNT	IES
	Rates	Fringes
CARPENTER	\$ 34.57	18.16
CARP2337-001 06/01/2008		
ZONE A: MILWAUKEE, OZAUKEE, WAUK	KESHA AND WA	SHINGTON
ZONE B: KENOSHA & RACINE		

PILEDRIVERMAN

Rates Fringes

Zone A		19.46 19.46
CARP2337-003 06/02/2008		
	Rates	Fringes
MILLWRIGHT Zone A Zone B	.\$ 27.92 .\$ 26.82	19.08 19.08
ZONE DEFINITIONS		
ZONE A: MILWAUKEE, OZAUKEE, WAUF	CESHA AND WASH	INGTON COUNTIES
ZONE B: KENOSHA & RACINE COUNTIE	IS	
ELEC0014-002 05/30/2016		
ASHLAND, BARRON, BAYFIELD, BUFFALO, BURNETT, CHIPPEWA, CLARK (except Maryville, Colby, Unity, Sherman, Fremont, Lynn & Sherwood), CRAWFORD, DUNN, EAU CLAIRE, GRANT, IRON, JACKSON, LA CROSSE, MONROE, PEPIN, PIERCE, POLK, PRICE, RICHLAND, RUSK, ST CROIX, SAWYER, TAYLOR, TREMPEALEAU, VERNON, AND WASHBURN COUNTIES		
	Rates	Fringes
Electricians:	.\$ 32.00	19.28
ELEC0014-007 05/30/2016		
REMAINING COUNTIES		
	Rates	Fringes
Teledata System Installer Installer/Technician	.\$ 24.35	13.15
Low voltage construction, instremoval of teledata facilities including outside plant, telepinterconnect, terminal equipmer fiber optic cable and equipmer bypass, CATV, WAN (wide area networks), and ISDN (integrate	s (voice, data, phone and data ent, central of it, micro waves networks), LAN	, and video) inside wire, Efices, PABX, s, V-SAT, (local area
ELEC0127-002 06/01/2016		
KENOSHA COUNTY		
	Rates	Fringes
Electricians:		5
ELEC0158-002 05/30/2016		
BROWN, DOOR, KEWAUNEE, MANITOWOC (except Schleswig), MARINETTE(Wausuakee and area South thereof), OCONTO, MENOMINEE (East of a ine 6 miles West of the West boundary of Oconto County), SHAWANO (Except Area North of Townships of Aniwa and Hutchins) COUNTIES		
	Rates	Fringes
Electricians:	.\$ 30.50	9.50% + 9.57
ELEC0159-003 05/30/2016		
COLUMBIA, DANE, DODGE (Area West of Hwy 26, except Chester and Emmet Townships), GREEN, LAKE (except Townships of Berlin, Seneca, and St. Marie), IOWA, MARQUETTE (except Townships of Neshkoka, Crystal Lake, Newton, and Springfield), and SAUK COUNTIES		

https://www.wdol.gov/wdol/scafiles/davisbacon/wi15.dvb[3/3/2017 6:55:51 AM]

Rates Fringes

Electricians:	\$ 36.50 	20.39	
ELEC0219-004 06/01/2015			
FLORENCE COUNTY (Townships of Auro Florence and Homestead) AND MARIN Niagara)	ora, Commonwea ETTE COUNTY (1	alth, Fern, Township of	
	Rates	Fringes	
Electricians:			
Electrical contracts over \$180,000	\$ 31.16	18.34	
	\$ 28.96	18.26	
ELEC0242-005 05/29/2016			
DOUGLAS COUNTY			
	Rates	Fringes	
Electricians:	\$ 34.92	25.05	
ELEC0388-002 06/01/2013			
ADAMS, CLARK (Colby, Freemont, Lyn Sherwood, Unity), FOREST, JUNEAU MARINETTE (Beecher, Dunbar, Goodma West of a line 6 miles West of the County), ONEIDA, PORTAGE, SHAWANO AND WOOD COUNTIES	, LANGLADE, LI an & Pembine), e West boundar	INCOLN, MARATHON, MENOMINEE (Area ry of Oconto	
	Rates	Fringes	
Electricians:	\$ 28.96 24.	.85% + 9.70	
ELEC0430-002 06/01/2016			
RACINE COUNTY (Except Burlington	Township)		
	Rates	Fringes	
Electricians:	\$ 36.07	21.84	
ELEC0494-005 06/01/2016			
MILWAUKEE, OZAUKEE, WASHINGTON, AND WAUKESHA COUNTIES			
	Rates	Fringes	
Electricians:	\$ 36.01	24.00	
ELEC0494-006 06/01/2014			
CALUMET (Township of New Holstein including Chester Township), FOND (Schleswig), and SHEBOYGAN COUNTI	DU LAC, MANIT	c of Hwy 26 TOWOC	
	Rates	Fringes	
Electricians:	\$ 29.64	20.54	
ELEC0494-013 06/01/2015			
DODGE (East of Hwy 26 including Cl Twp), FOND DU LAC (Except Waupuin MANITOWOC (Schleswig), WASHINGTON			
	, AND WAUKESHA	A COUNTIES	
	, AND WAUKESHA	A COUNTIES Fringes	
Sound & Communications InstallerTechnician	, AND WAUKESHA	A COUNTIES Fringes	

of all sound, intercom, telephone interconnect, closed circuit TV systems, radio systems, background music systems, language laboratories, electronic carillion, antenna distribution systems, clock and program systems and low-voltage systems such as visual nurse call, audio/visual nurse call systems, doctors entrance register systems. Includes all wire and cable carrying audio, visual, data, light and radio frequency signals. Includes the installation of conduit, wiremold, or raceways in existing structures that have been occupied for six months or more where required for the protection of the wire or cable, but does not mean a complete conduit or raceway system. work covered does not include the installation of conduit, wiremold or any raceways in any new construction, or the installation of power supply outlets by means of which external electric power is supplied to any of the foregoing equipment or products

ELEC0577-003 05/30/2016

CALUMET (except Township of New Holstein), GREEN LAKE (N. part including Townships of Berlin, St Marie, and Seneca), MARQUETTE (N. part including Townships of Crystal Lake, Neshkoro, Newton, and Springfield), OUTAGAMIE, WAUPACA, WAUSHARA, AND WINNEBAGO COUNTIES

	Rates	Fringes	
Electricians:	\$ 30.68	17.28	
ELEC0890-003 06/01/2016			

DODGE (Emmet Township only), GREEN, JEFFERSON, LAFAYETTE, RACINE (Burlington Township), ROCK AND WALWORTH COUNTIES

	Rates	Fringes	
Electricians:	\$ 32.45	26.10% + \$10.56	
ELEC0953-001 07/01/20	 015		

	Rates	Fringes
Line Construction: (1) Lineman		32% + 5.00
Operator	\$ 33.71 \$ 26.78 \$ 24.86	32% + 5.00 32% + 5.00 14.11 13.45 32% + 5.00

ENGI0139-001 06/01/2016

 $\mathtt{KENOSHA}\,,\,\,\mathtt{MILWAUKEE}\,,\,\,\mathtt{OZAUKEE}\,,\,\,\mathtt{RACINE}\,,\,\,\mathtt{WASHINGTON}\,,\,\,\mathtt{AND}\,\,\mathtt{WAUKESHA}\,\,\mathtt{COUNTIES}$

		Rates	Fringes
Group 2 Group 3 Group 4 Group 5	Operator	\$ 42.71 \$ 42.21 \$ 41.52 \$ 39.34	20.40 20.40 20.40 20.40 20.40 20.40

HAZARDOUS WASTE PREMIUMS:

EPA Level "A" Protection: \$3.00 per hour EPA Level "B" Protection: \$2.00 per hour EPA Level "C" Protection: \$1.00 per hour

POWER EQUIPMENT OPERATORS CLASSIFICATIONS

GROUP 1: Cranes, Tower Cranes, Pedestal Tower Cranes and Derricks with or w/o attachments with a lifting capacity of over 100 tons; or Cranes, Tower Cranes, Pedestal Tower

Cranes and Derricks with boom, leads, and/or jib lengths measuring 176 feet or longer; Self-Erecting Tower Cranes over 4000 lbs lifting capacity; All Cranes with Boom Dollies; Boring Machines (directional); Master Mechanic. \$0.50 additional per hour per 100 tons or 100 ft of boom over 200 ft or lifting capacity of crane over 200 tons to a maximum of 300 tons or 300 ft. Thereafter an increase of \$0.01 per ft or ton, whichever is greater.

- ${\tt GROUP~2:}~{\tt Cranes},~{\tt Tower~Cranes},~{\tt Pedestal~Tower~Cranes}$ and ${\tt Derricks~with~or~without~attachments~with~a~lifting}$ capacity of 100 tons or less; or Cranes, Tower Cranes Portable Tower Cranes, Pedestal Tower Cranes and Derricks with boom, leadsand/or jib lengths measuring 175 feet or less; Backhoes (excavators) 130,000 lbs and over; Caisson Rigs; Pile Drivers; Boring Machines (vertical or horizontal), Versi-Lift, Tri-Lift, Gantry 20,000 lbs & over.
- GROUP 3: Backhoe (excavator) under 130,000 lbs; Self-erecting Tower Crane 4000 lbs & under lifting capacity; Traveling Crane (bridge type); Skid Rigs; Dredge Operator; Mechanic; Concrete Paver (over 27E); Concrete Spreader and Distributor; Forklift/ Telehandler (machinery- moving / steel erection); Hydro Blaster, 10,000 psi and over
- GROUP 4: Material Hoists; Stack Hoists; Hydraulic Backhoe (tractor or truck mounted); Hydraulic Crane, 5 tons or under (tractor or truck mounted); Hoist (tuggers 5 tons & over); Hydro-Excavators/Daylighters; Concrete Pumps Rotec type Conveyors; Tractor/Bulldozer/End Loader (over 40 hp); Motor Patrol; Scraper Operator; Sideboom; Straddle Carrier; Welder; Bituminous Plant and Paver Operator; Roller over 5 tons; Rail Leveling Machine (Railroad); Tie Placer; Tie Extractor; Tie Tamper; Stone Leveler; Rotary Drill Operator and Blaster; Percussion Drill Operator; Air Track Drill and/or Hammers; Gantrys (under 20,000 lbs); Tencher (wheel type or chain type having 8 inch or larger bucket); Milling Machine; Off-Road Material Haulers.
- GROUP 5: Backfiller; Concrete Auto Breaker (large); Concrete Finishing Machines (road type); Rubber Tired Roller; Concrete Batch Hopper; Concrete Conveyor Systems; Grout Pumps; Concrete Mixers (14S or over); Screw Type Pumps and Gypsum Pumps; Tractor, Bulldozer, End Loader (under 40 hp); Trencher (chain type, bucket under 8 inch); Industrial Locomotives; Rollers under 5 tons; Stump Grinder/Chipper (Large); Timber Equipment; Firemen (pile drivers and derricks); Personnel Hoist, Telehandler over 8000 lbs; Robotic Tool Carrier with or without attachments
- GROUP 6: Tampers Compactors (riding type); Assistant Engineer; A-Frames and Winch Trucks; Concrete Auto Breaker; Hydrohammers (small); Brooms and Sweepers; Hoist (tuggers under 5 tons); Boats (Tug, Safety, Work Barges, Launch); Shouldering Machine Operator; Prestress Machines; Screed Operator; Stone Crushers and Screening Plants; Screed Operators (milling machine), Farm or Industrial Tractor Mounted Equipment; Post Hole Digger; Fireman (asphalt plants); Air Compressors over 400 CFM; Generators, over 150 KW; Augers (vertical and horizontal); Air, Electric, Hydraulic Jacks (slipform); Skid Steer Loaders (with or without attachments); Boiler Operators (temporary heat); Refrigeration Plant/Freeze Machines; Power Pack Vibratory/Ultra Sound Drivers and Extractors; Welding Machines; Heaters (mechanical); Pumps; Winches (small electric); Oiler and Greaser; Rotary Drill Tender; Conveyor; Forklifts/Telehandler 8000 lbs & under; Elevators: Automatic Hoists; Pumps (well points); Combination Small Equipment Operators

ENGI0139-003 06/01/2016

REMAINING COUNTIES

	Rates	Fringes
Power Equipment Operator		
Group 1	.\$ 38.72	20.60
Group 2	.\$ 37.47	20.60
Group 3		20.60

Group 4\$	35.74	20.60
Group 5\$	33.67	20.60
Group 6\$	33.04	20.60

HAZARDOUS WASTE PREMIUMS:

EPA Level "A" Protection: \$3.00 per hour EPA Level "B" Protection: \$2.00 per hour EPA Level "C" Protection: \$1.00 per hour

POWER EQUIPMENT OPERATORS CLASSIFICATIONS

GROUP 1: Cranes, Tower Cranes and Derricks with or without attachments with a lifting capacity of over 100 tons; Cranes, Tower Cranes, and Derricks with boom, leads and/or jib lengths 176 ft or longer.

GROUP 2: Backhoes (Excavators) weighing 130,00 lbs and over; Cranes, Tower Cranes and Derricks with or without attachments with a lifting capacity of 100 tons or less; Cranes, Tower Cranes, and Derricks with boom, leads, and/or jib lengths 175 ft or less; Caisson Rigs; Pile Driver

GROUP 3: Backhoes (Excavators) weighing under 130,000 lbs; Travelling Crane (bridge type); Milling Machine; Concrete Paver over 27 E; Concrete Spreader and Distributor; Concrete Laser Screed; Concrete Grinder and Planing Machine; Slipform Curb and Gutter Machine; Boring Machine (Directional); Dredge Operator; Skid Rigs; over 46 meter Concrete Pump.

GROUP 4: Hydraulic Backhoe (tractor or truck mounted); Hydraulic Crane, 10 tons or less; Tractor, Bulldozer, or End Loader (over 40 hp); Motor Patrol; Scraper Operator; Bituminous Plant and Paver Operator; Screed-Milling Machine; Roller over 5 tons; Concrete pumps 46 meter and under; Grout Pumps; Rotec type machine; Hydro Blaster, 10,000 psi and over; Rotary Drill Operator; Percussion Drilling Machine; Air Track Drill with or without integral hammer; Blaster; Boring Machine (vertical or horizontal); Side Boom; Trencher, wheel type or chain type having 8 inch or larger bucket; Rail Leveling Machine (Railroad); Tie Placer; Tie Extractor; Tie Tamper; Stone Leveler; Straddle Carrier; Material Hoists; Stack Hoist; Man Hoists; Mechanic and Welder; Off Road Material Haulers.

GROUP 5: Tractor, Bulldozer, or Endloader (under 40 hp); Tampers -Compactors, riding type; Stump Chipper, large; Roller, Rubber Tire; Backfiller; Trencher, chain type (bucket under 8 inch); Concrete Auto Breaker, large; Concrete Finishing Machine (road type); Concrete Batch Hopper; Concrete Conveyor Systems; Concrete Mixers, 14S or over; Pumps, Screw Type and Gypsum); Hydrohammers, small; Brooms and Sweeeprs; Lift Slab Machine; Roller under 5 tons; Industrial Locomotives; Fireman (Pile Drivers and Derricks); Pumps (well points); Hoists, automatic; A-Frames and Winch Trucks; Hoists (tuggers); Boats (Tug, Safety, Work Barges and Launches); Assistant Engineer

GROUP 6: Shouldering Machine Operator; Farm or Industrial Tractor mounted equipment; Post Hole Digger; Auger (vertical and horizontal); Skid Steer Loader with or without attachments; Robotic Tool Carrier with or without attachments; Power Pack Vibratory/Ultra Sound Driver and Extractor; Fireman (Asphalt Plants); Screed Operator; Stone Crushers and Screening Plants; Air, Electric, Hydraulic Jacks (Slip Form); Prestress Machines; Air Compressor, 400 CFM or over; Refrigeration Plant/Freese Machine; Boiler Operators (temporary heat); Forklifts; Welding Machines; Generators; Pumps over 3"; Heaters, Mechanical; Combination small equipment operator; Winches, small electric; Oiler; Greaser; Rotary Drill Tender; Conveyor; Elevator Operator

IRON0008-002 06/01/2016

BROWN, CALUMET, DOOR, FOND DU LAC, KEWAUNEE, MANITOWOC, MARINETTE, OCONTO, OUTAGAMI, SHAWANO, SHEBOYGAN, AND WINNEBAGO COUNTIES:

> Rates Fringes

IRONWORKER	\$ 30.86	25.42
Paid Holidays: New Year's Day Day, Thanksgiving Day & Chris	, Memorial tmas Day.	Day, July 4th, Labor
IRON0008-003 06/01/2016		
KENOSHA, MILWAUKEE, OZAUKEE, RA WASHINGTON, AND WAUKESHA COUNTI		RTH (N.E. 2/3),
	Rates	Fringes
IRONWORKER	\$ 33.15	25.42
Paid Holidays: New Year's Day Day, Thanksgiving Day & Chris	, Memorial tmas Day.	Day, July 4th, Labor
IRON0383-001 06/01/2015		
ADAMS, COLUMBIA, CRAWFORD, DANE GRANT, GREENE, (Excluding S.E. JEFFERSON, JUNEAU, LA CROSSE, L MARQUETTE, MENOMINEE, MONROE, P area, vicinity of Edgerton and WAUSHARA, AND WOOD COUNTIES	tip), GREEN AFAYETTE, L ORTAGE, RIC	LAKE, IOWA, ANGLADE, MARATHON, HLAND, ROCK (Northern
	Rates	Fringes
IRONWORKER	\$ 32.85	21.84
IRON0512-008 05/01/2015		
BARRON, BUFFALO, CHIPPEWA, CLAR PEPIN, PIERCE, POLK, RUSK, ST C COUNTIES	K, DUNN, EA ROIX, TAYLO	U CLAIRE, JACKSON, R, AND TREMPEALEAU
	Rates	Fringes
IRONWORKER	\$ 35.50	23.45
IRON0512-021 05/01/2015		
ASHLAND, BAYFIELD, BURNETT, DOU PRICE, SAWYER, VILAS AND WASHB		
	Rates	Fringes
IRONWORKER		23.45
LABO0113-002 06/01/2016		
MILWAUKEE AND WAUKESHA COUNTIES		
	Rates	Fringes
LABORER Group 1	\$ 27.66 \$ 27.86 \$ 28.01 \$ 28.16	20.35 20.35 20.35 20.35 20.35 20.35
LABORERS CLASSIFICATIONS		
GROUP 1: General Laborer; Tre Demolition and Wrecking Labor Bridge Builder: Landscaper: M	er; Guard R	ail, Fence, and

L

Bridge Builder; Landscaper; Multiplate Culvert Assembler; Stone Handler; Bituminous Worker (Shoveler, Loader, and Utility Man); Batch Truck Dumper or Cement Handler; Bituminous Worker (Dumper, Ironer, Smoother, and Tamper); Concrete Handler

GROUP 2: Air Tool Operator; Joint Sawer and Filler

(Pavement); Vibrator or Tamper Operator (Mechanical Hand Operated); Chain Saw Operator; Demolition Burning Torch Laborer

GROUP 3: Bituminous Worker (Raker and Luteman); Formsetter (Curb, Sidewalk, and Pavement); Strike Off Man

GROUP 4: Line and Grade Specialist

GROUP 5: Blaster and Powderman

GROUP 6: Flagperson; traffic control person

LABO0113-003 06/01/2016

OZAUKEE AND WASHINGTON COUNTIES

		Rates	Fringes
LABORER			
Group	1	3 26.76	20.35
Group	2	26.86	20.35
Group	3	3 26.91	20.35
	4		20.35
Group	5	26.96	20.35
	6		20.35

LABORERS CLASSIFICATIONS

GROUP 1: General Laborer; Tree Trimmer; Conduit Layer; Demolition and Wrecking Laborer; Guard Rail, Fence, and Bridge Builder; Landscaper; Multiplate Culvert Assembler; Stone Handler; Bituminous Worker (Shoveler, Loader, and Utility Man); Batch Truck Dumper or Cement Handler; Bituminous Worker (Dumper, Ironer, Smoother, and Tamper); Concrete Handler

GROUP 2: Air Tool Operator; Joint Sawer and Filler
(Pavement); Vibrator or Tamper Operator (Mechanical Hand
Operated);

GROUP 3: Bituminous Worker (Raker and Luteman); Formsetter (Curb, Sidewalk, and Pavement); Strike Off Man

GROUP 4: Line and Grade Specialist

GROUP 5: Blaster; powderman

GROUP 6: Flagperson and Traffic Control Person

LABO0113-011 06/01/2016

KENOSHA AND RACINE COUNTIES

		Rates	Fringes
LABORER			
Group	1	\$ 26.57	20.35
Group	2	\$ 26.72	20.35
Group	3	\$ 26.92	20.35
	4		20.35
	5		20.35
	6	•	20.35

LABORERS CLASSIFICATIONS:

GROUP 1: General laborer; Tree Trimmer; Conduit Layer; Demolition and Wrecking Laborer; Guard Rail, Fence, and Bridge Builder; Landscaper; Multiplate Culvert Assembler; Stone Handler; Bituminous Worker (Shoveler, Loader, and Utility Man); Batch Truck Dumper or Cement Handler; Bituminous worker (Dumper, Ironer, Smoother, and Tamper); Concrete Handler

GROUP 2: Air Tool Operator; Joint Sawer and Filler (Pavement); Vibrator or Tamper Operator (Mechanical Hand Operated); Chain Saw Operator; Demolition Burning Torch Laborer

GROUP 3: Bituminous Worker (Raker and Luteman); Formsetter (Curb, Sidewalk, and Pavement); Strike Off Man

GROUP 4: Line and Grade Specialist

GROUP 5: Blaster and Powderman

GROUP 6: Flagman; traffic control person

LABO0140-002 06/01/2016

ADAMS, ASHLAND, BARRON, BAYFIELD, BROWN, BUFFALO, BURNETT, CALUMET, CHIPPEWA, CLARK, COLUMBIA, CRAWFORD, DODGE, DOOR, DOUGLAS, DUNN, EAU CLAIRE, FLORENCE, FOND DU LAC, FOREST, GRANT, GREEN, GREEN LAKE, IRON, JACKSON, JUNEAU, IOWA, JEFFERSON, KEWAUNEE, LA CROSSE, LAFAYETTE, LANGLADE, LINCOLN, MANITOWOC, MARATHON, MARINETTE, MARQUETTE, MENOMINEE, MONROE, OCONTO, ONEIDA, OUTAGAMIE, PEPIN, PIERCE, POLK, PORTAGE, PRICE, RICHLAND, ROCK, RUSK, SAUK, SAWYER, SHAWANO, SHEBOYGAN, ST. CROIX, TAYLOR, TREMPEALEAU, VERNON, VILLAS, WALWORTH, WASHBURN, WAUPACA, WAUSHARA, WINNEBAGO, AND WOOD COUNTIES

	I	Rates	Fringes
LABORER			
Group	1\$	30.67	16.55
Group	2\$	30.77	16.55
	3\$		16.55
Group	4\$	31.02	16.55
Group	5\$	30.87	16.55
Group	6\$	27.30	16.55

LABORER CLASSIFICATIONS

GROUP 1: General Laborer; Tree Trimmer; Conduit Layer; Demolition and Wrecking Laborer; Guard Rail, Fence, and Bridge Builder; Landscaper; Multiplate Culvert Assembler; Stone Handler; Bitminous Worker (Shoveler, Loader, and Utility Man); Batch Truck Dumper or Cement Handler; Bituminous Worker (Dumper, Ironer, Smoother and Tamper); Concrete Handler

GROUP 2: Air Tool Operator; Joint Sawer and Filler (Pavement); Vibrator or Tamper Operator (Mechanical Hand Operated); Chain Saw Operator, Demolition Burning Torch Laborer

GROUP 3: Bituminous Worker (Raker and Luteman); Formsetter (Curb, Sidewalk and Pavement); Strike Off Man

GROUP 4: Line and Grade Secialist

GROUP 5: Blaster; powderman

GROUP 6: Flagperson; Traffic Control

LABO0464-003 06/01/2016

DANE COUNTY

		Rates	Fringes
LABORER		+ 22 25	16.41
	1		16.41
Group	2	.\$ 31.05	16.41
	3		16.41
Group	4	.\$ 31.30	16.41
Group	5	.\$ 31.15	16.41
Group	6	.\$ 27.30	16.41

LABORERS CLASSIFICATIONS:

GROUP 1: General Laborer; Tree Trimmer; Conduit Layer; Demolition and Wrecking Laborer; Guard Rail, Fence, and Bridge Builder; Landscaper; Multiplate Culvert Assembler; Stone Handler; Bituminous Worker (Shoveler, Loader, and Utility Man); Batch Truck Dumper or Cement Handler; Bituminious Worker (Dumper, Ironer, Smoother, and Tamper);

Concrete Handler

GROUP 2: Air Tool Operator; Joint Sawer and Filler (Pavement); Vibrator or Tamper Operator (Mechanical Hand Operated); Chain Saw Operator; Demolition Burning Torch Laborer

GROUP 3: Bituminous Worker (Raker and Luteman); Formsetter (Curb, Sidewalk, and Pavement); Strike Off Man

GROUP 4: Line and Grade Specialist

GROUP 5: Blaster; Powderman

GROUP 6: Flagperson and Traffic Control Person

PAIN0106-008 05/02/2016

ASHLAND, BAYFIELD, BURNETT, AND DOUGLAS COUNTIES

		Rates	Fringes
Painters:			
New:			
Brush,	Roller\$	29.86	16.35
Spray,	Sandblast, Steel\$	30.46	16.35
Repaint			
	Roller\$	28.36	16.35
	Sandblast, Steel\$		16.35
<i></i>	·		

PAIN0108-002 06/01/2016

RACINE COUNTY

	Rates	Fringes	
Painters: Brush, Roller	\$ 32 74	18.70	
Spray & Sandblast		18.70	

PAIN0259-002 05/01/2008

BARRON, CHIPPEWA, DUNN, EAU CLAIRE, PEPIN, PIERCE, POLK, RUSK, SAWYER, ST. CROIX, AND WASHBURN COUNTIES

	Rates	Fringes	
PAINTER	\$ 24.11	12.15	
PAIN0259-004 05/01/2015			

BUFFALO, CRAWFORD, JACKSON, LA CROSSE, MONROE, TREMPEALEAU, AND VERNON COUNTIES

	Rates	Fringes
PAINTER	\$ 22.03	12.45
PAIN0781-002 06/01/2016		

JEFFERSON, MILWAUKEE, OZAUKEE, WASHINGTON, AND WAUKESHA COUNTIES

	Rates	Fringes	
Painters: Bridge	\$ 30.07	22.19 22.19 22.19	_

PAIN0802-002 06/01/2016

COLUMBIA, DANE, DODGE, GRANT, GREEN, IOWA, LAFAYETTE, RICHLAND, ROCK, AND SAUK COUNTIES

Rates Fringes

PAINTER

PREMIUM PAY:

Structural Steel, Spray, Bridges = \$1.00 additional per hour.

PAIN0802-003 06/01/2016

ADAMS, BROWN, CALUMET, CLARK, DOOR, FOND DU LAC, FOREST, GREEN LAKE, IRON, JUNEAU, KEWAUNEE, LANGLADE, LINCOLN, MANITOWOC, MARATHON, MARINETTE, MARQUETTE, MENOMINEE, OCONTO, ONEIDA, OUTAGAMIE, PORTAGE, PRICE, SHAWANO, SHEBOYGAN, TAYLOR, VILAS, WAUSHARA, WAUPACA, WINNEBAGO, AND WOOD COUNTIES

	Rates	Fringes
PAINTER	.\$ 24.39	11.72
PAIN0934-001 06/01/2016		

KENOSHA AND WALWORTH COUNTIES

	Rates	Fringes
Painters: Brush	.\$ 33.74	18.70 18.70 18.70

PAIN1011-002 06/01/2016

FLORENCE COUNTY

	Rates	Fringes	
Painters:	\$ 24.56	11.93	

PLAS0599-010 06/01/2016

	Rates	Fringes
CEMENT MASON/CONCRETE FINISHER		
Area 1		17.17
Area 2 (BAC)		19.75
Area 3		19.40
Area 4		20.51
Area 5		18.73
Area 6	\$ 32.02	22.99

AREA DESCRIPTIONS

AREA 1: BAYFIELD, DOUGLAS, PRICE, SAWYER, AND WASHBURN COUNTIES

AREA 2: ADAMS, ASHLAND, BARRON, BROWN, BURNETT, CALUMET, CHIPPEWA, CLARK, COLUMBIA, DODGE, DOOR, DUNN, FLORENCE, FOND DU LAC, FOREST, GREEN LAKE, IRON, JEFFERSON, KEWAUNEE, LANGLADE, LINCOLN, MANITOWOC, MARATHON, MARINETTE, MARQUETTE, MENOMINEE, OCONTO, ONEIDA, OUTAGAMIE, POLK, PORTAGE, RUSK, ST CROIX, SAUK, SHAWANO, SHEBOYGAN, TAYLOR, VILAS, WALWORTH, WAUPACA, WAUSHARA, WINNEBAGO, AND WOOD COUNTIES

AREA 3: BUFFALO, CRAWFORD, EAU CLAIRE, JACKSON, JUNEAU, LA CROSSE MONROE, PEPIN, PIERCE, RICHLAND, TREMPEALEAU, AND VERNON COUNTIES

AREA 4: MILWAUKEE, OZAUKEE, WASHINGTON, AND WAUKESHA COUNTIES

AREA 5: DANE, GRANT, GREEN, IOWA, LAFAYETTE, AND ROCK COUNTIES

AREA 6: KENOSHA AND RACINE COUNTIES

PLUM0011-003 05/02/2016

ASHLAND, BAYFIELD, BURNETT, DOUGLAS, IRON, SAWYER, AND WASHBURN

	Rates	Fringes
PLUMBER	.\$ 39.07	18.73
PLUM0075-002 06/01/2016		
MILWAUKEE, OZAUKEE, WASHINGTON,	AND WAUKESHA COU	UNTIES
	Rates	Fringes
PLUMBER	.\$ 40.27	21.47
PLUM0075-004 06/01/2016		
DODGE (Watertown), GREEN, JEFFER COUNTIES	RSON, LAFAYETTE,	AND ROCK
	Rates	Fringes
PLUMBER	.\$ 40.52	21.47
PLUM0075-009 06/01/2016		
COLUMBIA, DANE, IOWA, MARQUETTE,	RICHLAND AND SA	AUK COUNTIES
	Rates	Fringes
PLUMBER	.\$ 38.82	20.12
PLUM0111-007 06/01/2016		
MARINETTE COUNTY (Niagara only)		
	Rates	Fringes
PLUMBER/PIPEFITTER	.\$ 32.19	21.28
PLUM0118-002 06/01/2016		
KENOSHA, RACINE, AND WALWORTH CO	DUNTIES	
	Rates	Fringes
Plumber and Steamfitter	.\$ 40.95	19.95
PLUM0400-003 05/30/2016		
ADAMS, BROWN, CALUMET, DODGE (exc LAC, GREEN LAKE, KEWAUNEE, MANITO Niagara), MENOMINEE, OCONTO, OUT WAUPACA, WAUSHARA, AND WINNEBAGO	OWOC, MARINETTE CAGAMIE, SHAWANO	(except
	Rates	Fringes
PLUMBER/PIPEFITTER	.\$ 34.39	17.65
PLUM0434-002 05/29/2016		
BARON, BUFFALO, CHIPPEWA, CLARK, FLORENCE, FOREST, GRANT, JACKSON LINCOLN, MARATHON, MONROE, ONEIL PORTAGE, PRICE, RUSK, ST. CROIX, VILAS, AND WOOD COUNTIES	I, JUNEAU, LA CRO DA, PEPIN, PIERCI	OSSE, LANGLADE, E, POLK,
	Rates	Fringes
PIPEFITTER	.\$ 38.20	16.72
PLUM0601-003 06/01/2016		
DODGE (Watertown), GREEN, JEFFER OZAUKEE, ROCK, WASHINGTON AND WA		MILWAUKEE,

Rates Fringes

PIPEFITTER	\$ 43.26	22.96	
PLUM0601-009 06/01/2016			
COLUMBIA, DANE, IOWA, MARQUETTE,	RICHLAND AND	SAUK COUNTIES	
	Rates	Fringes	
PIPEFITTER	\$ 46.43	19.54	
TEAM0039-002 06/01/2016			
	Rates	Fringes	
TRUCK DRIVER 1 & 2 Axle Trucks 3 or more axles; Euclids	\$ 26.63	19.85	
or Dumptor, Articulated Truck, Mechanic	\$ 26.78	19.85	
SUWI2011-001 11/16/2011			
	Rates	Fringes	
WELL DRILLER	\$ 16.52		
WEI DEDG Dogging water programik			
WELDERS - Receive rate prescribed for craft performing			

operation to which welding is incidental.

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at www.dol.gov/whd/govcontracts.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (ii)).

The body of each wage determination lists the classification and wage rates that have been found to be prevailing for the cited type(s) of construction in the area covered by the wage determination. The classifications are listed in alphabetical order of "identifiers" that indicate whether the particular rate is a union rate (current union negotiated rate for local), a survey rate (weighted average rate) or a union average rate (weighted union average rate).

Union Rate Identifiers

A four letter classification abbreviation identifier enclosed in dotted lines beginning with characters other than "SU" or "UAVG" denotes that the union classification and rate were prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2014. PLUM is an abbreviation identifier of the union which prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing

the wage determination. 07/01/2014 is the effective date of the most current negotiated rate, which in this example is July 1, 2014.

Union prevailing wage rates are updated to reflect all rate changes in the collective bargaining agreement (CBA) governing this classification and rate.

Survey Rate Identifiers

Classifications listed under the "SU" identifier indicate that no one rate prevailed for this classification in the survey and the published rate is derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As this weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SULA2012-007 5/13/2014. SU indicates the rates are survey rates based on a weighted average calculation of rates and are not majority rates. LA indicates the State of Louisiana. 2012 is the year of survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. 5/13/2014 indicates the survey completion date for the classifications and rates under that identifier.

Survey wage rates are not updated and remain in effect until a new survey is conducted.

Union Average Rate Identifiers

Classification(s) listed under the UAVG identifier indicate that no single majority rate prevailed for those classifications; however, 100% of the data reported for the classifications was union data. EXAMPLE: UAVG-OH-0010 08/29/2014. UAVG indicates that the rate is a weighted union average rate. OH indicates the state. The next number, 0010 in the example, is an internal number used in producing the wage determination. 08/29/2014 indicates the survey completion date for the classifications and rates under that identifier.

A UAVG rate will be updated once a year, usually in January of each year, to reflect a weighted average of the current negotiated/CBA rate of the union locals from which the rate is based.

WAGE DETERMINATION APPEALS PROCESS

- 1.) Has there been an initial decision in the matter? This can be:
- * an existing published wage determination
- * a survey underlying a wage determination
- * a Wage and Hour Division letter setting forth a position on a wage determination matter
- a conformance (additional classification and rate) ruling

On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour Regional Office for the area in which the survey was conducted because those Regional Offices have responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

Branch of Construction Wage Determinations Wage and Hour Division U.S. Department of Labor 200 Constitution Avenue, N.W. Washington, DC 20210

2.) If the answer to the question in 1.) is yes, then an interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator

(See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator U.S. Department of Labor 200 Constitution Avenue, N.W. Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board U.S. Department of Labor 200 Constitution Avenue, N.W. Washington, DC 20210

4.) All decisions by the Administrative Review Board are final.

END OF GENERAL DECISION

FEBRUARY 1999

NOTICE TO BIDDERS WAGE RATE DECISION


The wage rate decision of the Secretary of Labor which has been incorporated in these advertised specifications is incomplete in that the classifications may be omitted from the Secretary of Labor's decision.

Since the bidder is responsible, independently, for ascertaining area practice with respect to the necessity, or lack of necessity, for the use of these classifications in the prosecution of the work contemplated by this project, no inference may be drawn from the omision of these classifications concerning prevailing area practices relative to their use. Further, this omission will not, per se, be construed as establishing any governmental liability for increased labor cost if it is subsequently determined that such classifications are required.

There may be omissions and/or errors in the federal wage rates. The bidder is responsible for evaluating and determining the correct applicable rate. The higher of state or federal rate will apply.

Page 1 of 1








Page 1 of 7

Federal ID(s): N/A

SECTION: 0001 Contract Items

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0010	203.0500.S Removing Old Structure Over Waterway (station) 01. 08+51.5	LS	LUMP SUM	
0020	204.0100 Removing Pavement	750.000 SY		
0030	204.0115 Removing Asphaltic Surface Butt Joints	1,220.000 SY		
0040	204.0150 Removing Curb & Gutter	220.000 LF		
0050	204.0155 Removing Concrete Sidewalk	190.000 SY	·	
0060	204.0175 Removing Concrete Slope Paving	920.000 SY		
0070	204.0245 Removing Storm Sewer (size) 01. 27"	8.000 LF		
0800	204.0250 Abandoning Manholes	1.000 EACH		
0090	205.0100 Excavation Common	436.000 CY		
0100	205.0501.S Excavation, Hauling, and Disposal of Petroleum Contaminated Soil	1,903.000 TON	·	·
0110	210.1500 Backfill Structure Type A	810.000 TON		
0120	213.0100 Finishing Roadway (project) 01. 2984- 07-75	1.000 EACH		
0130	305.0120 Base Aggregate Dense 1 1/4-Inch	466.000 TON		
0140	320.0145 Concrete Base 8-Inch	64.000 SY		
0150	415.0410 Concrete Pavement Approach Slab	300.000 SY	<u> </u>	
0160	416.0610 Drilled Tie Bars	44.000 EACH		







Page 2 of 7

Federal ID(s): N/A

SECTION: 0001 Contract Items

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0170	455.0605 Tack Coat	30.000 GAL		
0180	465.0105 Asphaltic Surface	200.000 TON		
0190	502.0100 Concrete Masonry Bridges	1,195.000 CY		
0200	502.3200 Protective Surface Treatment	1,493.000 SY		
0210	505.0400 Bar Steel Reinforcement HS Structures	56,820.000 LB		
0220	505.0600 Bar Steel Reinforcement HS Coated Structures	179,560.000 LB		·
0230	505.0800.S Bar Steel Reinforcement HS Stainless Structures	2,250.000 LB	·	
0240	511.1200 Temporary Shoring (structure) 01. B-40- 0923	2,520.000 SF	<u></u>	
0250	513.7084 Railing Steel Type NY4 (structure) 01. B- 40-0923	285.000 LF		·
0260	516.0100 Dampproofing	146.000 SY		
0270	516.0500 Rubberized Membrane Waterproofing	44.000 SY	<u> </u>	
0280	522.1018 Apron Endwalls for Culvert Pipe Reinforced Concrete 18-Inch	1.000 EACH	<u></u>	
0290	522.1030 Apron Endwalls for Culvert Pipe Reinforced Concrete 30-Inch	2.000 EACH	·	
0300	522.1048 Apron Endwalls for Culvert Pipe Reinforced Concrete 48-Inch	1.000 EACH	·	·
0310	532.0800.S Wall Gabion	240.000 CY		



02/07/2017 12:47:24



Proposal Schedule of Items

Page 3 of 7

Federal ID(s): N/A

SECTION: 0001 Contract Items

0320 550.0010 230.000 Pre-Boring Unconsolidated Materials LF	
Pre-Boring Rock or Consolidated LF	·
0240	
0340 550.0500 44.000 Pile Points EACH	
0350 550.1100 1,980.000 Piling Steel HP 10-Inch X 42 Lb LF	·
0360 601.0331 350.000 Concrete Curb & Gutter 31-Inch LF	·
0370 602.0410 1,510.000 Concrete Sidewalk 5-Inch SF	
0380 602.0515 70.000 Curb Ramp Detectable Warning Field SF	.
0390 602.1000 370.000 Concrete Loading Zone SF	
0400 608.0515 10.000 Storm Sewer Pipe Reinforced Concrete LF	
0410 608.0518 13.000 Storm Sewer Pipe Reinforced Concrete LF	
0420 608.0530 20.000 Storm Sewer Pipe Reinforced Concrete LF	
0430 608.0548 16.000 Storm Sewer Pipe Reinforced Concrete LF	·
0440 611.0420 1.000 Reconstructing Manholes EACH	·
0450 611.2004 1.000 Manholes 4-FT Diameter EACH	·
0460 612.0206 12.000 Pipe Underdrain Unperforated 6-Inch LF	









Page 4 of 7

Federal ID(s): N/A

SECTION: 0001 Contract Items

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0470	612.0406 Pipe Underdrain Wrapped 6-Inch	156.000 LF	·	
0480	619.1000 Mobilization	1.000 EACH		
0490	620.0300 Concrete Median Sloped Nose	100.000 SF		
0500	623.0200 Dust Control Surface Treatment	480.000 SY		
0510	625.0100 Topsoil	50.000 SY		
0520	628.1504 Silt Fence	200.000 LF		·
0530	628.1520 Silt Fence Maintenance	200.000 LF		
0540	628.6005 Turbidity Barriers	200.000 SY		
0550	629.0210 Fertilizer Type B	0.100 CWT		
0560	631.1000 Sod Lawn	50.000 SY	<u></u>	
0570	642.5201 Field Office Type C	1.000 EACH		
0580	643.0100 Traffic Control (project) 01. 2984-07-75	1.000 EACH		
0590	643.0300 Traffic Control Drums	1,640.000 DAY		·
0600	643.0420 Traffic Control Barricades Type III	19,475.000 DAY		
0610	643.0705 Traffic Control Warning Lights Type A	38,950.000 DAY		
0620	643.0715 Traffic Control Warning Lights Type C	1,640.000 DAY	·	
0630	643.0900 Traffic Control Signs	3,280.000 DAY		








Page 5 of 7

Federal ID(s): N/A

SECTION: 0001 Contract Items

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0640	643.2000 Traffic Control Detour (project) 01. 2984- 07-75	1.000 EACH	·	
0650	643.3000 Traffic Control Detour Signs	10,045.000 DAY		
0660	646.0106 Pavement Marking Epoxy 4-Inch	960.000 LF	·	
0670	646.0116 Pavement Marking Epoxy 6-Inch	370.000 LF		
0680	646.0126 Pavement Marking Epoxy 8-Inch	80.000 LF		
0690	646.0136 Pavement Marking Epoxy 12-Inch	130.000 LF		
0700	647.0166 Pavement Marking Arrows Epoxy Type 2	1.000 EACH		
0710	647.0206 Pavement Marking Arrows Bike Lane Epoxy	2.000 EACH		·
0720	647.0306 Pavement Marking Symbols Bike Lane Epoxy	2.000 EACH		
0730	647.0356 Pavement Marking Words Epoxy	1.000 EACH	·	
0740	649.0400 Temporary Pavement Marking Removable Tape 4-Inch	28.000 LF		
0750	650.4000 Construction Staking Storm Sewer	4.000 EACH	·	
0760	650.4500 Construction Staking Subgrade	85.000 LF		
0770	650.6500 Construction Staking Structure Layout (structure) 01. B-40-0923	LS	LUMP SUM	
0780	650.7000 Construction Staking Concrete Pavement	85.000 LF		







Page 6 of 7

Federal ID(s): N/A

SECTION: 0001 Contract Items

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0790	650.9910 Construction Staking Supplemental Control (project) 01. 2984-07-75	LS	LUMP SUM	·
0800	652.0225 Conduit Rigid Nonmetallic Schedule 40 2-Inch	42.000 LF		·
0810	652.0230 Conduit Rigid Nonmetallic Schedule 40 2 1/2-Inch	504.000 LF	·	
0820	652.0240 Conduit Rigid Nonmetallic Schedule 40 4-Inch	480.000 LF		·
0830	657.6005.S Anchor Assemblies Light Poles on Structures	4.000 EACH		
0840	690.0150 Sawing Asphalt	190.000 LF		
0850	690.0250 Sawing Concrete	140.000 LF		
0860	715.0502 Incentive Strength Concrete Structures	1,195.000 DOL	1.00000	1,195.00
0870	999.1000.S Seismograph	LS	LUMP SUM	
0880	SPV.0060 Special 01. INLET SCREEN TYPE M	2.000 EACH		·
0890	SPV.0060 Special 02. INLET SCREEN TYPE R	2.000 EACH		·
0900	SPV.0060 Special 03. INLET COVERS TYPE 57	3.000 EACH		
0910	SPV.0060 Special 04. MANHOLE COVERS TYPE 58A	2.000 EACH	<u>-</u>	
0920	SPV.0060 Special 05. ADJUSTING WATER BOXES	3.000 EACH		·
0930	SPV.0060 Special 06. INSTALLING CONDUIT INTO EXISTING MANHOLE	2.000 EACH	·	



Page 7 of 7

Federal ID(s): N/A

SECTION: 0001 Contract Items

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0940	SPV.0060 Special 07. JUNCTION BOXES 18"x12"x8"	4.000 EACH		
0950	SPV.0060 Special 08. BAR GRATE SYSTEM	3.000 EACH		
0960	SPV.0060 Special 09. CONCRETE COLLAR	4.000 EACH		
0970	SPV.0060 Special 10. ADJUSTING TES MANHOLE COVER	2.000 EACH	·	
0980	SPV.0060 Special 11. CONSTRUCTION STAKING CURB RAMP	8.000 EACH		
0990	SPV.0090 Special 01. 4-DUCT CONDUIT, CEMENT ENCASED, 4-INCH RIGID NONMETALLIC CONDUIT DB-60	200.000 LF		
1000	SPV.0090 Special 02. CONSTRUCTION STAKING CONCRETE SIDEWALK	120.000 LF		<u> </u>
1010	SPV.0105 Special 01. TEMPORARY ROUTING OF STORM SEWERS	LS	LUMP SUM	
1020	SPV.0180 Special 01. REMOVING VEGETATED REVETMENT MATTRESS SLOPE PROTECTION	650.000 SY		
1030	SPV.0180 Special 02. VEGETATED REVETMENT MATTRESS SLOPE PROTECTION	1,535.000 SY		
1040	SPV.0180 Special 03. GROUTED REVETMENT MATTRESS SLOPE PROTECTION	65.000 SY	·	·

ection:	0001	rotai:	·	

Tota	l Bid:	

PLEASE ATTACH SCHEDULE OF ITEMS HERE