

# HIGHWAY WORK PROPOSAL

Wisconsin Department of Transportation  
06/2017 s.66.0901(7) Wis. Stats

Proposal Number: **015**

<u>COUNTY</u>	<u>STATE PROJECT</u>	<u>FEDERAL</u>	<u>PROJECT DESCRIPTION</u>	<u>HIGHWAY</u>
Milwaukee	2100-00-70	N/A	South 35th Street; Bridge Over Kinnickinnic River	LOC STR

## ADDENDUM REQUIRED ATTACHED AT BACK

This proposal, submitted by the undersigned bidder to the Wisconsin Department of Transportation, is in accordance with the advertised request for proposals. The bidder is to furnish and deliver all materials, and to perform all work for the improvement of the designated project in the time specified, in accordance with the appended Proposal Requirements and Conditions.

Proposal Guaranty Required: \$75,000.00 Payable to: Wisconsin Department of Transportation	Attach Proposal Guaranty on back of this PAGE.
Bid Submittal Date: January 15, 2019 Time (Local Time): 9:00 am	Firm Name, Address, City, State, Zip Code
Contract Completion Time October 31, 2019	<b>SAMPLE NOT FOR BIDDING PURPOSES</b>
Assigned Disadvantaged Business Enterprise Goal 0%	This contract is exempt from federal oversight.

This certifies that the undersigned bidder, duly sworn, is an authorized representative of the firm named above; that the bidder has examined and carefully prepared the bid from the plans, Highway Work Proposal, and all addenda, and has checked the same in detail before submitting this proposal or bid; and that the bidder or agents, officer, or employees have not, either directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken any action in restraint of free competitive bidding in connection with this proposal bid.

Do not sign, notarize, or submit this Highway Work Proposal when submitting an electronic bid on the Internet.

Subscribed and sworn to before me this date \_\_\_\_\_

\_\_\_\_\_  
(Signature, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Bidder Signature)

\_\_\_\_\_  
(Print or Type Name, Notary Public, State Wisconsin)

\_\_\_\_\_  
(Print or Type Bidder Name)

\_\_\_\_\_  
(Date Commission Expires)

\_\_\_\_\_  
(Bidder Title)

Notary Seal

Type of Work: Structure P-40-0511, steel railing, slope paving replacement, removing pavement, concrete pavement, grading, base aggregate, concrete curb and gutter, sidewalk, storm sewer, conduit, and pavement marking	For Department Use Only
Notice of Award Dated	Date Guaranty Returned

**PLEASE ATTACH  
PROPOSAL GUARANTY HERE**

**Effective with November 2007 Letting**

**PROPOSAL REQUIREMENTS AND CONDITIONS**

The bidder, signing and submitting this proposal, agrees and declares as a condition thereof, to be bound by the following conditions and requirements.

If the bidder has a corporate relationship with the proposal design engineering company, the bidder declares that it did not obtain any facts, data, or other information related to this proposal from the design engineering company that was not available to all bidders.

The bidder declares that they have carefully examined the site of, and the proposal, plans, specifications and contract forms for the work contemplated, and it is assumed that the bidder has investigated and is satisfied as to the conditions to be encountered, as to the character, quality, and quantities of work to be performed and materials to be furnished, and as to the requirements of the specifications, special provisions and contract. It is mutually agreed that submission of a proposal shall be considered conclusive evidence that the bidder has made such examination.

The bidder submits herewith a proposal guaranty in proper form and amount payable to the party as designated in the advertisement inviting proposals, to be retained by and become the property of the owner of the work in the event the undersigned shall fail to execute the contract and contract bond and return the same to the office of the engineer within fourteen (14) days after having been notified in writing to do so; otherwise to be returned.

The bidder declares that they understand that the estimate of quantities in the attached schedule is approximate only and that the attached quantities may be greater or less in accordance with the specifications.

The bidder agrees to perform the said work, for and in consideration of the payment of the amount becoming due on account of work performed, according to the unit prices bid in the following schedule, and to accept such amounts in full payment of said work.

The bidder declares that all of the said work will be performed at their own proper cost and expense, that they will furnish all necessary materials, labor, tools, machinery, apparatus, and other means of construction in the manner provided in the applicable specifications and the approved plans for the work together with all standard and special designs that may be designed on such plans, and the special provisions in the contract of which this proposal will become a part, if and when accepted. The bidder further agrees that the applicable specifications and all plans and working drawings are made a part hereof, as fully and completely as if attached hereto.

The bidder, if awarded the contract, agrees to begin the work not later than ten (10) days after the date of written notification from the engineer to do so, unless otherwise stipulated in the special provisions.

The bidder declares that if they are awarded the contract, they will execute the contract agreement and begin and complete the work within the time named herein, and they will file a good and sufficient surety bond for the amount of the contract for performance and also for the full amount of the contract for payment.

The bidder, if awarded the contract, shall pay all claims as required by Section 779.14, Statutes of Wisconsin, and shall be subject to and discharge all liabilities for injuries pursuant to Chapter 102 of the Statutes of Wisconsin, and all acts amendatory thereto. They shall further be responsible for any damages to property or injury to persons occurring through their own negligence or that of their employees or agents, incident to the performance of work under this contract, pursuant to the Standard Specifications for Road and Bridge Construction applicable to this contract.

In connection with the performance of work under this contract, the contractor agrees to comply with all applicable state and federal statutes relating to non-discrimination in employment. No otherwise qualified person shall be excluded from employment or otherwise be subject to discrimination in employment in any manner on the basis of age, race, religion, color, gender, national origin or ancestry, disability, arrest or conviction record (in keeping with s.111.32), sexual orientation, marital status, membership in the military reserve, honesty testing, genetic testing, and outside use of lawful products. This provision shall include, but not be limited to the following: employment, upgrading, demotion or transfer; recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation, and selection for training, including apprenticeship. The contractor further agrees to ensure equal opportunity in employment to all applicants and employees and to take affirmative action to attain a representative workforce.

The contractor agrees to post notices and posters setting forth the provisions of the nondiscrimination clause, in a conspicuous and easily accessible place, available for employees and applicants for employment.

If a state public official (section 19.42, Stats.) or an organization in which a state public official holds at least a 10% interest is a party to this agreement, this contract is voidable by the state unless appropriate disclosure is made to the State of Wisconsin Ethics Board.

## **Effective with August 2015 Letting**

### **BID PREPARATION**

#### **Preparing the Proposal Schedule of Items**

##### **A General**

- (1) Obtain bidding proposals as specified in section 102 of the standard specifications prior to 11:45 AM of the last business day preceding the letting. Submit bidding proposals using one of the following methods:
  1. Electronic bid on the internet.
  2. Electronic bid on a printout with accompanying diskette or CD ROM.
  3. Paper bid under a waiver of the electronic submittal requirements.
- (2) Bids submitted on a printout with accompanying diskette or CD ROM or paper bids submitted under a waiver of the electronic submittal requirements govern over bids submitted on the internet.

- (3) The department will provide bidding information through the department's web site at:  
<https://wisconsindot.gov/Pages/doing-bus/contractors/hcci/bid-let.aspx>

The contractor is responsible for reviewing this web site for general notices as well as information regarding proposals in each letting. The department will also post special notices of all addenda to each proposal through this web site no later than 4:00 PM local time on the Thursday before the letting. Check the department's web site after 5:00 PM local time on the Thursday before the letting to ensure all addenda have been accounted for before preparing the bid. When bidding using methods 1 and 2 above, check the Bid Express™ on-line bidding exchange at <http://www.bidx.com/> after 5:00 PM local time on the Thursday before the letting to ensure that the latest schedule of items Expedite file (\*.ebs or \*.00x) is used to submit the final bid.

- (4) Interested parties can subscribe to the Bid Express™ on-line bidding exchange by following the instructions provided at the [www.bidx.com](http://www.bidx.com) web site or by contacting:

Info Tech Inc.  
5700 SW 34th Street, Suite 1235  
Gainesville, FL 32608-5371  
email: <mailto:customer.support@bidx.com>

- (5) The department will address equipment and process failures, if the bidder can demonstrate that those failures were beyond their control.
- (6) Contractors are responsible for checking on the issuance of addenda and for obtaining the addenda. Notice of issuance of addenda is posted on the department's web site at:  
<https://wisconsindot.gov/Pages/doing-bus/contractors/hcci/bid-let.aspx>

or by calling the department at (608) 266-1631. Addenda can ONLY be obtained from the department's web site listed above or by picking up the addenda at the Bureau of Highway Construction, 4<sup>th</sup> floor, 4822 Madison Yards Way, Madison, WI, during regular business hours.

- (7) Addenda posted after 5:00 PM on the Thursday before the letting will be emailed to the eligible bidders for that proposal. All eligible bidders shall acknowledge receipt of the addenda whether they are bidding on the proposal or not. Not acknowledging receipt may jeopardize the awarding of the project.

##### **B Submitting Electronic Bids**

###### **B.1 On the Internet**

- (1) Do the following before submitting the bid:
  1. Have a properly executed annual bid bond on file with the department.

2. Have a digital ID on file with and enabled by Info Tech Inc. Using this digital ID will constitute the bidder's signature for proper execution of the bidding proposal.
- (2) In lieu of preparing, delivering, and submitting the proposal as specified in 102.6 and 102.9 of the standard specifications, submit the proposal on the internet as follows:
  1. Download the latest schedule of items reflecting all addenda from the Bid Express™ web site.
  2. Use Expedite™ software to enter a unit price for every item in the schedule of items.
  3. Submit the bid according to the requirements of Expedite™ software and the Bid Express™ web site. Do not submit a bid on a printout with accompanying diskette or CD ROM or a paper bid. If the bidder does submit a bid on a printout with accompanying diskette or a paper bid in addition to the internet submittal, the department will disregard the internet bid.
  4. Submit the bid before the hour and date the Notice to Contractors designates.
  5. Do not sign, notarize, and return the bidding proposal described in 102.2 of the standard specifications.
- (3) The department will not consider the bid accepted until the hour and date the Notice to Contractors designates.

## **B.2 On a Printout with Accompanying Diskette or CD ROM**

- (1) Download the latest schedule of items from the Wisconsin pages of the Bid Express™ web site reflecting the latest addenda posted on the department's web site at:  
<https://wisconsindot.gov/Pages/doing-bus/contractors/hcci/bid-let.aspx>  
Use Expedite™ software to prepare and print the schedule of items. Provide a valid amount for all price fields. Follow instructions and review the help screens provided on the Bid Express™ web site to assure that the schedule of items is prepared properly.
- (2) Staple an 8 1/2 by 11 inch printout of the Expedite™ generated schedule of items to the other proposal documents submitted to the department as a part of the bidder's sealed bid. As a separate submittal, not in the sealed bid envelop but due at the same time and place as the sealed bid, also provide the Expedite™ generated schedule of items on a 3 1/2 inch computer diskette or CD ROM. Label each diskette or CD ROM with the bidder's name, the 4 character department-assigned bidder identification code from the top of the bidding proposal, and a list of the proposal numbers included on that diskette or CD ROM as indicated in the following example:

**Bidder Name**

**BN00**

**Proposals: 1, 12, 14, & 22**

- (3) If bidding on more than one proposal in the letting, the bidder may include all proposals for that letting on one diskette or CD ROM. Include only submitted proposals with no incomplete or other files on the diskette or CD ROM.
- (4) The bidder-submitted printout of the Expedite™ generated schedule of items is the governing contract document and must conform to the requirements of section 102 of the standard specifications. If a printout needs to be altered, cross out the printed information with ink or typewriter and enter the new information and initial it in ink. If there is a discrepancy between the printout and the diskette or CD ROM, the department will analyze the bid using the printout information.
- (5) In addition to the reasons specified in section 102 of the standard specifications, proposals are irregular and the department may reject them for one or more of the following:
  1. The check code printed on the bottom of the printout of the Expedite™ generated schedule of items is not the same on each page.
  2. The check code printed on the printout of the Expedite™ generated schedule of items is not the same as the check code for that proposal provided on the diskette or CD ROM.

3. The diskette or CD ROM is not submitted at the time and place the department designates.

### **C Waiver of Electronic Submittal**

- (1) The bidder may request a waiver of the electronic submittal requirements. Submit a written request for a waiver in lieu of bids submitted on the internet or on a printout with accompanying diskette or CD ROM. Use the waiver that was included with the paper bid document sent to the bidder or type up a waiver on the bidder's letterhead. The department will waive the electronic submittal requirements for a bidding entity (individual, partnership, joint venture, corporation, or limited liability company) for up to 4 individual proposals in a calendar year. The department may allow additional waivers for equipment malfunctions.
- (2) Submit a schedule of items on paper conforming to section 102 of the standard specifications. The department charges the bidder a \$75 administrative fee per proposal, payable at the time and place the department designates for receiving bids, to cover the costs of data entry. The department will accept a check or money order payable to: "Wisconsin, Dept. of Transportation."
- (3) In addition to the reasons specified in section 102 of the standard specifications, proposals are irregular and the department may reject them for one or more of the following:
  1. The bidder fails to provide the written request for waiver of the electronic submittal requirements.
  2. The bidder fails to pay the \$75 administrative fee before the time the department designates for the opening of bids unless the bidder requests on the waiver that they be billed for the \$75.
  3. The bidder exceeds 4 waivers of electronic submittal requirements within a calendar year.
- (4) In addition to the reasons specified in section 102 of the standard specifications, the department may refuse to issue bidding proposals for future contracts to a bidding entity that owes the department administrative fees for a waiver of electronic submittal requirements.

# PROPOSAL BID BOND

DT1303 1/2006

Wisconsin Department of Transportation

Proposal Number	Project Number	Letting Date
Name of Principal		
Name of Surety	State in Which Surety is Organized	

We, the above-named Principal and the above-named Surety, are held and firmly bound unto the State of Wisconsin in the sum equal to the Proposal Guaranty for the total bid submitted for the payment to be made; we jointly and severally bind ourselves, our heirs, executors, administrators, successors and assigns. The condition of this obligation is that the Principal has submitted a bid proposal to the State of Wisconsin acting through the Department of Transportation for the improvement designated by the Proposal Number and Letting Date indicated above.

If the Principal is awarded the contract and, within the time and manner required by law after the prescribed forms are presented for signature, enters into a written contract in accordance with the bid, and files the bond with the Department of Transportation to guarantee faithful performance and payment for labor and materials, as required by law, or if the Department of Transportation shall reject all bids for the work described, then this obligation shall be null and void; otherwise, it shall be and remain in full force and effect. In the event of failure of the Principal to enter into the contract or give the specified bond, the Principal shall pay to the Department of Transportation **within 10 business days of demand** a total equal to the Proposal Guaranty as liquidated damages; the liability of the Surety continues for the full amount of the obligation as stated until the obligation is paid in full.

The Surety, for value received, agrees that the obligations of it and its bond shall not be impaired or affected by any extension of time within which the Department of Transportation may accept the bid; and the Surety does waive notice of any such extension.

IN WITNESS, the Principal and Surety have agreed and have signed by their proper officers and have caused their corporate seals to be affixed this date: **(DATE MUST BE ENTERED)**

## PRINCIPAL

\_\_\_\_\_  
(Company Name) **(Affix Corporate Seal)**

\_\_\_\_\_  
(Signature and Title)

\_\_\_\_\_  
(Company Name)

\_\_\_\_\_  
(Signature and Title)

\_\_\_\_\_  
(Company Name)

\_\_\_\_\_  
(Signature and Title)

\_\_\_\_\_  
(Company Name)

\_\_\_\_\_  
(Signature and Title)

## NOTARY FOR PRINCIPAL

\_\_\_\_\_  
(Date)

State of Wisconsin )  
 ) ss.  
\_\_\_\_\_ County )

On the above date, this instrument was acknowledged before me by the named person(s).

\_\_\_\_\_  
(Signature, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Print or Type Name, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Date Commission Expires)

**Notary Seal**

\_\_\_\_\_  
(Name of Surety) **(Affix Seal)**

\_\_\_\_\_  
(Signature of Attorney-in-Fact)

## NOTARY FOR SURETY

\_\_\_\_\_  
(Date)

State of Wisconsin )  
 ) ss.  
\_\_\_\_\_ County )

On the above date, this instrument was acknowledged before me by the named person(s).

\_\_\_\_\_  
(Signature, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Print or Type Name, Notary Public, State of Wisconsin)

\_\_\_\_\_  
(Date Commission Expires)

**Notary Seal**

**IMPORTANT: A certified copy of Power of Attorney of the signatory agent must be attached to the bid bond.**





# CERTIFICATE OF ANNUAL BID BOND

DT1305 8/2003

Wisconsin Department of Transportation

Time Period Valid (From/To)	
Name of Surety	
Name of Contractor	
Certificate Holder	Wisconsin Department of Transportation

This is to certify that an annual bid bond issued by the above-named Surety is currently on file with the Wisconsin Department of Transportation.

This certificate is issued as a matter of information and conveys no rights upon the certificate holder and does not amend, extend or alter the coverage of the annual bid bond.

**Cancellation:** Should the above policy be cancelled before the expiration date, the issuing surety will give thirty (30) days written notice to the certificate holder indicated above.

\_\_\_\_\_  
(Signature of Authorized Contractor Representative)

\_\_\_\_\_  
(Date)



## March 2010

## LIST OF SUBCONTRACTORS

Section 66.0901(7), Wisconsin Statutes, provides that as a part of the proposal, the bidder also shall submit a list of the subcontractors the bidder proposes to contract with and the class of work to be performed by each. In order to qualify for inclusion in the bidder's list a subcontractor shall first submit a bid in writing, to the general contractor at least 48 hours prior to the time of the bid closing. The list may not be added to or altered without the written consent of the municipality. A proposal of a bidder is not invalid if any subcontractor and the class of work to be performed by the subcontractor has been omitted from a proposal; the omission shall be considered inadvertent or the bidder will perform the work personally.

No subcontract, whether listed herein or later proposed, may be entered into without the written consent of the Engineer as provided in Subsection 108.1 of the Standard Specifications.

[illegible]

**DECEMBER 2000**

**CERTIFICATION REGARDING DEBARMENT, SUSPENSION, AND OTHER  
RESPONSIBILITY MATTERS - PRIMARY COVERED TRANSACTIONS**

Instructions for Certification

1. By signing and submitting this proposal, the prospective contractor is providing the certification set out below.
2. The inability of a person to provide the certification required below will not necessarily result in denial of participation in this covered transaction. The prospective contractor shall submit an explanation of why it cannot provide the certification set out below. The certification or explanation will be considered in connection with the department or agency's determination whether to enter into this transaction. However, failure of the prospective contractor to furnish a certification or an explanation shall disqualify such person from participation in this transaction.
3. The certification in this clause is a material representation of fact upon which reliance was placed when the department determined to enter into this transaction. If it is later determined that the contractor knowingly rendered an erroneous certification in addition to other remedies available to the Federal Government the department may terminate this transaction for cause or default.
4. The prospective contractor shall provide immediate written notice to the department to whom this proposal is submitted if at any time the prospective contractor learns that its certification was erroneous when submitted or has become erroneous by reason of changed circumstances.
5. The terms "covered transaction," "debarred," "suspended," "ineligible," "lower tier covered transaction," "participant," "person," "primary covered transaction," "principal," "proposal," and "voluntarily excluded," as used in this clause, have the meanings set out in the Definitions and Coverage sections of the rules implementing Executive Order 12549. You may contact the department to which this proposal is being submitted for assistance in obtaining a copy of those regulations.
6. The prospective contractor agrees by submitting this proposal that, should this contract be entered into, it shall not knowingly enter into any lower tier covered transaction with a person who is debarred, suspended, declared ineligible, or voluntarily excluded from participation in this covered transaction, unless authorized by the department entering into this transaction.
7. The prospective contractor further agrees by submitting this proposal that it will include the clause titled "Certification Regarding Debarment, Suspension, Ineligibility and Voluntary Exclusion-Lower Tier Covered Transaction," which is included as an addendum to PR-1273 - "Required Contract Provisions Federal Aid Construction Contracts," without

modification, in all lower tier covered transactions and in all solicitations for lower tier covered transactions.

8. The contractor may rely upon a certification of a prospective subcontractor/materials supplier that it is not debarred, suspended, ineligible, or voluntarily excluded from the covered transaction, unless it knows that the certification is erroneous. A contractor may decide the method and frequency by which it determines the eligibility of its principals. Each contractor may, but is not required to, check the Disapproval List (telephone # 608/266/1631).
9. Nothing contained in the foregoing shall be construed to require establishment of a system of records in order to render in good faith the certification required by this clause. The knowledge and information of a contractor is not required to exceed that which is normally possessed by a prudent person in the ordinary course of business dealings.
10. Except for transactions authorized under paragraph 6 of these instructions, if a contractor in a covered transaction knowingly enters into a lower tier covered transaction with a person who is suspended, debarred, ineligible or voluntarily excluded from participation in this transaction, in addition to other remedies available to the Federal Government, the department may terminate this transaction for cause or default.

Certification Regarding Debarment, Suspension, and Other Responsibility Matters - Primary Covered Transactions

- (1) The prospective contractor certifies to the best of its knowledge and belief, that it and its principals:
  - (a) Are not presently debarred, suspended, proposed for debarment, declared ineligible, or voluntarily excluded from covered transactions by any Federal department or agency;
  - (b) Have not within a three-year period preceding this proposal been convicted of or had a civil judgment rendered against them for commission of fraud or a criminal offense in connection with obtaining, attempting to obtain, or performing a public (Federal, State or local) transaction or contract under a public transaction; violation of Federal or State antitrust statutes or commission of embezzlement, theft, forgery, bribery, falsification or destruction of records, making false statements or receiving stolen property;
  - (c) Are not presently indicted for or otherwise criminally or civilly charged by a governmental entity (Federal, State or local) with commission of any of the offense enumerated in paragraph (1)(b) of this certification; and
  - (d) Have not within a three-year period preceding this proposal had one or more public transactions (Federal, State or local) terminated for cause or default.
- (2) Where the prospective contractor is unable to certify to any of the statements in this certification, such prospective contractor shall attach an explanation to this proposal.

## Special Provisions

### Table of Contents

Article	Description	Page #
1.	General.....	3
2.	Scope of Work.....	3
3.	Prosecution and Progress.....	3
4.	Traffic. ....	6
5.	Holiday Work Restrictions.....	6
6.	Utilities.....	7
7.	Information to Bidders, U.S. Army Corps of Engineers Section 404 Permit.....	9
8.	Environmental Protection, Aquatic Exotic Species Control. ....	9
9.	Erosion Control. ....	10
10.	Erosion Control Structures.....	10
11.	Construction Over or Adjacent to Navigable Waters. ....	11
12.	Notice to Contractor – Lead-Based Paint. ....	11
13.	Notice to Contractor – Notification of Demolition and/or Renovation No Asbestos Found.....	11
14.	Notice to Contractor – Emerald Ash Borer.....	11
15.	Archaeological Site.....	14
16.	Public Convenience and Safety. ....	14
17.	Coordination with Milwaukee County Transit (MCTS). ....	14
18.	Notice to Contractor – Restoration within Right-of-Way. ....	15
19.	Notice to Contractor – Work without a Construction Permit. ....	15
20.	Notice to Contractor – Survey.....	15
21.	Notice to Contractor – Work within Milwaukee County Parks System. ....	15
22.	Coordination with Milwaukee County Parks System. ....	15
23.	Removing Old Structure Over Waterway With Minimal Debris Station 3+04.48, Item 203.0600.S.001.....	16
24.	Protection of Concrete. ....	16
25.	Concrete Identification Stamping. ....	16
26.	Expansion Device, P-40-511. ....	17
27.	Field Office, Type C, Item 642.5201. ....	17
28.	Traffic Control.....	18
29.	Removing Bearings, P-40-511, Item 506.7050.S.001. ....	18
30.	Epoxy Injection Crack Repair, Item 509.9025.S; Cored Holes 2-Inch Diameter, Item 509.9026.S.....	19
31.	Structure Repainting General. ....	21
32.	Labeling and Disposal of Waste Material.....	22
33.	Preparation and Coating of Top Flanges P-40-511, Item 517.0900.S.001. ....	24
34.	Concrete Staining P-40-511, Item 517.1010.S.001. ....	25
35.	Structure Repainting Recycled Abrasive P-40-511, Item 517.1800.S.001.....	26
36.	Negative Pressure Containment and Collection of Waste Materials, P-40-511, Item 517.4500.S.001.....	28

37.	Portable Decontamination Facility, Item 517.6001.S.....	29
38.	Temporary Curb Ramp, Item 644.1601.S.....	30
39.	Temporary Pedestrian Safety Fence, Item 644.1616.S.....	31
40.	Temporary Pedestrian Barricade, Item 644.1810.S. ....	31
41.	Inlet Cover Type MS 57, Item SPV.0060.102. ....	32
42.	Manhole Cover Type MS 58-A, Item SPV.0060.103. ....	32
43.	Storm Inlet Type 45A, Item SPV.0060.112. ....	33
44.	Adjusting CUC Manhole Cover, Item SPV.0060.400.....	33
45.	Sawing Concrete-Encased Duct Package, Item SPV.0060.426.....	34
46.	End Diaphragm Adjustment, Item SPV.0060.510.....	35
47.	Marking Line Epoxy 6-Inch, Item SPV.0090.001. ....	35
48.	Construction Staking Concrete Sidewalk, SPV.0090.002. ....	36
49.	4-Duct Conduit Cement Encased DB-60, Item SPV.0090.404.....	36
50.	Underdeck Utility Structure P-40-511, City of Milwaukee Communications Conduit, Item SPV.0105.400. ....	40



**SPECIAL PROVISIONS**

**1. General.**

Perform the work under this construction contract for Project 2100-00-70, 35<sup>th</sup> Street-Bridge Over Kinnickinnic River, Loc Str, Milwaukee County, Wisconsin as the plans show and execute the work as specified in the State of Wisconsin, Department of Transportation, Standard Specifications for Highway and Structure Construction, 2019 Edition, as published by the department, and these special provisions.

If all or a portion of the plans and special provisions are developed in the SI metric system and the schedule of prices is developed in the US standard measure system, the department will pay for the work as bid in the US standard system.

100-005 (20180628)

**2. Scope of Work.**

The work under this contract shall consist of bridge rehabilitations to include railing replacement, concrete masonry bridges, slope paving replacement, removing existing roadway, concrete pavement, associated grading, base aggregate, concrete curb and gutter, sidewalk, storm sewer structures, conduit and pavement marking and all incidental items necessary to complete the work as shown on the plans and included in the proposal and contract.

104-005 (20090901)

**3. Prosecution and Progress.**

Begin work within ten calendar days after the engineer issues a written notice to do so.

Provide the start date to the engineer in writing within a month after executing the contract but at least 14 calendar days before the preconstruction conference. Upon approval, the engineer will issue the notice to proceed within ten calendar days before the approved start date.

To revise the start date, submit a written request to the engineer at least two weeks before the intended start date. The engineer will approve or deny that request based on the conditions cited in the request and its effect on the department's scheduled resources.

Do not commence work under this contract until the required traffic control devices and markings are in place and the engineer approves the installations. If the contractor desires to work on Saturday, Sunday, or nationally recognized legal holidays, he must obtain approval from the engineer at least 24 hours in advance. If scheduling changes after approval has been obtained, the engineer must be notified as soon as possible, but not later than 12:00 PM.

Arrange weekly construction/progress meetings to apprise all sub-contractors and work being done by others of current status of project.

Provide proposed sequence of operations, methods of handling traffic, method of operation in the Kinnickinnic River, plans for cleanup of the Kinnickinnic River should spills of oil, soil, or debris from abutment and pier rehabilitation construction or other types of pollutants be accidentally discharged into it, and a program of debris removal to prevent accumulation of unsightly debris in the water course in writing within 14 days before the preconstruction conference. Submit revisions in traffic handling to the engineer for approval at least 48-hours in advance of making any changes in traffic operations.

The contractor shall be responsible to find the staging area during construction by occupying the work area on the bridge, approaches, or be negotiating with the adjacent property owners for the construction staging.

Obtain permission from the engineer a minimum of 48 hours prior to any construction schedule change.

Contractor shall access the underside of the structure from the top to avoid any impacts to the wetlands to the maximum extent possible.

**Emergency Vehicle Access**

Maintain emergency vehicular access at all times to roadways located within the project limits.

*Supplement standard spec 107.18 with the following:*

Use equipment having vacuum or water-spray mechanisms to eliminate the dispersion of dust when performing roadway-cleaning operations. Provide suitable, self-contained particulate collectors, if vacuum equipment is used, to prevent discharge from collection bin into the atmosphere.

*Amend standard spec 108.9.2 by adding the following paragraphs:*

Take special precautions to avoid damage to all existing utility facilities in the proximity of the construction area.

Submit a schedule and description of clearing operations with the ECIP 14 days prior to any Clearing operations. The department will determine, based on schedule and scope of work, what additional erosion control measures shall be implemented prior to the start of Clearing operations, and list those additional measures in the ECIP.

Do not commence work under this contract until the required traffic control devices and markings are in place and the engineer approves the installations. Once work has started on the contract, work continually until the contract work is complete. The contract will not be considered complete until all items on the contract are completed, including seeding and roadway finishing. If the contractor desires to work on Saturday, Sunday, or nationally recognized legal holidays, he must obtain approval from the engineer at least 24 hours in advance. If scheduling changes after approval has been obtained, the engineer must be notified as soon as possible, but not later than 12:00 PM.

The department will not grant time extensions to the interim completion dates specified above for the following:

- Severe weather as specified in standard spec 108.10.2.2
- Labor disputes that are not industry wide
- Delays in material deliveries

No extra cost will be allowed for "cold weather protection" as addressed in standard spec 415.13.

Except where noted, keep all intersections accessible at all times. Include any costs associated with staging operations at intersections that are to remain accessible at all times in the unit bid price for Traffic Control (Project).

Maintain or provide where necessary, as directed by the engineer, pedestrian access to adjacent properties, businesses, recreation areas, and bus stops. Provide adequate temporary sidewalk and bridging between the curb and the right-of-way line over freshly paved concrete or other obstructions on the sidewalk area at entrances to buildings or as directed by the engineer. The cost of bridging shall be included in the unit bid price for Concrete Sidewalk 5-Inch.

Maintain vehicular access to all business and commercial properties at all times except as noted in the traffic control plans and specifications.

The labor and materials required to restore concrete sidewalk, after saw cutting, will be deemed incidental to the bid item 690.250, Sawing Concrete.

Store drums, buckets and other containers related to construction operations in a secure area to prevent vandalism, spills, and unwanted dumping. If an abandoned container is discovered on the project site, notify the WDNR at (800) 943-0003.

The project will require a Section 404 permit from USACE only if there is fill material being placed into the waterway. This includes devices for dewatering, temporary fills, large concrete debris from the bridge, etc. If nothing will be entering the waterway, no permit would be required from the Regulatory Branch of USACE.

### **Fish Spawning**

There shall be no instream disturbance of the Kinnickinnic River as a result of construction activity under or for this contract, from March 1 to June 15 both dates inclusive, in order to avoid adverse impacts upon the spawning of endemic fish population.

Any change to this limitation will require submitting a written request by the contractor to the engineer, subsequent review and concurrence by the Department of Natural Resources in the request, and final approval by the engineer. The approval will include all conditions to the request as mutually agreed upon by WisDOT and DNR.

## **Migratory Birds**

Swallow and other migratory birds' nests have been observed on or under the existing bridge. All active nests (when eggs or young are present) of migratory birds are protected under the federal Migratory Bird Treaty Act.

The nesting season for swallows and other birds is usually between May 1 and August 30. Either prevent active nests from becoming established, or apply for a depredation permit from the US Fish and Wildlife Service for work that may disturb or destroy active nests. The need for a permit may be avoided by removing the existing bridge structure prior to nest occupation by birds, or clearing nests from all structures before the nests become active in early spring. As a last resort, prevent birds from nesting by installing a suitable netting device on the remaining structure prior to nesting activity. Include the cost for preventing nesting in the cost of Removing Old Structure Over Waterway with Minimal Debris.

The contractor shall be responsible for keeping birds from nesting on the existing half of the bridge not being worked on.

If netting is used, it shall be properly maintained and removed as soon as the nesting period is over.

If contractor's work does not start by May 1, 2019, the City of Milwaukee will take appropriate action to prevent nesting until the start of project construction.

## **Northern Long-eared Bat (*Myotis septentrionalis*)**

Northern Long-eared Bats (NLEB) have the potential to inhabit the project limits because they roost in trees. Roosts may not have been observed on this project, but conditions to support the species exist. The species and all active roosts are protected by the Federal Endangered Species Act. If an individual bat or active roost is encountered during construction operations, stop work and notify the engineer and the WisDOT Regional Environmental Coordinator (REC).

In accordance to the final 4(d) rule issued for the NLEB, the department has determined that the proposed activity may affect, but will not result in prohibited take of the NLEB. The activity involves tree removal, but will not occur within 0.25 miles of a known hibernacula, nor will the activity remove a known maternity roost tree or any other tree within 150 feet of a known maternity roost tree.

Clearing is restricted from June 1 to July 31.

If additional trees need to be removed, no Clearing shall occur without prior approval from the engineer, following coordination with the WisDOT REC. Additional tree removal beyond the area originally specified will require consultation with the United States Fish and Wildlife Service (USFWS) and may require a bat presence/absence survey. Notify the engineer if additional Clearing cannot be avoided to begin coordination with the WisDOT REC. The WisDOT REC will initiate consultation with the USFWS and determine if a survey is necessary.

Submit a schedule and description of Clearing operations with the ECIP 14 days prior to any Clearing operations. The department will determine, based on schedule and scope of work, what additional erosion control measures shall be implemented prior to the start of Clearing operations, and list those additional measures in the ECIP.

## **Construction Staging**

The rehabilitation of the South 35<sup>th</sup> Street Bridge over the Kinnickinnic River shall be undertaken in four major stages as shown on the traffic control plans and described below:

During Stage 1 the west side of the bridge shall remain functional with one lane for the northbound traffic and one lane for the southbound traffic while the east side of the bridge is closed for construction. Pedestrian access shall be maintained on the west side of the bridge.

During Stage 2 the entire bridge is closed, for approximately seven calendar days within Stage 1, to allow for the pouring and curing of the concrete deck on the east side. Maintain pedestrian access from Stage 1.

During Stage 3 the east side of the bridge shall be open with one northbound lane and one southbound lane while the west side of the bridge is closed. Pedestrian access shall be maintained on the east side of the bridge.

During Stage 4 the entire bridge is closed, for approximately seven calendar days within Stage 3, to allow for the pouring and curing of the concrete deck on the west side. Maintain pedestrian access from Stage 3.

#### **4. Traffic.**

Undertake traffic control according to standard spec 643 and/or as approved by the engineer, except as hereinafter modified.

Submit to the engineer for approval a detailed traffic control plan for any changes to the proposed traffic control detail as shown on the plans. Submit this plan ten days prior to the preconstruction conference.

Provide 24 hours-a-day availability of equipment and forces to expeditiously restore lights, signs, or other traffic control devices that are damaged or disturbed, in accord with standard spec 643.3.1(6). The cost to maintain and restore the above items shall be considered incidental to the item as bid and no additional payment will be made.

Supply the name and telephone number of a local contact person for traffic control repair prior to or at the preconstruction conference.

Have available at all times sufficient experienced personnel to promptly install, remove and reinstall the required traffic control devices to reroute traffic during the construction operations.

During all construction operations, maintain adequate turning provisions for vehicles, including buses and trucks, at the intersections that are to remain open.

Local access to residences and businesses within the project area shall be maintained to the maximum extent possible. No residential or commercial drive approach shall be closed without sufficient notice given to the occupants of the premise to remove their vehicles prior to removal or closing of the drive approach access. Reasonable access to abutting business locations shall be maintained at all times.

On-street parking will not be allowed during construction.

In the event where emergency vehicles and equipment which provide fire, police, and rescue service for the public need access to properties, the contractor shall cooperate to the fullest extent in accommodating emergency access in the shortest possible time.

All construction vehicles and equipment entering or leaving traffic lanes shall yield to through traffic.

The City of Milwaukee will provide all posting of no parking restrictions, necessary to facilitate construction operations. Contact Mrs. Sharon Betthausen at (414) 286-3632, three working days prior to the start of construction.

When an area of the roadway is temporarily closed to traffic, sign and delineate the portion of the roadway that is to remain open, according to Part 6 of the Manual on Uniform Traffic Control Devices (MUTCD), and the WisDOT manual titled "Guidelines for Construction, Maintenance, & Utility Operations".

#### **5. Holiday Work Restrictions.**

Do not perform work on, nor haul materials of any kind along or across any portion of the highway carrying South 35th Street traffic, and entirely clear the traveled way and shoulders of such portions of the highway of equipment, barricades, signs, lights, and any other material that might impede the free flow of traffic during the following holiday periods:

- From noon Friday, May 24, 2019 to 6:00 AM Tuesday, May 28, 2019 for Memorial Day;
- From noon Wednesday, July 3, 2019, to 6:00 AM Friday, July 5, 2019 for Independence Day;
- From noon Friday, August 30, 2019, to 6:00 AM Tuesday, September 3, 2019 for Labor Day.

stp-107-005 (20050502)

## **6. Utilities.**

This contract does not come under the provision of Administrative Rule Trans 220.

stp-107-066 (20080501)

Coordinate construction activities with a call to Digger's Hotline or a direct call to the utilities that have facilities in the area as required by statutes. Use caution to ensure the integrity of underground facilities and maintain code clearances from overhead facilities at all times.

Note: Bidders are advised to contact each utility company listed in the plans prior to preparing their bid to obtain current information on the status of each utility company's work required in association with the project. Existing trees, street light poles, hydrants and utility poles are to remain in place during construction unless noted on plans. Conduct an on-site visit prior to bidding to determine any special measures required for proper clearance between the trees, hydrants, poles, other utilities and any other physical structures and the construction equipment. During construction operations, keep all manholes accessible to utility companies for emergencies.

### **City of Milwaukee – Communications**

Facilities are located within the project limits, including conduits attached to Structure P-40-511.

Existing circuits will be moved to cables outside of the project area and impacted cables will be cut and pulled out of the conduits prior to construction. Existing sub-duct within the conduits will be discontinued in place.

Work will be done in October of 2018. No work is proposed during construction.

Contact Bryan M. Pawlak, DPW/Communications at (414) 286-3686 with concerns or questions.

### **City of Milwaukee - City Underground Conduit (CUC)**

There is an existing CUC package suspended from the South 35<sup>th</sup> Street Bridge. The removal of the conduit is incidental to the bridge removal. All cables located within the conduit on the bridge will be removed prior to the start of construction.

A new 4-duct conduit package is to be installed suspended from the bridge as shown on the plans and included in the contract. New conduit will be installed by the contractor extending both north and south of the abutments and tied into the existing CUC packages as shown on the plans. There are two existing CUC manholes that will need to be adjusted to grade by the contractor.

All CUC work including conduit installation, sawing concrete encased packages, conduit suspended from the bridge and manhole adjustments are incorporated into the contract documents and shown in the plan set.

Contact Karen Roney at (414) 286-3243 with concerns or questions.

### **City of Milwaukee – Sewers**

Underground facilities are located within the project limits. No work and or adjustments of these facilities are anticipated, in conjunction with this project.

Contact Mr. Zafar Yousuf at (414) 286-2467 with concerns or questions.

### **City of Milwaukee - Street Lighting**

Facilities are located within the project limits.

Existing street lighting pole located at Station 1+75; 36' RT and Station 3+60, 40' LT will be removed before construction starts. Temporary overhead circuitry will be installed north and east of the bridge over the roadway to keep the remaining street lights working during construction.

During and after construction permanent underground street lighting facilities will be reinstalled.

The street lighting contact below will need to be kept informed on the status of the project to coordinate street lighting work with the bridge contractor.

Contact Mr. Dennis Miller at (414) 286-5942 with concerns or questions.

## **City of Milwaukee - Water Works**

Underground facilities are located within the project limits. No work and or adjustments of these facilities are anticipated, in conjunction with this project.

Contact Mr. Dave Goldapp at (414) 286-6301 with concerns or questions.

## **Milwaukee Metropolitan Sewage District (MMSD)**

Underground facilities are located within the project limits.

MMSD has (6) manholes within the project limits.

Structure BSO601P (3) Manholes: these will not be adjusted, new finished pavement will match existing at approximately Station 2+26, 4' RT.

Manhole BSO601D: this will not be adjusted, new finished pavement will match existing at approximately Station 2+21, 3' LT.

Manhole BSO601C: this will not be adjusted, new finished pavement will match existing at approximately Station 2+27, 19' LT.

Manhole 07707: repair and minor adjustment will be done during paving operations by MMSD at Station 3+64, 3' LT. Contact Anthony Jackson at (414) 841-9553 at least 5 days prior to schedule work. MMSD anticipates 3 working days to complete the work.

Contact Mr. Larry Anderson at (414) 225-2241 with concerns or questions.

## **Charter/Spectrum**

Overhead facilities are located within the project limits, they will be relocated to the west side of S. 35<sup>th</sup> street prior to construction.

Charter to place temporary 30' class 5 poles at/near Station 2+42, LT 43.5' and Station 4+04, LT 44'. Charter will detach existing strand and fiber and reattach to temporary poles. When bridge work is complete, the strand and fiber will be relocated back to the original poles, and the temporary poles will be removed.

Contact Mr. Steve Cramer at (414) 277-4045 with concerns or questions.

## **We Energies - Electric**

Overhead facilities are located within the project limits, they will be relocated to the west side of S. 35<sup>th</sup> street prior to construction.

When working with a crane, load, or load line in the vicinity of overhead electrical facilities, the contractor will be required to maintain a minimum clearance of 20 feet. There are alternatives to the 20-foot minimum clearance, please see Table A of Section 1407-1411 of the OSHA Small Entity Compliance Guide for Final Rule for Cranes and Derricks in Construction.

The We Energies neutral conductor is a multi-grounded neutral conductor and part of a multi-grounded system as defined in the National Electrical Safety Code as adopted and amended by the Wisconsin State Electrical Code. Because the multi-grounded neutral conductor is visibly grounded at the point of work and also multiple other locations, no specific working clearance is required between the crane or load and the multi-grounded neutral conductor. However, some clearance is to be maintained between the crane or load and the multi-grounded neutral conductor to avoid any physical damage to the conductor or adjacent structures.

Contact Mr. Alex Dantine at (920) 621-6903 with concerns or questions.

## **We Energies – Gas**

Facilities are located within the project limits.

Gas Main is to be discontinued in place at Station 0+64, 28' RT to Station 4+69, 26' RT.

Work will be done in October of 2018. No work is proposed during construction.

Contractor may remove the discontinued pipe pursuant to the following:

- It is imperative that the highway contractor contact We Energies before removing any gas facilities or electrical underground cables, to verify that they have been discontinued and carry no natural gas or electrical current. The contractor must not assume that unmarked facilities have been discontinued. At no time is it acceptable to push, pull, cut or drill an unmarked facility without explicit consent from We Energies. Contractor must call the We Energies 24 hour Dispatch lines to arrange for this verification.
- We Energies Electric Dispatch #1-800-662-4797
- We Energies Gas Dispatch #1-800-261-5325
- If the line has been verified by We Energies to be dead per the above paragraph, it is the responsibility of the contractor to remove and dispose of all sections of the discontinued facility necessary for them to continue with the project.

Contact Mr. Alex Dantine at (920) 621-6903 with concerns or questions.

## **7. Information to Bidders, U.S. Army Corps of Engineers Section 404 Permit.**

The department has obtained a U.S. Army Corps of Engineers Section 404 permit. Comply with the requirements of the permit in addition to requirements of the special provisions. A copy of the permit is available from the regional office by contacting Rebecca Graser at (651) 290-5728.

stp-107-054 (20080901)

## **8. Environmental Protection, Aquatic Exotic Species Control.**

Exotic invasive organisms such as VHS, zebra mussels, purple loosestrife, and Eurasian water milfoil are becoming more prolific in Wisconsin and pose adverse effects to waters of the state. Wisconsin State Statutes 30.07, "Transportation of Aquatic Plants and Animals; Placement of Objects in Navigable Waters", details the state law that requires the removal of aquatic plants and zebra mussels each time equipment is put into state waters.

At construction sites that involve navigable water or wetlands, use the follow cleaning procedures to minimize the chance of exotic invasive species infestation. Use these procedures for all equipment that comes in contact with waters of the state and/or infested water or potentially infested water in other states.

Ensure that all equipment that has been in contact with waters of the state, or with infested or potentially infested waters, has been decontaminated for aquatic plant materials and zebra mussels before being used in other waters of the state. Before using equipment on this project, thoroughly disinfect all equipment that has come into contact with potentially infested waters. Guidelines from the Wisconsin Department of Natural Resources for disinfection are available at:

<http://dnr.wi.gov/topic/invasives/disinfection.html>

Use the following inspection and removal procedures:

1. Before leaving the contaminated site, wash machinery and ensure that the machinery is free of all soil and other substances that could possibly contain exotic invasive species;
2. Drain all water from boats, trailers, bilges, live wells, coolers, bait buckets, engine compartments, and any other area where water may be trapped;
3. Inspect boat hulls, propellers, trailers and other surfaces. Scrape off any attached mussels, remove any aquatic plant materials (fragments, stems, leaves, seeds, or roots), and dispose of removed mussels and plant materials in a garbage can before leaving the area or invested waters; and
4. Disinfect your boat, equipment and gear by either:
  - 4.1. Washing with ~212 F water (steam clean), or
  - 4.2. Drying thoroughly for five days after cleaning with soap and water and/or high pressure water, or
  - 4.3. Disinfecting with either 200 ppm (0.5 oz per gallon or 1 Tablespoon per gallon) Chlorine for 10-minute contact time or 1:100 solution (38 grams per gallon) of Virkon Aquatic for 20- to 30-minute contact time. Note: Virkon is not registered to kill zebra mussel veligers nor invertebrates like spiny water flea. Therefore this disinfect should be used in conjunction with a hot water (>104° F) application.

Complete the inspection and removal procedure before equipment is brought to the project site and before the equipment leaves the project site.

stp-107-055 (20130615)

## **9. Erosion Control.**

The contractor shall prepare and submit an erosion control implementation plan (ECIP) for the project including borrow sites, material disposal sites, dust control, and dewatering according to Chapter TRANS 401 requirements. The erosion control implementation plan shall supplement information shown on the plans and shall not reproduce it. The erosion control implementation plan shall identify how the contractor intends to implement the project's erosion control plan.

Provide the ECIP 14 calendar days prior to the pre-construction conference. Provide 1 copy of the ECIP to WisDOT and 1 copy of the ECIP to the WDNR Liaison (Ms. Kristina Betzold; WDNR Southeast Region Headquarter; 2300 N. Dr. Martin Luther King Jr. Dr.; Milwaukee, WI 53212). Pursue operations in a timely and diligent manner, continuing all construction operations methodically from the initial removals and topsoil stripping operations through the subsequent grading, paving, and re-topsoiling to minimize the period of exposure to possible erosion. Do not implement the ECIP until it has been approved by the department.

Re-topsoil graded areas, as designated by the engineer, immediately after grading is completed within those areas. Place sod, as designated by the engineer, within five calendar days after placement of topsoil.

When performing roadway cleaning operations, the contractor shall use equipment having vacuum or water spray mechanism to eliminate the dispersion of dust. If vacuum equipment is employed, it shall have suitable self-contained particulate collectors to prevent discharge from the collection bin into the atmosphere.

Stockpile excess material or spoils on upland areas away from wetlands, floodplains and waterways. Stockpiled materials/and/or spoils shall be protected against erosion. Piles of stockpiled soil shall be protected against erosion and shall not create nuisance dust emissions. Said materials and/or spoils shall not be stockpiled for more than 14 calendar days.

Use Silt fence on the side slopes, and use erosion mat if needed which is paid under item Erosion Mat Class II Type C. Do not place erosion control perpendicular to flow in stream.

If erosion mat is used along stream banks, it shall be biodegradable and non-netted, or if netted, constructed more loosely so that small animals are able to work their way through. Long-term netted mats cause animals to become entrapped while moving in and out of the stream. Avoid the use of fine mesh matting that is tied or bonded at the mesh intersection such that the openings between the mesh are fixed in size.

Avoid construction during any rain event. Should stream flow conditions change during the course of construction, modifications to your proposed erosion control may be necessary.

The rehabilitation of the existing structure should occur with limited material entering the waterway. Maintain an unimpeded, natural stream flow condition at all times through the structure during rehabilitation to maintain the integrity of the stream environment.

Do not place any fills in waterways or wetlands for work pads.

Reuse incidental amounts of sediment that are excavated during bridge rehabilitation in project area.

## **10. Erosion Control Structures.**

Within seven calendar days after beginning work on the bridge superstructure, place all permanent erosion control devices, including riprap, erosion mat, ditch checks, or any other item required by the contract or deemed necessary by the engineer. These devices shall be in place in the area under the bridge and on both sides of the roadway, from the waterway to a point 100-feet behind the backwall of the abutment. Within said limits, place these devices to a height equivalent to the calculated water elevation resulting from a storm that occurs on the average of once every two years (Q2) as shown on the plan, or as the engineer directs. Before initial construction operations, place turbidity barriers, silt screens, and



other temporary erosion control measures as the plans show, and remove them after the permanent erosion control devices are in place unless directed otherwise by the engineer.

In the event that construction activity does not disturb the existing ground below the Q2 elevation, the above timing requirements for permanent erosion control will be waived.

#### **11. Construction Over or Adjacent to Navigable Waters.**

The Kinnickinnic River is classified as a state navigable waterway under standard spec 107.19.

stp-107-060 (20171130)

#### **12. Notice to Contractor – Lead-Based Paint.**

The potential exists for lead based paint. Use appropriate and adequate health and safety measures to protect site workers from an unsafe exposure to residual lead and to avoid a lead release into the surrounding environment during demolition. Handling and disposal of lead based materials shall be according to all applicable state and federal regulations.

#### **13. Notice to Contractor – Notification of Demolition and/or Renovation No Asbestos Found.**

John Roelke, License Number ALL-119523, inspected Structure P-40-511 for asbestos on October 27, 2015. No regulated Asbestos Containing Material (RACM) was found on this structure. A copy of the inspection report is available from: David Tapia at (414) 286-2453.

In accordance with NR447 and DHS159, ensure that DNR or DHS receives a completed Notification of Demolition and/or Renovation (DNR Form 4500-113 (R 4/11), or subsequent revision) via U.S. mail, hand-delivery, or using the online notification system at least 10 working days before beginning any construction or demolition. Pay all associated fees. Provide a copy of the completed 4500-113 form to Joan Bonack and DOT BTS-ESS attn: Hazardous Materials Specialist PO Box 7965, Madison, WI 53707-7965. In addition, comply with all local or municipal asbestos requirements.

Use the following information to complete WisDNR form 4500-113:

- Site Name: Structure P-40-511, S. 35<sup>th</sup> Street Over Kinnickinnic River
- Site Address: 0.2M South Junction STH 24
- Ownership Information: City of Milwaukee, 841 North Broadway, Milwaukee, WI 53202
- Contact: Joan Bonack
- Phone: (262) 521-5351
- Age: 56 years old. This structure was constructed in 1962.
- Area: 8330 SF of deck

Insert the following paragraph in Section 6.g.:

- If asbestos not previously identified is found or previously non-friable asbestos becomes crumbled, pulverized, or reduced to a powder, stop work immediately, notify the engineer, and the engineer will notify the department's Bureau of Technical Services at (608) 266-1476 for an emergency response as specified in standard spec 107.24. Keep material wet until it is abated or until it is determined to be non-asbestos containing material.

stp-107-125 (20120615)

#### **14. Notice to Contractor – Emerald Ash Borer.**

##### **Clearing and Grubbing**

This applies to projects in the emerald ash borer (EAB) quarantined zones to include the following counties:

Brown	Crawford	Fond du Lac	Kenosha
La Crosse	Milwaukee	Ozaukee	Racine
Sheboygan	Vernon	Washington	Waukesha

*Supplement standard spec 151-1.3 for airport construction, with the following:*

The emerald ash borer (EAB) has resulted in a quarantine of ash trees (*Fraxinus sp.*) by the Wisconsin Department of Agriculture, Trade, and Consumer Protection (DATCP) and the Wisconsin Department of Natural Resources (DNR).

Ash trees species attacked by emerald ash borer include the following:

- Green ash (*F. pennsylvanica*) is found throughout the state, but is most common in southern Wisconsin. It may form pure stands or grow in association with black ash, red maple, swamp white oak, and elm. It grows as an associate in upland hardwood stands, but is most common in and around stream banks, floodplains, and swamps.
- black ash (*F. nigra*) is distributed over the entire state but is most frequently found in northern Wisconsin. It is most common in swamps, but is also found in other wet forest types.
- Blue ash (*F. quadrangulata*) is a threatened species that is currently found only at a few sites in Waukesha County. The species is at the edge of its range in Wisconsin, but is common in states farther south. The species is not of commercial importance. Blue ash twigs are 4-sided.
- White ash (*F. americana*) tends to occur primarily in upland forests, often with sugar maple (*Acer saccharum*).

The quarantine of ash trees includes all horticultural cultivars of the species listed above.

Note that blue ash twigs are 4-sided. All other Wisconsin ash trees have round stems.

Also, Mountain ash (*Sorbus americana* and *S. decora*) is not a true ash and is not susceptible to EAB infestation.

The contractor shall be responsible for hiring a certified arborist to identify all ash trees that will be cleared and grubbed for the project. In addition, prior to scheduled clearing and grubbing activities, the arborist shall mark all ash trees with florescent lime flagging tied around the trunk perimeter.

Follow and obey the following Wisconsin Department of Agriculture, Trade, and Consumer Protection order:

**ATCP 21.17 Emerald ash borer; import controls and quarantine.**

**Importing or Moving Regulated Items from Infested Areas; Prohibition.**

Except as provided in subparagraph (3), no person may do any of the following:

- Import a regulated item under sub. (2) into this state if that item originates from an emerald ash borer regulated area identified in 7CFR 301.53-3.

Move any regulated item under sub. (2) out of an emerald ash borer regulated area that is identified in 7CFR 301.53-3 and located in this state.

Note: the United States Department of Agriculture-Animal and Plant Health Inspection Service (USDA-APHIS) periodically updates the list of regulated areas in 7CFR 301.53-3. subsection (1) applies to new regulated areas as those areas are identified in the CFR.

**Regulated Items.** The following are regulated items for purposes of subparagraph (1):

- The emerald ash borer, *Agrilus planipennis* Fairmaire in any living stage.
- Ash trees. Ash limbs, branches, and roots.
- Ash logs, slabs or untreated lumber with bark attached.
- Cut firewood of all non-coniferous species.
- Ash chips and ash bark fragments (both composted and uncomposted) larger than one inch in diameter.

- Any other item or substance that may be designated as a regulated item if a DATCP pest control official determines that it presents a risk of spreading emerald ash borer and notifies the person in possession of the item or substance that it is subject to the restrictions of the regulations.

## **Regulatory Considerations**

The quarantine means that ash wood products may not be transported out of the quarantined area.

Clearing and grubbing includes all ash trees that are to be removed from within the project footprint. If ash trees are identified within clearing and grubbing limits of the project, the following measures are required for the disposal:

### **Chipped Ash Trees**

May be left on site if used as landscape mulch within the project limits. If used as mulch on site, chips may not be applied at a depth greater than standard mulch applications as this will impede germination of seeded areas.

With the written permission of the engineer, chipped material may be buried on site within the airport property as directed by the engineer according to standard spec 201.3(14).

May be buried on adjacent properties to projects within the quarantined zone with prior approval of the engineer according to standard spec 201.3 (15).

May be trucked to a licensed landfill within the quarantined zone with the engineer's approval according to standard spec 201.3(15).

Burning chips is optional if in compliance with standard spec 201.3.

Chips must be disposed of immediately if not used for project mulching and may not be stockpiled and left on site for potential transport by others. Chips may be stockpiled temporarily if they will be used for project mulching and are not readily accessible to the public.

Chipper equipment must be cleaned following post-chipping activities to ensure no spread of wood chip debris into non-quarantined counties.

### **Ash logs, Branches, and Roots**

May be buried without chipping within the existing right-of-way or on adjacent properties according to standard spec 201.3 (14)(15).

May be trucked to a licensed landfill within the quarantined zone with the engineer's approval according to standard spec 201.3 (15).

Burning is optional if in compliance with standard spec 201.3.

Ash logs, branches, and roots must be disposed of immediately and may not stockpile.

All additional costs will be incidental to clearing and grubbing items.

Do not bury or use mulch in an area that will be disturbed again during later phases of the project.

Anyone moving firewood or ash products from the state or these counties is subject to state and federal fines up to \$1,000.00. All fines are the responsibility of the contractor.

Obtain updated quarantine information at the DNR Firewood Information Line at 1 (800) 303-WOOD.

### **Furnishing and Planting Plant Materials**

Ash trees may be obtained from inside or outside the quarantine area and planted within the quarantined area. Ash trees from within the quarantine area may not be transported and planted into the non-quarantined area.

### **Updates for Compliance**

Each year, as a service, the Wisconsin department of agriculture, trade and consumer protection distributes an updated federal CFR listing to nursery license holders and other affected persons in this state. More frequent updates, if any, are available on the Department of Agriculture, Trade, and Consumer Protection (DATCP) website at [www.datcp.state.wi.us](http://www.datcp.state.wi.us). subsection (1) applies to new regulated areas as those areas are identified in the CFR, regardless of whether affected persons receive update notices from the DATCP. Persons may request update notices by calling (608) 224-4573, by visiting the DATCP website, or by writing to the following address:

### **Regulated Items**

More frequent updates, if any, are available on the DATCP website at [www.datcp.state.wi.us](http://www.datcp.state.wi.us). subsection (1) applies to new regulated areas as those areas are identified in the CFR, regardless of whether affected persons receive update notices from DATCP. Persons may request update notices by calling (608) 224-4573, by visiting the DATCP website, or by writing to the above address.

### **15. Archaeological Site.**

Kinnickinnic River Parkway site is located approximately Station 1+66.50 to Station 5+11.00 RT/LT within the limits shown on the plans.

Notify the Bureau of Technical Services – Environmental Process and Document Section (BTS-EPDS) at (608) 266-0099 at least two weeks before commencement of any ground disturbing activities. BTS-EPDS will determine if a qualified archaeologist will need to be on site during construction of this area.

Do not use the site for borrow or waste disposal. Do not use the site area not currently capped by asphalt/concrete for the staging of personnel, equipment and/or supplies.

stp-107-220 (20180628)

### **16. Public Convenience and Safety.**

*Replace standard spec 107.8(6) with the following:*

Check for and comply with all local ordinances governing the hours of operation, of construction equipment. Do not operate any motorized construction equipment from 9:00 PM until 7:00 AM, unless prior written approval is obtained from the engineer.

Motorized equipment shall be operated in compliance with all applicable local, state, and federal laws and regulations relating to noise levels. All motorized construction equipment will be required to have mufflers constructed according to manufacturer's specifications, and it will be required that mufflers and exhaust systems be maintained in good working order, free from leaks or holes.

Upon request the City of Milwaukee's Department of Neighborhood Services (DNS), may issue a construction noise variance, to work outside of the hours listed above.

Department of Neighborhood Services  
4001 South 6<sup>th</sup> Street  
(414) 286-2268

### **17. Coordination with Milwaukee County Transit (MCTS).**

During construction of any pedestrian accommodations, at or adjacent to bus stops, MCTS will coordinate with the contractor to determine where temporary bus stops should be installed. MCTS crews will remove the existing bus stop signs/shelters and MCTS will install temporary signs. Contact MCTS at least ten working days before relocation of bus stops is required.

The removal of the sidewalk, at any existing bus stop location must occur in conjunction with the placement of the temporary surface that will provide access to the temporary bus stop location.

For Stages 2 and 4, MCTS plans to use 37<sup>th</sup> Street between Forest Home Avenue and Manitoba Street for north-south Route 35. This will require the following *no parking anytime*:

- E/S of 37<sup>th</sup> Street from Forest Home Avenue to Manitoba Street
- W/S of 37<sup>th</sup> Street from Manitoba Street to north 50-feet

- N/S and S/S of Manitoba Street from 37<sup>th</sup> Street to east 50-feet
- N/S and S/S of Manitoba Street from 35<sup>th</sup> Street to west 50-feet

All bus stops are located outside the scope of the project. For the detour via 37<sup>th</sup> Street, the following stops would be temporarily discontinued during stages 2 and 4:

- Northbound 35<sup>th</sup> Street and Dakota, #4701
- Southbound 35<sup>th</sup> Street and Dakota, #4629

No bus shelters will be impacted by this project.

Contact Mr. David Locher at (414) 343-1727 with concerns or questions.

#### **18. Notice to Contractor – Restoration within Right-of-Way.**

Excavation and restoration for installation of sidewalk shall be limited to 9 inches, beyond the back (high side) of the sidewalk, unless otherwise shown on the plans. This includes installation of sod lawn. Contractor must stay within right-of-way unless a construction permit has been obtained.

#### **19. Notice to Contractor – Work without a Construction Permit.**

All work including the removal and replacement of sidewalk and sod must be done within the right-of-way, unless construction permit authority has been obtained, to work on private property abutting the project.

#### **20. Notice to Contractor – Survey.**

Digital design file information/existing surface data, including design surface DTMs and/or coordinate system GPS information will not be available for this project. As such, machine grading will not be possible.

#### **21. Notice to Contractor – Work within Milwaukee County Parks System.**

Contractor shall protect and avoid damage to any part of the Project Area and surrounding areas to ensure the safety of its personnel, County staff and all park users. Contractor shall also provide and install all safety devices, barricades, signs, flag person(s) or other measures as needed to comply. Contractor shall conduct reasonable and appropriate restoration work to correct any rutting, re-seed disturbed areas, prevent the spread of invasive species, repair any damage to trails, and take the necessary steps to safely work in any environmentally sensitive areas. Contractor shall "decontaminate" their equipment before arriving and/or leaving a project area in order to prevent the spread of invasive species."

#### **22. Coordination with Milwaukee County Parks System.**

The Parks Department requires that the contractor looking to access/work on county property for a project that will involve land disturbance or digging no matter how big or small requires a right-of-entry permit signed by the Parks Director or his/her designee. Right-of-entry permits can be obtained at Milwaukee County Parks, 9480 Watertown Plank Road, Wauwatosa, WI 53226.

The county assumes no responsibility for any loss or damage to the personal property of the vendor while in use or stored at or on the premises.

**23. Removing Old Structure Over Waterway With Minimal Debris Station 3+04.48, Item 203.0600.S.001.**

Conform to standard spec 203 as modified in this special provision.

*Add the following to standard spec 203:*

**203.3.6 Removals Over Waterways and Wetlands**

**203.3.6.2 Removing Old Structure Over Waterway with Minimal Debris**

- (1) Remove the existing Structure P-40-511 over the Kinnickinnic River in large sections and conforming to the contractor's approved structure removal and clean-up plan. During superstructure removal, prevent all large pieces and minimize the number of small pieces from entering the waterway or wetland. Remove all reinforcing steel, all concrete, and all other debris that falls into the waterway or wetland. The contractor may leave limited amounts of small concrete pieces scattered over the waterway floor or wetland only if the engineer allows.
- (2) Submit a structure removal and clean-up plan as part of the erosion control implementation plan required under standard spec 107.20. Do not start work under the structure removal and clean-up plan without the department's written approval of the plan. Include the following information in the structure removal and clean-up plan:
  - Methods and schedule to remove the structure.
  - Methods to control potentially harmful environmental impacts.
  - Methods for superstructure removal that prevent all large pieces and minimize the number of small pieces from entering the waterway or wetlands.
  - Methods to control dust and contain slurry.
  - Methods for removing piers and abutments. If blasting in water, include restrictions that regulatory agencies and the contract require.
  - Methods for cleaning the waterway or wetlands.
- (3) If stockpiling spoil material, place it on an upland site an adequate distance from the waterway, wetland, or any open water created by excavation. Install silt fence between the spoil pile and the waterway, wetland, or excavation site.

*Add the following Removing Old Structure bid item to standard spec 203.5.1:*

ITEM NUMBER	DESCRIPTION	UNIT
203.0600.S.001	Removing Old Structure Over Waterway With Minimal Debris Station 3+04.48	LS
stp-203-020 (20170615)		

**24. Protection of Concrete.**

*Supplement standard spec 415.3.14 as follows:*

Provide for a minimum of one concrete finisher to remain on the project site after final finishing of all concrete surfaces until such time as the concrete has hardened sufficiently to resist surface scarring caused by footprints, handprints, or any other type of imprint, malicious or otherwise. Finisher must actively and continuously patrol on foot the newly placed concrete and repair any damage to the surface that might be sustained as described above.

Include the cost for providing the finisher(s), the necessary equipment, and materials in the contract unit price for each concrete item.

**25. Concrete Identification Stamping.**

Stamp ends of all monolithic portland cement concrete surfaces with a stamp bearing the contractor's name and the year of construction. Make all letters 2-inches in height.

Include the cost of this work in the contract unit price for other Portland cement concrete items and no additional payment will be made.

## 26. Expansion Device, P-40-511.

### A Description

This special provision describes furnishing and installing an expansion device as the plans show conforming to standard spec 502 as modified in this special provision.

### B Materials

The minimum thickness of the polychloroprene strip seal shall be 1/4 inch for non-reinforced elastomeric glands and 1/8 inch for reinforced glands. Furnish the strip seal gland in lengths suitable for a continuous one-piece installation at each individual expansion joint location. Provide preformed polychloroprene strip seals that conform to the requirements ASTM D3542, and have the following physical properties:

Property Requirements	Value	Test Method
Tensile Strength, min.	2000 psi	ASTM D412
Elongation @ Break, min	250%	ASTM D412
Hardness, Type A, Durometer	55 ± 5 pts.	ASTM D2240
Compression Set, 70 hours @212°F, max.	35%	D395 Method B Modified
Ozone Resistance, after 70 hrs. at 100°F under 20% Strain with 100 pphm ozone	No Cracks	ASTM D1149 Method A
Mass Change in Oil 3 after 70 hr. 212°F Mass Change, max.	45%	ASTM D471

Install the elastomeric strip seal gland with tools recommended by the manufacturer, and with a lubricant adhesive conforming to the requirements of ASTM D4070.

The manufacturer and model number shall be one of the following approved strip seal expansion device products:

Manufacturer	Model Number Strip Seal Gland Size <sup>[1]</sup>		
	4-Inch	5-Inch	6-Inch
D.S. Brown	SSA2-A2R-400	SSA2-A2R-XTRA	SSA2-A2R-XTRA
R.J. Watson	RJA-RJ400	RJA-RJ500	RJA-RJ600
Watson Bowman Acme	A-SE400	A-SE500	A-SE800
Commercial Fabricators	A-AS400	-----	-----

<sup>[1]</sup> Expansion device strip seal gland size requirement of 4", 5", and 6" shall be as the plans show.

Furnish manufacturer's certification for production of polychloroprene represented showing test results for the cured material supplied, and certifying that it meets all specified requirements.

The steel extrusion or retainer shall conform to ASTM designation A 709 grade 36 steel. After fabrication, steel shall be galvanized conforming to the requirements ASTM A123.

Manufacturer's certifications for adhesive and steel shall attest that the materials meet the specification requirements.

stp-502-020 (20171130)

## 27. Field Office, Type C, Item 642.5201.

*Supplement standard spec 642 by adding the following:*

The contractor shall locate the field office, at a distance that is not greater than ½ mile from the project location.

## **28. Traffic Control.**

Perform the work under this item according to the requirements of standard spec 643, as shown on the plans or as approved by the engineer, except as herein modified.

No operation may proceed until all traffic control devices for such work are in the proper location.

Have available at all times sufficient experienced personnel to promptly install, remove and reinstall the required traffic control devices to route traffic in order to perform the operations.

Provide the City of Milwaukee Police Department and the engineer a 24-hour emergency contact number with which the contractor or his representative can be contacted during non-working hours in the event a safety hazard develops.

Mask out all traffic control signs and have flags removed when not in use.

The traffic requirements are subject to change at the direction of the engineer in the event of an emergency.

Receive prior approval from the engineer for the location of egress or ingress for construction vehicles to prosecute the work.

Park or store equipment and materials only at work sites approved by the engineer.

Do not disturb, remove, or obliterate any traffic control signs, advisory signs, shoulder delineators, or beam guard in place along the traveled roadways without the approval of the engineer.

Install appropriate advance and intermediate warning signs of standard design. Install the signs at locations indicated on the plan and at locations as directed by the engineer according to Part VI of the Manual of Uniform Traffic Control Devices. Sign shape, message and color must be according to Part VI of the Manual of Uniform Traffic Control Devices.

## **29. Removing Bearings, P-40-511, Item 506.7050.S.001.**

### **A Description**

This special provision describes raising the girders and removing the existing bearings, as the plans show.

### **B (Vacant)**

### **C Construction**

Raise the structure's girders and remove the existing bearings as the plans show.

Obtain prior approval from the engineer for the method of jacking the girders and of supporting them as required.

### **D Measurement**

The department will measure Removing Bearings P-40-511 by the unit for each bearing removed.

### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
506.7050.S.001	Removing Bearings, P-40-511	EACH

Payment is full compensation for raising the bridge girders; and for removing the old bearings.

Cost of furnishing and installing the bearings will be paid for under separate bid items.

stp-506-035 (20130615)



**30. Epoxy Injection Crack Repair, Item 509.9025.S;  
Cored Holes 2-Inch Diameter, Item 509.9026.S.**

**A Description**

This special provision describes repairing structural cracks in piers using the epoxy injection method, and coring 2 inch diameter core samples the repaired cracks.

Conform to standard spec 509 as modified in this special provision.

**B Materials**

Furnish epoxy injection material that is insensitive to the presence of water and is composed of a two-component epoxy resin designed specifically for structurally re-bonding cracks in Portland cement concrete. The epoxy injection material shall conform to the following physical properties at 77 degrees F:

	Unmixed		Mixed
	Component A (Resin)	Component B (Catalyst)	
Weight per gallon, lbs	9.15 ±0.1	8.2 ±0.1	9.15 ±0.1
Viscosity, cps	500-700	120-160	275-350
Specific Gravity, g/cc	1.128 ±0.012	0.984 ±0.012	1.099 ±0.012
Color Straw	Straw	Straw	Straw
Shelf Life (closed containers)	2 years	2 years	---
Solids by Weight	---	---	100%
Pot Life (200 gram mass)	---	---	12-15 mins.
Mixing Ratio (by weight)	80%	20%	---
Mixing Ratio (by volume)	78%	22%	---
Bond Strength	---	---	2000 psi min
Shrinkage Resistance	---	---	ASTM C883
Thermal Compatibility	---	---	ASTM C884

Furnish surface seal material for confining the injected epoxy resin in the cracks that meets the following requirements:

1. Adequate strength to hold the injection fittings firmly in place to resist injection pressures and prevent leakage during injection
2. Non-sag consistency
3. Insensitive to the presence of water
4. Controlled cure time
5. Two-component epoxy resin
6. 100% solids by weight
7. Applicable to wet surfaces
8. Viscosity should be paste

**C Construction**

**C.1 Injection Equipment**

Use equipment to meter and mix the two-epoxy resin components and to inject the mixture into the cracks. The equipment shall be portable and have positive displacement type pumps equipped with an interlock to provide positive ration control of exact proportions of the two components at the nozzle. Use electric or air powered pumps that provide in-line metering and mixing.

Use injection equipment that has automatic pressure control capable of discharging the mixture at any present pressure up to 160 psi (±5 psi), and is equipped with a manual pressure control override.

The equipment shall have the capability of maintaining the volume ratio for the mixture prescribed by the manufacturer of the epoxy resin material within a tolerance of ±5% by volume at any discharge pressure up to 160 psi.

The injection equipment shall be equipped with sensors on both the Component A and B reservoirs that will automatically stop the machine when only one component is being pumped to the mixing head.

## **C.2 Surface Area Preparation**

Clean the surface areas adjacent to cracks of all dirt, dust, grease, oil, efflorescence, or other foreign matter, which may be detrimental to adhesion of the surface seal material. Acids and corrosives will not be permitted for cleaning.

Install injection ports along the cracks on both faces of the pier at intervals of 4 to 10 inches, or as appropriate to accomplish full penetration of the injection resin. Center the injection ports over the cracks and secure in place using surface seal material. Where possible, install the injection ports over the widest areas of the cracks.

Apply the surface seal material to the face of the crack between the entry ports. For known through cracks, apply the surface seal material to both faces of the member. Before proceeding with the injection operation, allow sufficient time to elapse for the surface seal material to gain adequate strength.

## **C.3 Epoxy Injection**

Install the epoxy injection resin according to the manufacturer's instructions.

During installation, in general, limit pressures to 35 psi at the point of entry into the crack.

On vertical cracks, start the injection at the lowest point and continue upward along the crack. While injecting, resin should flow to and out of the next higher port. When this flow is established, cap the lower port and continue the injection until all ports have been injected and flow has been established between them.

On horizontal cracks, follow the same procedures used for vertical cracks; start the injection at one end and continue the injection in succession along the crack until all ports have been injected and flow has been established between them.

## **C.4 Finishing and Clean-Up**

When cracks are completely filled, cure the epoxy resin for a sufficient length of time so that when the surface seal is removed, there is no draining or runback of the epoxy material from the cracks. Grind, or use other appropriate method, to remove surface seal material, excess epoxy material, and injection ports. No epoxy material shall extend beyond the plane of the surfaces of the in-situ concrete.

## **C.5 Core Sampling**

To determine if the crack injection is complete, obtain two 2 inch diameter core samples from the repaired pier. Take the cores to the depth of the element or at least 12 inches. Take the cores at locations selected by the engineer. The engineer will have the option of increasing or decreasing the number of cores taken.

The injection shall be considered complete if more than 90% of the crack void, to 12 inches deep, is filled with the epoxy resin in each of the samples taken. If the injection is incomplete, re-injection and additional cores may be required.

Repair the core holes left in the member using one of the two following methods:

1. Fill core holes with an epoxy mortar consisting of one part epoxy injection resin to four parts clean, dry, bagged fine aggregate mixed by volume. Match the finish repair to the surrounding surface.
2. Fill core holes with an epoxy mortar consisting of one part epoxy gel to one part clean, dry, bagged fine aggregate mixed by volume. Match the finish repair to the surrounding surface.

## **D Measurement**

The department will measure Epoxy Injection Crack Repair in length by the linear foot crack, acceptably repaired.

The department will measure Cored Holes 2-Inch Diameter as each individual cored hole as approved by the engineer and acceptably completed. Additional cores taken as required by the engineer after re-injection (due to incomplete injection) will not be measured for payment. Additional cores taken by the contractor that are not ordered by the engineer will not be measured for payment.

## **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid items:

ITEM NUMBER	DESCRIPTION	UNIT
509.9025.S	Epoxy Injection Crack Repair	LF
509.9026.S	Cored Holes 2-Inch Diameter	EACH

Payment is full compensation for furnishing and placing the epoxy sealant, including any cleaning before and after injection; coring samples of the work; inspecting the core samples; and for repairing the core holes left in the member.

stp-509-025 (20100709)

## **31. Structure Repainting General.**

### **A General**

#### **A.1 Inspection**

On all structures in this contract, notify the engineer of any missing or broken bolts or nuts, any missing or broken rivets, or of any cracks or flaws in the steel members while cleaning or painting.

#### **A.2 Date Painted**

At the completion of all painting work, stencil in black paint or contrasting color paint the date of painting the bridge. The numbers shall be three inches (75 mm) in height and shall show the month and year in which the painting was completed: e.g., 11-95 (November 1995). On each bridge painted, stencil the date at two locations. On truss bridges, stencil the date on the cover plates of end posts near and above the top of the railings at the oncoming traffic end. On steel girder bridges, stencil the date on the inside of the outside stringers at the abutments. The date on grade separation bridges shall be readable when going under the structure or at some equally visible surface near the ends of the bridge, as designated by the engineer.

#### **A.3 Graffiti Removal**

Remove any graffiti on concrete abutments, piers, pier caps, parapet railings, slope paving or any other location at the direction of the engineer. Use a brush sandblast to remove graffiti.

The above work will not be measured and paid for separately, but will be considered incidental to other items in the contract.

### **B (Vacant)**

### **C Construction**

#### **C.1 Repainting Methods**

Do not perform blasting, cleaning and painting on days of high winds. Prevailing winds in excess of 15 mph (25 km/hr) shall be considered high winds.

Place the final field coat of paint on the exterior of the exterior beams as a continuous painting operation. Stop at splices, vertical stiffeners or other appropriate locations so that lap marks are not evident or noticeable.

Completely clean and remove spent abrasive and other waste materials resulting from the contractor's operation from bridge deck surfaces, gutter lines, drains, curbs, bridge seats, pier caps, slope paving, roadway below, and all structural members and assemblies.

#### **C.2 Inspection**

*Add the following to standard spec 105.9:*

Furnish, erect and move scaffolding and other equipment to allow the inspector to closely observe all affected surfaces. The scaffolding, with appropriate safety devices, shall meet the approval of the engineer.

stp-517-005 (20150630)

## **32. Labeling and Disposal of Waste Material.**

The EPA ID number for Structure P-40-511 is WIR000168641.

The state has an exclusive mandatory use contract with a private waste management contractor to transport and dispose of hazardous waste.

The state's waste management contractor shall furnish and deliver appropriate hazardous waste containers and site-specific labels to each bridge site. The provided containers shall be placed at pre-selected drop-off and pick-up points at each bridge site, and these locations shall be determined at the preconstruction conference. The custody of the containers and labels shall be the responsibility of the painting contractor while they are at the job site.

Contact the waste management contractor a minimum of one week in advance of the start of the project to request container drop-off. Provide the waste management contractor with the project ID, structure number, EPA ID, and the agreed-upon location for container staging. Contact information for the waste management contractor is located on the WisDOT Internet site at

<http://wisconsindot.gov/Documents/doing-bus/eng-consultants/cnslt-rsrcs/environment/hazwaste-contacts.pdf>.

Report all reportable spills and discharges according to the contingency plan.

Labels are site-specific. Check the labels to ensure that the project ID, structure number, and EPA ID match the structure generating the waste. Apply a label to each drum when it is opened for the first time. Fill in the date on the label the first day material is accumulated in the drum. The following page is an example of a properly filled-in label.

During paint removal operations, continuously monitor and notify the project inspector of the status of waste generation and quantity stored so that timely disposal can be arranged.

HAZARDOUS WASTE

WW-5257580999-001-01-0

# STORAGE LABEL

RQ, HAZARDOUS WASTE, SOLID, n.o.s.,  
(LEAD), 9, NA3077, III, (D008)

Enter the date that waste  
materials were first placed into  
the container

EPA CODE: E/D008 STATE: S

WIP#: 391498

WIP DESC: BRIDGE SAND WITH LEAD

DATE ACCUMULATED: 07/01/2005

HAZARDOUS WASTE – FEDERAL LAW PROHIBITS IMPROPER DISPOSAL IF FOUND,  
CONTACT THE NEAREST POLICE OR PUBLIC SAFETY AUTHORITY OR THE U.S.  
ENVIRONMENTAL PROTECTION AGENCY.

WISC DOT BRIDGE # B-29-53/54

I-94 OVER CTH H

PROJECT ID # 5882-03-70

CAMP DOUGLAS, WI 54618

(608) 963-0871

GENERATOR EPA ID  
WIR000121103

Project ID Number on  
label must match the  
Project Number  
assigned by the  
WIDOT

Bridge Number and  
Address on label must  
match specific bridge  
from which waste was  
generated.

EPA ID Number on  
label is specific to the  
bridge from which the  
waste is generated.

stp-517-055 (20180628)

### **33. Preparation and Coating of Top Flanges P-40-511, Item 517.0900.S.001.**

#### **A Description**

This special provision describes thoroughly cleaning and coating the top surface and edges of the top flanges, removing loose paint, rust, mill scale, dirt, oil, grease, or other foreign substances until the specified finish is obtained.

#### **B (Vacant)**

#### **C Construction**

For top flanges and edges that have no paint on them and according to the department's Pre-Qualified Paint Systems for Structure Overcoating Cleaning and Priming, clean the top surface and edges of the top flanges and paint them with one coat of an approved zinc rich primer. Paint for Solvent Cleaning for Overcoat-minimum Cleaning (SP-1) is not allowed.

For top flanges and edges that have paint on them and according to the department's Pre-Qualified Paint Systems for Structure Overcoating Cleaning and Priming, clean all areas of rust and loose paint on the top surface and edges of the top flanges. Wash the top surface and edges of the top flanges and paint them with one coat of an approved zinc-rich primer according to paint manufacture's recommendations. If flash rusting occurs before the application of the primer, stop painting application, remove the flash rusting and paint cleaned surface. Paint for Solvent Cleaning for Overcoat-minimum Cleaning (SP-1) is not allowed.

Where plans call for the cleaning of other painted structural steel including hanger assemblies, bearings, field splices, and connections, clean areas of loose paint and rust according to the department's Pre-Qualified Paint Systems for Structure Overcoating Cleaning and Priming, or and according to paint manufacture's cleaning recommendations. Sound paint need not be removed with the exception of an area 12 inch on either side of hanger assembly centerlines. Clean this area to base metal according to the paint manufacture's cleaning recommendations and paint them one coat of an approved zinc-rich primer according to paint manufacture's recommendations. Paint for Solvent Cleaning for Overcoat-minimum Cleaning (SP-1) is not allowed.

For areas of exposed steel members that are to be imbedded in new concrete and according to the department's Pre-Qualified Paint Systems for Structure Overcoating Cleaning and Priming, thoroughly clean the surface area of exposed steel members that are to be imbedded in the new concrete and solvent wash and paint one coat of an approved zinc rich primer according to paint manufacture's recommendations to these areas. Paint for Solvent Cleaning for Overcoat-minimum Cleaning (SP-1) is not allowed.

According to the approved project specific hazardous material containment plan, furnish and erect tarpaulins or other materials to collect all of the spent paint containing material resulting from blasting or hand and power tool cleaning and coating. Minimize dust during all clean-up activities. Collect and store waste material at the end of each work day or more often if needed. Store waste materials in the hazardous waste containers provided. Lock and secure all waste containers at the end of each work day. Cover containers at all times except when adding or removing waste material. Store the containers in an accessible and secured area, not located in a storm water runoff course, flood plain or exposed to standing water. Transportation and disposal of such waste material will be the responsibility of the department.

Damage to existing painted surfaces as a result of construction operations, shall be restored to the approval of the engineer at the contractor's expense.

#### **D Measurement**

The department will measure Preparation and Coating of Top Flanges (Structure) as a single complete lump sum unit of work for the structure, completed according to the contract and accepted.

#### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
517.0900.S.001	Preparation and Coating of Top Flanges P-40-511	LS

Payment is full compensation for preparing and cleaning the designated surfaces; and for furnishing and applying the coating.

stp-517-010 (20140630)

### **34. Concrete Staining P-40-511, Item 517.1010.S.001.**

#### **A Description**

This special provision describes providing a two coat concrete stain on the exposed concrete surfaces of structures as the plans show.

#### **B Materials**

##### **B.1 Mortar**

Use mortar for sack rubbing the concrete surfaces as given in standard spec 502.3.7.5 or use one of the following products:

Preblended, Packaged Type II Cement:	Tri-Mix by TK Products
	Thorseal Pearl Gray by Thoro Products

The mortar shall contain one of the following acrylic bonding admixtures mixed and applied according to manufacturer's recommendations:

Acrylic Bonding Admixture:	TK-225 by TK Products
	Achro 60 by Thoro Products
	Achro Set by Master Builders

##### **B.2 Concrete Stain**

Use concrete stain manufactured for use on exterior concrete surfaces, consisting of a base coat and a pigmented sealer finish coat. Use the following products, or equal as approved by the department, as part of the two coat finish system:

Tri-Sheen Concrete Surfacers, Smooth by TK Products
Tri-Sheen Acrylic by TK Products
TK-1450 Natural Look Urethane Anti-Graffiti Primers by TK Products
Safe-Cure and Seal EPX by Chem Masters
H&C Concrete Stain Solid Color Water Based by Sherwin-Williams

#### **C Construction**

##### **C.1 General**

Furnish, prepare, apply, cure, and store all materials according to the product manufacturer's specifications for the type and condition of application required.

Match or exceed the stain manufacturer's minimum recommended curing time of the concrete or 28 days, whichever is greater, before staining.

##### **C.2 Preparation of Concrete Surfaces**

Provide a sack rubbed finish as specified in standard spec 502.3.7.5, using mortar as indicated above on concrete surfaces with open voids or honeycombing.

Following the sack rubbing, clean all concrete surfaces that are to be coated to ensure that the surface is free of all laitance, dirt, dust, grease, efflorescence, and any foreign material and that the surface will accept the coating material according to product requirements. As a minimum, clean the surface using a 3000-psi water blast. Hold the nozzle of the water blaster approximately 6 inches from the concrete surface and move it continuously in a sweeping motion. Give special attention to smooth concrete surfaces to produce an acceptable surface texture. Correct any surface problems resulting from the surface preparation methods. Grit blasting of the concrete surface is not allowed.

##### **C.3 Staining Concrete Surfaces**

Apply the concrete stain according to the manufacturer's recommendations.

Apply the concrete stain when the temperature of the concrete surface is 45° F or higher, or as given by the manufacturer.

The color of the stain shall be as given on the plan. Tint the base coat to match the finish coat; the two coats shall be compatible with each other.

Do not begin staining the structure until earthwork operations are completed to a point where this work can begin without receiving damage. Where this work is adjacent to exposed soil or pavement areas, provide temporary covering protection from overspray or splatter.

#### **C.4 Test Areas**

Before applying stain to the structure, apply the stain to sample panels measuring a minimum of 48 inches x 48 inches and constructed to demonstrate workmanship in the use of the form liner specified on the structure if applicable. Match or exceed the stain manufacturer's minimum recommended curing time of the concrete or 28 days, whichever is greater, before staining. Prepare the concrete surfaces of the sample panels and apply stain using the same materials and in the same manner as proposed for the structure, including staining of the joints between the stones produced by the form liner if applicable. Do not apply stain to the structure until the department approves the test panels.

#### **C.5 Surfaces to be Coated.**

Apply concrete stain to the surfaces according to the plan.

#### **D Measurement**

The department will measure Concrete Staining (Structure) in area by the square foot of surface, acceptably prepared and stained.

#### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
517.1010.S.001	Concrete Staining P-40-511	SF

Payment is full compensation for furnishing and applying the two coat system; for preparing the concrete surface; and for preparing the sample panels.

stp-517-110 (20140630)

### **35. Structure Repainting Recycled Abrasive P-40-511, Item 517.1800.S.001.**

#### **A Description**

This special provision describes surface preparation and painting of the metal surfaces according to the manufacturer's recommendations as modified in this special provision.

#### **A.1 Areas to be Cleaned and Painted**

All structural metal surfaces of:

1. Structure P-40-511 9,980 SF.

Areas are approximate and given for informational purposes only.

#### **B Materials**

##### **B.1 Coating System**

Furnish a complete coating system from the department's approved list for "Structure Repainting Recycle Abrasive Structure". The color for the finish coating material shall match the color number the plans show according to Federal Standard Number 595B, as printed in 1989. Supply the engineer with the product data sheets for approval before any coating is applied. The product data sheets shall indicate the mixing and thinning directions, the recommended spray nozzles and pressures, and the minimum drying time between coats.

The color of the primer must be such that a definite contrast between it and the color of the blasted steel is readily apparent. There shall be a color contrast between all subsequent coats for the paint system selected. Submit color samples of the primer and all coats to the engineer for approval before any application of paint.

#### **C Construction**

##### **C.1 Surface Preparation**

Before blast cleaning, solvent clean all surfaces to be coated according to SSPC-SP1.

All metal surfaces must be blast cleaned according to SSPC-SP10 and verified before painting.



Upon completion of surface preparation, test representative surfaces, which were previously rusted (i.e. pitted steel) for the presence of residual chloride. Perform Surface Contamination Tests (SCAT) according to the manufacturer's recommendations. The tests must be witnessed by the engineer. If chlorides are detected at levels greater than 7ug/cm<sup>2</sup>, continue to clean the affected areas until results are below the specified limit. Submit anticipated testing frequencies and chloride remediation methods to the engineer for review and approval.

Apply the prime coat the same day that the metal surfaces receive the No. 10 blast or re-blast before application. Cleaned surfaces shall be of the specified condition immediately before paint application. If rust bloom occurs before applying the primer, stop the painting operation in the area of the rust bloom and re-blast and clean the area to SSPC SP-10 before applying the primer.

The steel grit and any associated equipment brought to the site and used for blast cleaning shall be clean. Remove immediately dirty grit or equipment brought to the site at no expense to the department. Furnish an abrasive that has a gradation such that it will produce a uniform surface profile between 1 to 3 mils on the steel surface, as measured according to ISO 8503-5.

The abrasive blasting and recovery system shall be a completely integrated self-contained system for abrasive blasting and recovery. It shall be an open blast and recovery system that will allow no emissions from the recovery operation. The recovery equipment shall be such that the amount of contaminants in the clean recycled steel grit shall be less than 1 percent by weight as per SSPC AB-2.

Remove by grinding all fins, tears, slivers, and burred or sharp edges that are present on any steel member, or that appear during the blasting operation, and re-blast the area to give a 1 to 3 mils surface profile.

Remove all spent material and paint residue from steel surfaces with a good commercial grade vacuum cleaner equipped with a brush-type cleaning tool, and test cleanliness according to ASTM D4285. The airline used for surface preparation shall have an in-line water trap and the air shall be free of oil and water as it leaves the airline.

Take care to protect freshly coated surfaces from subsequent blast cleaning operations. Thoroughly wire brush damaged primed surfaces with a non-rusting tool, or if visible rust occurs, re-blast to a near white condition. Clean and re-prime the brushed or blast cleaned surfaces according to this specification.

## **C.2 Coating Application**

Apply paint according to the manufacturer's recommendations in a neat workmanlike manner. Paint application shall normally be by airless spray or inaccessible areas by brush, roller or other methods approved by the engineer.

The engineer may allow the use of conventional spray equipment after satisfactory demonstration by the contractor of the proper application technique and handling of that equipment.

Mix the paint or coatings according to the manufacturer's directions to a smooth lump-free consistency. Keep paint thoroughly mixed during the painting application.

After the inspector approves the entire cleaned surface to be coated, apply a prime coat uniformly to the entire surface. Either before or after applying the prime coat, brush or spray a stripe coat of primer on all plate edges, bolt heads, nuts, and washers. Apply succeeding coats as the product data sheet shows.

Remove all dry spray by vacuuming, wiping, or sanding if necessary.

If the application of the coating at the required thickness in one coat produces runs, bubbles, or sags; apply a "mist-coating" in multiple passes of the spray gun; separate the passes by several minutes. Where excessive coating thickness produces "mud-cracking", remove such coating back to soundly bonded coating and re-coat the area to the required thickness.

The resultant paint film shall be smooth and uniform, without skips or areas of excessive paint according to SSPC PA1.

The coating is supplied for normal use without thinning. If in cool weather it is necessary to thin the coating for proper application, thin according to the manufacturer's recommendations.

During surface preparation and coating application the ambient and steel temperature shall be between 39 degrees F and 100 degrees F. The steel temperature shall be at least 5 degrees F above the dew point temperature. (This requires the steel to be dry and free of any condensation or ice regardless of the actual temperature of the steel.) The relative humidity shall not exceed 85%. The manufacturer's ambient condition requirements must be followed if they are more stringent.

Paint thickness shall be within the requirements for a three coat paint system listed in the department's approved list for Structure Repainting Recycle Abrasive Structure and the paint system being used.

Time to recoat shall be according to the manufacturer's recommendations.

The dry film thickness will be determined by use of a magnetic film thickness gage. The gage shall be calibrated for dry film thickness measurement according to SSPC-PA 2. Dry film thickness in each area measured will be based on an average of three gage readings, after calibration of the gage to account for surface profile of the bare steel as a result of surface preparation.

#### **D Measurement**

The department will measure Structure Repainting Recycled Abrasive (Structure) as a single complete lump sum unit of work, completed according to the contract and accepted.

#### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
517.1800.S.001	Structure Repainting Recycled Abrasive P-40-511	LS

Payment is full compensation for preparing and cleaning the designated surfaces; furnishing and applying the paint; and for providing the listed equipment.

stp-517-050 (20150630)

### **36. Negative Pressure Containment and Collection of Waste Materials, P-40-511, Item 517.4500.S.001.**

#### **A Description**

This special provision describes providing a dust collector to maintain a negative air pressure in the enclosure; furnishing and erecting enclosures as required to contain, collect and store waste material resulting from the preparation of steel surfaces for painting, and repainting, including collection of such waste material, and labeling and storing waste material in approved hazardous waste containers.

#### **B (Vacant)**

#### **C Construction**

Erect an enclosure to completely enclose (surround) the blasting operations. The ground, slope paving, or roadway cannot be used as the bottom of the enclosure unless covered by approved containment materials. So that there are no visible emissions to the air or ground or water, design, erect, operate, maintain and disassemble the enclosures in such a manner to effectively contain and collect dust and waste materials resulting from surface preparation and paint over spray. Suspend all enclosures over water from the structure or as approved by the engineer.

Construct the enclosure of flexible materials such as tarpaulins or of rigid materials such as plywood, or of a combination of flexible and rigid materials and meet SSPC Guide 6 requirements with Level 1 emissions. Systems manufactured and provided by Eagle Industries, Detroit Tarps, or equal, are preferred. The tarpaulins shall be a non-permeable material, either as part of the tarp system or have a separate non-permeable lining. Maintain all materials free of tears, cuts or holes. The vertical sides of the enclosure shall extend from the bottom of the deck down to the level of the covered work platform or covered barge where used for structures over water, and shall be fastened securely to those levels to prevent the wind from lifting them. Bulkheads are required between beams to enclose the blasting area as approved by the engineer. Where bulkheads are required, construct them of plywood and properly seal them. To prevent spent materials and paint over spray from escaping the enclosed area, overlap and fasten together all seams. Place groundcovers under all equipment before operations or as approved by the engineer.

To allow proper cleaning, inspection of structures or equipment, and painting, provide safe adequate artificial lighting in areas where natural light is inadequate.

Provide a dust collector so that there are no visible emissions outside of the enclosure and so that a negative air pressure inside the enclosure is maintained. The dust collector shall be sized to maintain the minimum air flow based on the cross-sectional area of the enclosure.

A combination of positive air input and negative air pressure may be needed to maintain the minimum airflow within the enclosure.

Filter all air exhausted from the enclosure to create a negative pressure within the enclosure so as to remove all hazardous and other particulate matter.

After all debris has been removed and all painting has been approved in the containment area is complete, remove containment according to SSPC Guide 6.

As a safety factor for structures over water, provide for scum control. Provide a plan for corrective measures to mitigate scum forming and list the procedures, labor and equipment needed to assure compliance. Effectively contain the scum that forms on the water and does not sink in place from moving upstream or downstream by the use of floating boom devices.

If in the use of floating boom devices the scum tends to collect at the devices, contain, collect, store the scum, and do not allow it to travel upstream or downstream beyond the devices. Remove the scum at least once a day or more often if needed.

Collect and store at the bridge site for disposal all waste material or scum collected by this operation, or any that may have fallen onto the ground tarps. Collect and store all waste material and scum at the end of each workday or more often if needed. Storage shall be in provided hazardous waste containers. Label each container as it is filled, using the labels provided by the Hazardous Waste Disposal contractor. Check the label and ensure that the project ID, bridge number and EPA ID match the structure. Fill in the generation date when the first material is placed in the container. Secure all containers at the end of each workday. Keep the containers covered at all times except to add or remove waste material. Store the containers in an accessible and secured area, not located in a storm water runoff course, flood plain, or exposed to standing water.

In a separate operation, recover the recyclable abrasive for future application, and collect the paint and/or corrosion particles for disposal.

#### **D Measurement**

The department will measure Negative Pressure Containment and Collection of Waste Materials P-40-511 as a single complete lump sum unit of work for each structure designated in the contract, completed according to the contract and accepted.

#### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
517.4500.S.001	Negative Pressure Containment and Collection of Waste Materials P-40-511	LS

Payment is full compensation for designing, erecting, operating, maintaining, and disassembling the containment devices; providing negative pressure exhaust ventilation; collecting, labeling, and for storing spent materials in provided hazardous waste containers.

stp-517-065 (20140630)

### **37. Portable Decontamination Facility, Item 517.6001.S.**

#### **A Description**

This special provision describes furnishing and maintaining weekly, or more often if needed, a single unit portable decontamination facility.

#### **B Materials**

Supply and operate all equipment according to OSHA.

Supply adequate heating equipment with the necessary fuel to maintain a minimum temperature of 68° F in the facility.

The portable decontamination facility shall consist of a separate "Dirty Room", "Shower Room" and "Clean Room". The facility shall be constructed so as to permit use by either sex. The facility shall have adequate ventilation.

The "Dirty Room" shall have appropriately marked containers for disposable garments, clothing that requires laundering, worker shoes, and any other related equipment. Each container shall be lined with poly bags for transporting clothing, or for disposal. Benches shall be provided for personnel.

The "Shower Room" shall include self-contained individual showering stalls that are stable and well secured to the facility. Provide showers with a continuous supply of potable hot and cold water. The wastewater must be retained for filtration, treatment, and/or for proper disposal.

The "Clean Room" shall be equipped with secure storage facilities for street clothes and separate storage facilities for protective clothing. The lockers shall be sized to store clothing, valuables and other personal belongings for each worker. Benches shall be provided for personnel.

Supply a separate hand wash facility, either attached to the decontamination facility or outside the containment.

### **C Construction**

Properly contain, store, and dispose of the wastewater.

### **D Measurement**

The department will measure Portable Decontamination Facility by each individual unit, acceptably completed.

### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
517.6001.S	Portable Decontamination Facility	EACH

Payment is full compensation for furnishing and maintaining a portable decontamination facility.

stp-517-060 (20140630)

## **38. Temporary Curb Ramp, Item 644.1601.S.**

### **A Description**

This special provision describes providing, maintaining, and removing temporary curb ramps.

### **B Materials**

Furnish materials as follows:

- Asphaltic surface conforming to standard spec 465.2.
- Engineer-approved ready mixed concrete or ancillary concrete conforming to standard spec 602.2 except no QMP is required.
- Commercially available prefabricated curb ramps conforming to Americans with Disabilities Act Accessibility Guidelines.

Furnish yellow detectable warning fields conforming to Americans with Disabilities Act Accessibility Guidelines. Use either an engineer-approved surface-applied type or cast iron from the department's approved products list.

### **C Construction**

Provide and maintain temporary curb ramps, including detectable warning fields, throughout the project duration. Place and compact a dense graded aggregate foundation before placing the curb ramp, unless the curb ramp is to be placed on existing roadway surface.

Remove and dispose temporary curb ramps and associated detectable warning fields when no longer required.

### **D Measurement**

The department will measure temporary curb ramps by each individual ramp acceptably completed.

### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
644.1601.S	Temporary Curb Ramp	EACH

Payment is full compensation for providing, maintaining, and removing temporary curb ramps.

stp-644-020 (20150630)

### 39. Temporary Pedestrian Safety Fence, Item 644.1616.S.

#### A Description

This special provision describes providing, maintaining, and removing the temporary pedestrian safety fence.

#### B Materials

Furnish notched metal "T" or "U" shaped fence posts weighing 1 1/3 pounds per foot or more.

Furnish select 2x4 dimensional lumber.

Furnish fence fabric meeting the following requirements.

<b>Color:</b>	International orange (UV stabilized)
<b>Roll Height:</b>	4 feet
<b>Mesh Opening:</b>	1 inch min to 3 inch max
<b>Resin/Construction:</b>	High density polyethylene mesh
<b>Tensile Yield:</b>	Avg. 2000 lb per 4-ft. width (ASTM D638)
<b>Ultimate Tensile Strength:</b>	Avg. 3000 lb per 4-ft. width (ASTM D638)
<b>Elongation at Break (%):</b>	Greater than 100% (ASTM D638)
<b>Chemical Resistance:</b>	Inert to most chemicals and acids

The engineer may allow prefabricated fencing systems conforming to Americans with Disabilities Act Accessibility Guidelines.

#### C Construction

Provide a continuous safety fence with the top edge free of sharp or rough edges.

Repair or reconstruct installations disturbed during construction operations. Remove and dispose of as specified in standard spec 204.3 when no longer required.

#### D Measurement

The department will measure Temporary Pedestrian Safety Fence by the linear foot, acceptably completed.

#### E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
644.1616.S	Temporary Pedestrian Safety Fence	LF

Payment is full compensation for providing, maintaining, and removing the temporary pedestrian safety fence.

stp-644-025 (20150630)

### 40. Temporary Pedestrian Barricade, Item 644.1810.S.

#### A Description

This special provision describes providing, maintaining, and removing temporary pedestrian barricades.

#### B Materials

Furnish materials listed on the department's approved products list.

### **C Construction**

Install a continuous temporary pedestrian barricade with the top edge free of sharp or rough edges.

Place the bottom of lower rail a maximum of 2 inches above the ground.

Repair or reconstruct disturbed installations when necessary. Remove when work is complete.

### **D Measurement**

The department will measure Temporary Pedestrian Barricade by the linear foot, acceptably completed.

### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
644.1810.S	Temporary Pedestrian Barricade	LF

Payment is full compensation for providing, maintaining, and removing temporary pedestrian barricades.

stp-644-030 (20170615)

## **41. Inlet Cover Type MS 57, Item SPV.0060.102.**

### **A Description**

Perform work under these items according to the requirements of standard spec 611 and the details as shown on the plans.

### **B Materials**

Furnish materials under these items according to the requirements of standard spec 611 and the details as shown on the plans.

### **C (Vacant)**

### **D Measurement**

The department will measure Inlet Cover, Type MS 57 by each unit in place, furnished, installed, and acceptably completed.

### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.102	Inlet Cover Type MS 57	EACH

Payment is full compensation for furnishing and installing the inlet covers.

## **42. Manhole Cover Type MS 58-A, Item SPV.0060.103.**

### **A Description**

Perform work under these items according to the requirements of standard spec 611 and the details as shown on the plans.

### **B Materials**

Furnish materials under these items according to the requirements of standard spec 611 and the details as shown on the plans.

### **C (Vacant)**

### **D Measurement**

The department will measure Manhole Cover Type MS 58-A by each unit in place, furnished, installed, and acceptably completed.

### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.103	Manhole Cover Type MS 58-A	EACH

Payment is full compensation for removing and salvaging the existing covers; providing new covers, including frames, lids, and for adjusting each cover. Old covers removed remain the City of Milwaukee's property.

#### **43. Storm Inlet Type 45A, Item SPV.0060.112.**

##### **A Description**

Perform work under these items according to the requirements of standard spec 611 and the details as shown on the plans.

##### **B Materials**

Furnish materials under these items according to the requirements of standard spec 611 and the details as shown on the plans.

##### **C (Vacant)**

##### **D Measurement**

The department will measure Storm Inlet Type 45A by each unit in place, furnished, installed, and acceptably completed.

##### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.112	Storm Inlet Type 45A	EACH

Payment is full compensation for providing materials, including masonry, making sewer connections to new or existing facilities, and other fittings; for excavating, backfilling, disposing of surplus material, and for cleaning out and restoring the work site; except that the department will pay for covers, including frames, grates and lids separately.

#### **44. Adjusting CUC Manhole Cover, Item SPV.0060.400.**

##### **A Description**

This special provision describes adjusting the existing chimney of the block, precast, or brick round manholes; furnishing, installing and removing protection of the cables in the manhole during adjustment operations. Perform work according to standard spec 611, as shown on the plans, and as hereinafter specified.

##### **B Material**

Furnish and install materials that conform to the requirements of standard spec 519. Salvage and reinstall existing covers on the manholes. The city will supply covers designated for replacement. Contractor shall contact Ricardo Lopez, Inventory Clerk at (414) 286-6123 prior to obtaining the frames and lids from the DPW Field Headquarters at 3850 N. 35<sup>th</sup> St. Contractor must have the "Castings Requisitions Form" which shall be supplied by the city at the Preconstruction Meeting to obtain the covers.

##### **C Construction**

Report any pre-existing problems to Ms. Karen Rogney of city Underground Conduits Section at (414) 286-3243 three working days in advance of any construction on manholes.

Before removing the pavement around the manhole, the contractor shall place a ¾-inch plywood cover or equal over existing active Street Lighting, Traffic Control, Communication or private vendor electrical cables. This cover shall be properly supported to/at the manhole floor.

Break out and remove pavement around manhole. Remove existing covers and store and secure them properly. Any damaged, lost, or stolen covers shall be the responsibility of the contractor and shall be replaced at contractor's expense.

Remove existing chimney to surface of concrete roof slab. If manhole does not have an existing concrete roof slab, remove sufficient chimney as to provide adequate corbel to fit new cast iron frame and cover.

Adjust manhole cover to proposed grade using bricks or concrete rings as necessary. Completely underpin entire flange area of manhole frame with mortar, bricks and/or concrete rings. Remove wedges/shims. Fill voids with grout. Do not back plaster inside walls.

After completion of paving, remove the temporary ¾-inch plywood cover or equal which is over the existing electrical cables in the manhole as mentioned above.

Notify Ms. Roney three working days in advance of completion of each manhole adjustment, for inspection and acceptance of work performed. The contractor will receive no payment until the above work is approved by city Underground Conduits.

#### **D Measurement**

The department will measure Adjusting CUC Manhole Cover by each unit, acceptably completed.

#### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.400	Adjusting CUC Manhole Cover	EACH

Payment is full compensation for furnishing all required materials, exclusive of frames, grates, or lids available and designated for adjusting; and for removing, reinstalling and adjusting the covers. Covers to be adjusted and which are rendered unfit for use by the contractor through the contractor's operations shall be replaced by the contractor in kind at the contractor's own cost and expense.

### **45. Sawing Concrete-Encased Duct Package, Item SPV.0060.426.**

#### **A Description**

The work under this provision consists of full depth sawing of cement encased multiple duct conduit below grade; preparing sawed conduit ends to accept adaptor couplings needed to allow transition of new PVC conduit from existing clay, fiber or PVC conduit (See Item SPV.0090.404).

#### **B (Vacant)**

#### **C Construction**

##### **Equipment**

- Use ring saw or concrete cutting chainsaw for all full-depth cuts. Use diamond blades. The contractor may use a high speed 16" construction saw on duct systems with less than 4-ducts when approved by the engineer.

##### **Sawing Encasement**

- Carefully expose the outside of the existing cement encasement. The contractor is to verify that the conduit lines are free of all cabling. Saw a full depth transverse cut through the encasement. Saw straight cuts with the surface remaining vertical over its full depth. Hand chip concrete away from sawed conduit duct ends to allow transition fittings to be placed over the ends. The exposed conduit will be protected from damage. Any damaged conduit ends will be the responsibility of the contractor and will require a resaw at the contractor's expense.

#### **D Measurement**

The department will measure Sawing Concrete-Encased Duct Package by each unit, acceptably completed. Up to 6 conduits per cement encasement will be considered a single unit.

Encasements in excess of 6 conduits will constitute multiple units.

#### **E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.426	Sawing Concrete-Encased Duct Package	EACH

Payment is full compensation for sawing concrete encased duct packages full depth.



**46. End Diaphragm Adjustment, Item SPV.0060.510.**

**A Description**

This special provision describes adjustment of the location of the existing 12C20.7 steel channel girder end diaphragms at north and south abutments.

**B Materials**

Furnish new 7/8 inch diameter ASTM A325 (AASHTO M164) bolts, ASTM A563 (AASHTO M291) nuts, and washers ASTM F436 (AASHTO M293). All materials to be hot dipped galvanized and according to standard spec 506.

**C Construction**

Remove all of the 12C20.7 steel channel end diaphragms from the gusset plates and/or transverse girder web at the ends of the girders at the north and south abutments.

For existing 12C20.7 steel channel girder end diaphragms; Drill two new 1 inch diameter holes in the gusset plates and/or transverse girder web 3 inches below the lowest pair of existing holes. Reposition the diaphragm minimum 3 inches lower than its original orientation and reattach the 12C20.7 steel channel to the gusset plate and/or transverse girder web with 6 bolts at each end. There are total of 20 existing 12C20.7 steel channel girder end diaphragms to be adjusted. Fill the abandoned holes in the gusset plates and/or transverse girder web by pug welding and grind smooth.

All work to be according to standard spec 506.

**D Measurement**

The department will measure End Diaphragm Adjustment by each unit, acceptably completed.

**E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.510	End Diaphragm Adjustment	EACH

Payment is full compensation for removing and reattaching the existing end diaphragms, and providing the associated new hardware for the connections.

**47. Marking Line Epoxy 6-Inch, Item SPV.0090.001.**

**A Description**

This special provision describes providing Epoxy Pavement Marking lines 6 inches wide.

**B Materials**

Furnish materials according to standard spec 646.

**C Construction**

Construct marking lines according to standard spec 646.

**D Measurement**

The department will measure Marking Line Epoxy 6-Inch by the linear foot, acceptably completed.

**E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0090.002	Marking Line Epoxy 6-Inch	LF

Payment is full compensation for cleaning and preparing the pavement surface, and for furnishing and installing the material.

**48. Construction Staking Concrete Sidewalk, SPV.0090.002.**

**A Description**

This special provision describes furnishing and setting construction stakes or control points, including all calculations required, necessary to establish the horizontal and vertical position of the concrete sidewalk as shown on the plans.

**B (Vacant)**

**C Construction**

**C.1 General**

Obtain or calculate benchmark data, grades, and alignment from data in the plan and verify with the engineer prior to beginning the work. The engineer will furnish horizontal alignment, horizontal alignment ties and control point data. This work shall include reestablishing the plan horizontal roadway alignment, alignment ties, and control points.

Obtain approval from the engineer prior to beginning the work for methods of survey and prior to beginning the work. The degree of accuracy used in the survey work shall be consistent with third order, class II. Establish additional benchmarks and control points as necessary or as directed by the engineer. Check plan dimensions, alignment, and elevations for accuracy with existing field conditions. Immediately call to the engineer's attention any errors and apparent discrepancies for correction or interpretation prior to proceeding with the work.

Maintain neat, orderly and complete survey notes and computations used in establishing the lines and grades. Make the survey notes and computations available to the engineer within 24 hours upon request as the work progresses.

**C.2 Concrete Sidewalk**

Place construction stakes for concrete sidewalk at intervals of 25 feet. A minimum of three stakes per cross section is required. Set and maintain as necessary additional stakes per cross section to achieve the required accuracy and to satisfy the contractors' method of operations. Set additional stakes as necessary to establish location and grade along intersecting road radii; and for auxiliary lanes, vertical curves, horizontal curves, and curve transitions. Locate all concrete sidewalk construction stakes to within 0.25 feet of the true horizontal position and establish the grade elevation to within 0.01 feet of the true vertical position.

**D Measurement**

The department will measure Construction Staking, Concrete Sidewalk by the linear foot along each roadway centerline or reference line, acceptably completed. When sidewalk occurs on both sides of the roadway, the quantity of Construction Staking, Concrete Sidewalk, will be measured by the linear foot along the centerline or reference line of each side of the roadway.

**E Payment**

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0090.002	Construction Staking, Concrete Sidewalk	LF

Payment is full compensation for all survey work necessary to locate and set all concrete sidewalk construction stakes including additional stakes per cross section set to achieve the required accuracy and to satisfy the contractors' method of operations including intersecting road radii, auxiliary lanes, vertical curves, horizontal curves, and curve transitions; for resetting damaged or missing concrete sidewalk construction stakes; and for furnishing all stakes, lath, flags.

**49. 4-Duct Conduit Cement Encased DB-60, Item SPV.0090.404**

**A Description**

This work consists of furnishing and installing cement encased multiple duct conduit packages below grade as shown on the plans and as hereinafter described.

## **B Materials**

### **B.1 Conduit**

Furnish and install 4-inch rigid nonmetallic DB-60 polyvinyl chloride (PVC) conduit. Conduit will be accepted on the basis of a Manufacturer's Certificate of Compliance and WISDOT field inspection upon delivery to a project.

PVC conduit and fittings shall conform to the requirements of Standard Specifications for Smooth-Wall Poly (Vinyl Chloride) (PVC) Conduit and Fittings for Underground Installation, ASTM Designation: F512 (latest edition).

### **B.2 Conduit Spacers**

Furnish and install nonmetallic interlocking base spacers and intermediate spacers that provide a 1" vertical and 1" horizontal separation between PVC pipes. The base spacers shall provide a 3" vertical separation from the trench bed to the bottom of the PVC pipes.

### **B.3 Conduit Bed**

Furnish and install a minimum 2" conduit bed of stone chips or crushed stone screenings conforming to the following:

#### **3/8 Inch Crushed Stone Chips**

Sieve Sizes	% Passing by Weight
1/2"	100
3/8"	90-100
No. 8	0-15
No. 30	0-3

#### **Crushed Stone Screenings**

Sieve Sizes	% Passing by Weight
1/2"	100
No. 4	75-100
No. 100	10-25

### **B.4 Concrete**

The type of concrete mix to be used to encase the ducts will be:

Type I Cement	280 lbs
Fly Ash	100 lbs
Sharp Torpedo Sand	3100 lbs
Water	35 gals
Chryso Air 260 or approved equal	2.0 ozs
Chryso Plast 209 or approved equal	7.0 ozs
Air	5%

Mix the materials to provide an approximate 3 inch slump

### **B.5 Slurry Backfill**

Aggregate slurry backfill consists of No. 1 concrete aggregate Class 'C' concrete mix with the cement deleted.

Fly Ash (Class C)	75 lbs.
Concrete Sand (Damp)	1830 lbs.
No. 1 Concrete Aggregate	1830 lbs.

Mix the materials with water to inundate the aggregate sufficiently to provide an approximate 3-inch slump. Deposit the mix in the trench directly from a concrete transit mix truck.

## B.6 Pull Rope

Pull rope specifications will be:

- Flat construction (7/16" to 5/8" wide)
- 100% woven aramid fiber (may include tracer wire)
- 1500 lbs. Minimum pull strength prelubricated
- sequential footage markings for location

For any questions on materials, contact Ms. Karen Roney at (414) 286-3243.

## C Construction

### C.1 Excavation

The excavation shall have the minimum or maximum dimensions shown on the plans and as follows:

Number of Ducts Wide	Minimum (Inches)	Maximum (Inches)
1	8 1/2	11
2	14 1/8	16 5/8
3	19 3/4	22 1/4
4	25 3/8	27 7/8
5	31	33 1/2
6	36 5/8	39 1/8
7	42 1/4	44 3/4
8	47 7/8	50 3/8

These minimum and maximum trench widths apply to standard 4 inch PVC electrical duct only. When required, the excavation may be widened for the handling and placing of materials.

Sheath and brace open-cut trenches as required by code and as necessary to maintain safety. The cost of furnishing, placing and removing of sheathing and bracing shall be included in the unit bid for the work.

The dimensions of the excavation will be governed by the number, configuration and the grade (cover) to which the conduit is to be installed as shown on the plan. The walls of the excavation shall be clean and true.

Prior to excavating trenches, expose the existing manhole and conduit lines. The object of this is to permit adjustments in line and grade to avoid special construction methods. Protect the exposed manhole and conduit from damage.

Lay the conduit at a depth so that sufficient protection from damage is provided. Allowable covers shall be as follows:

The standard cover for mainline conduit is 39 inches and the minimum cover acceptable is 28 inches.

Maintain the standard cover wherever possible and any deviation less than the minimum cover requires the approval of the engineer.

Grade the trench to have a minimum pitch of three inches per 100 feet. When an obstruction is encountered in the trench and it is necessary to excavate a deeper trench than would otherwise be required, in order to obtain drainage, refer the matter to the engineer to determine whether the extra excavation should be made.

In grading a trench for mainline conduit, there are three general practices for direction of pitch.

(a) When grading a trench in a street with a level grade, the high point of the trench bottom should ordinarily be centered between manholes and pitched downward equally toward each manhole.

(b) Where the street slopes in one direction, locate the high point of the trench bottom approximately 30 feet from the end wall of the higher manhole and grade toward both manholes.

(c) Where a steep grade is encountered, grade the trench at the minimum pitch from the end wall of the higher manhole to a point 20 feet plus or minus toward the lower manhole. From this point, follow the street grade at the standard cover to a point 20 feet plus or minimum away from the end wall of the lower manhole. From this point, the remainder of the section shall be laid at the normal pitch.

After the rough excavation is completed, prepare the bottom of the trench to receive the conduit. Bring the duct bed to the final grade by grading uniformly from the high point to the low or drainage points. Use stone chips or crushed stone screenings to grade the trench. The duct bed shall be a minimum of 2" in depth.

## **C.2 Placing of Duct**

Proceed with placing the ducts as soon as the duct bed has been completed. Inspect all ducts before placing to see that the bores are clean and free from mud, sand, etc. Use only ducts with a smooth bore, free from burrs, rough projections etc. Smooth off burrs or other rough areas likely to damage cable are found in the duct by rasping or scraping.

Place the duct on base spacers with the ends staggered so no two couplings are adjacent. This may be accomplished by the use of the short lengths in stock or cutting back full length sections to the desired lengths. If cut pieces are used, place the cut end at the manhole. Locate the base spacers within 2 feet of the end of each duct and one base spacer located in the middle of the duct.

Use full length pieces for the balance of the conduit line.

Formations of two ducts or more in height are to be carried forward in full formation, that is, as each tier of twenty foot lengths is laid, the next higher tier of ducts shall then be placed on the intermediate spacers. Place these intermediate spacers on top of the base spacers located within two feet from each duct end and one in the middle of each duct. Place the intermediate spacers and ducts for the remaining tiers. Glue each length into the adjoining coupling. A twist and push on the duct being placed will suffice for a water tight joint. Exercise caution in the driving operation, so that neither the coupling nor the duct will be split or damaged in any way. After the full formation has been completed, place wood trench and duct bracing on the ducts to prevent shifting or floating while the concrete envelope is being placed and during driving operation.

This procedure shall be followed with succeeding lengths, providing spacers at the proper intervals, until sufficient trench footage of completed formation has been placed and is ready to receive concrete encasement.

The terminating point for mainline conduit will be the inside manhole wall. Install a standard end bell fitting flush with the wall on all duct access points.

Install a #10 copper tracer wire along and above the centerline of the duct for encasement in the concrete. The wire shall be 4 feet longer than the run of conduit and be at least 2 feet long at each access point.

Install a pull rope in each run of conduit, as laid. The rope shall be 4 feet longer than the run of conduit and shall be doubled back at least 2 feet at each raceway access point. Anchor the pull rope at each access point in a manner acceptable to the engineer.

## **C.3 Concreting**

Begin concreting after sufficient conduit has been laid and the trench and duct have been inspected. The minimum concrete encasement of the ducts is 3 inches on the top, 2 inches on the sides, and 3 inches on the bottom. After placing, puddle the concrete with a splicing bar or similar tool so that complete duct encasement is accomplished. Remove wood braces used to keep the conduit from floating before the concrete sets completely and the resultant encasement voids filled with concrete.

Allow the concrete encasement to set for a minimum of 6 hours before backfilling is commenced.

## **C.4 Slurry Backfill**

4. Slurry Backfill. Commence backfilling of the conduit immediately after the duct has been inspected, approved and has set to withstand the load.

An aggregate slurry as specified shall be used to backfill the concrete encased conduit. The trench shall be backfilled to the proposed or existing subgrade. The mix shall be deposited in the trench directly from a concrete transit mix truck.

## **D Measurement**

The department will measure 4-Duct Cement Encased DB-60, furnished and installed at the locations on the plans, by the linear foot, acceptably installed. The measured quantity will equal the linear feet of encased duct, based on the distance along the centerline of duct between ends of conduit. City of Milwaukee shall have final acceptance.

## E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0090.404	4-Duct Conduit Cement Encased DB-60	LF

Payment is full compensation for furnishing the 4-inch conduit, conduit bodies, conduit fittings, conduit spacers, end caps and trace wire; for excavating, bedding, encasement and backfilling including any concrete, stone, aggregate slurry, bracing, or other related materials; for disposing of surplus materials; and for making inspections, and for installing the conduit.

## 50. Underdeck Utility Structure P-40-511, City of Milwaukee Communications Conduit, Item SPV.0105.400.

### A Description

This section describes furnishing and installing a duct package of four, 4-inch diameter, Fiberglass Reinforced Epoxy (FRE) conduits, the conduit support system including all deck inserts and hangars, and the abutment penetrations to the underside of the deck of Structure P-40-511 as shown on the plans.

### B Materials

Use material conforming to the class of material named and as specified. Conduit shall be non-metallic, filament-wound epoxy, suitable for direct burial, concrete encasement, and suspended from bridge members without regard to outdoor ambient light. The product shall contain carbon black to provide ultraviolet protection.

The conduit shall have an interference joint system consisting of an integral bell and spigot with interlocking male and female threads. Epoxy adhesive shall be applied on joints per manufacturer's specifications prior to use.

Product shall be listed by Underwriters Laboratories and conform to the National Electrical Code.

The ID dimension shall be full, actual trade size.

All adaptors, couplings, expansion joints and suspended hangers shall be FRE fittings corresponding to and manufactured for use with FRE conduit as specified on the plans. The suspended hanger assemblies shall include stainless steel threaded concrete inserts as specified on the plans.

Epoxy coated reinforcement tie bar shall conform to standard spec 505.

### C Construction

Construct according to the pertinent provisions of standard spec 502 and 652.

The four-duct package to be installed on P-40-511 consists of four 4-inch ducts, one high by four wide.

Install the conduit 5 feet beyond the back of the bridge abutment walls. Install a fiberglass to PVC adaptor on the end of each duct and temporarily cap.

Coupling of the duct sections shall be accomplished and secured by first applying epoxy adhesive then mating a spigot end into an integral bell end with a blow to the open end of the duct section.

Submit shop drawings for all deck inserts, hangers, braced hangers, expansion couplings and hanger spacing to Ms. Karen Roney at (414) 286-3243 of the City of Milwaukee for review 60 business days in advance of the bridge deck placement.

Install all FRE duct and components according to the manufacturer's instructions.

### D Measurement

The department will measure Underdeck Utility Structure P-40-511 City of Milwaukee Communications Conduit, as a single lump sum unit of work, acceptably completed.

## E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0105.400	Underdeck Utility Structure P-40-511 City of Milwaukee Communications Conduit	LS

Payment is full compensation for furnishing and installing the Underdeck Utility Crossing, Structure P-40-511, City of Milwaukee Conduit; including the FRE conduit, the conduit support system including the stainless steel deck inserts and hangars, epoxy coated hanger tie bar, the abutment penetrations. Duct and associated fittings rendered unfit for use by the contractor through the contractor's operations shall be replaced by the contractor in kind at the contractor's own cost and expense.

## **ADDITIONAL SPECIAL PROVISION 4**

### **Payment to First-Tier Subcontractors**

Within 10 calendar days of receiving a progress payment for work completed by a subcontractor, pay the subcontractor for that work. The prime contractor may withhold payment to a subcontractor if, within 10 calendar days of receipt of that progress payment, the prime contractor provides written notification to the subcontractor and the department documenting "just cause" for withholding payment.

The prime contractor may also withhold routine retainage from payments due subcontractors.

### **Payment to Lower-Tier Subcontractors**

Ensure that subcontracting agreements at all tiers provide prompt payment rights to lower-tier subcontractors that parallel those granted first-tier subcontractors in this provision.

### **Release of Routine Retainage**

After granting substantial completion the department may reduce the routine retainage withheld from the prime contractor to 75 percent of the original total amount retained.

When the Department sends the semi-final estimate the department may reduce the routine retainage withheld from the prime contractor to 10 percent of the original total amount retained.

Within 30 calendar days of receiving the semi-final estimate from the department, submit written certification that subcontractors at all tiers are paid in full for acceptably completed work and that no routine retainage is being withheld. The department will pay the prime contractor in full and reduce the routine retainage withheld from the prime contractor to zero when the department approves the final estimate.

This special provision does not limit the right of the department, prime contractor, or subcontractors at any tier to withhold payment for work not acceptably completed or work subject to an unresolved contract dispute.



## ADDITIONAL SPECIAL PROVISION 6

### ASP 6 - Modifications to the standard specifications

*Make the following revisions to the standard specifications:*

---

#### 107.17.1 General

*Replace paragraph seven with the following effective with the December 2018 letting:*

- (7) Have a professional engineer registered in the state of Wisconsin sign and seal the shop drawings. At least 30 calendar days before starting falsework, form, or shoring construction; submit a PDF file of shop drawings to the railroad's chief engineering officer and to the engineer. The engineer and the railroad may review the shop drawings. If the engineer or the railroad finds the shop drawings unsatisfactory, the contractor shall make the required changes. A satisfactory shop drawing review does not relieve the contractor of responsibility and liability for the structural integrity and proper functioning of the falsework, forms, or shoring.
- 

#### 109.1.1 General

*Replace the entire text with the following effective with the January 2019 letting:*

- (1) The engineer will use the US standard system to measure all work completed under the contract. The engineer will determine quantities of materials the contractor furnishes and work the contractor performs using measurement methods and computations conforming to standard engineering practice, modified to meet department requirements. The engineer will document these measurements using department procedures.
  - (2) The engineer will measure the work as the contract measurement subsection for individual items specifies. The department will measure the actual quantities of work the contractor acceptably completes and make final payment based on those actual measured quantities except as follows:
    1. If the measurement subsection for a bid item specifically restricts the quantity measured for payment or allows for use of conversion factors.
    2. If the engineer executes a contract change order modifying the method of measurement for specific bid items, the engineer will measure the quantities of applicable bid items for payment using the change order methods.
    3. If the engineer, under 105.3.1(2), approves a contractor-requested plan dimension change between US standard and SI metric dimensions, the engineer will measure whichever of the following is less:
      - Actual quantities constructed.
      - Quantities derived from the original plan dimensions.
    4. For substitutions made under 106.2.3 between US standard and SI metric products, the engineer will measure the actual quantities of the substitute products using the original contract measuring system.
- 

#### 305.2.1 General

*Replace paragraph two with the following effective with the December 2018 letting:*

- (2) Where the contract specifies or allows 1 1/4-inch base, do not place reclaimed asphalt, reprocessed material, or blended materials below virgin aggregate materials unless the contract specifies or the engineer allows in writing. The department will allow virgin aggregate above reclaimed asphalt, reprocessed material, or blended materials in shoulder areas adjacent to concrete pavement.
- 

#### 420.3.2.1 General

*Replace paragraph one with the following effective with the December 2018 letting:*

- (1) Use self-propelled grinding machines with depth, grade, and slope controls designed for grinding and texturing concrete. Equip grinding machines with diamond blades and a vacuuming system capable of removing liquid and solid residue from the ground surface. Shroud the machine to prevent discharging loosened material into adjacent work areas or live traffic lanes. Provide the specified effective wheelbase, defined as the center of the front to center of the rear main support wheels.

---

**420.3.2.2 Continuous Grinding**

Replace paragraph one with the following effective with the December 2018 letting:

- (1) Under the Continuous Diamond Grinding Concrete Pavement bid item, ensure that the grinding machine, including the grinding head, weighs 35,000 pounds or more, will grind a strip at least 4 feet wide, and has an effective wheel base of 25 feet or more. For pavements with a design speed less than 40 miles per hour and areas difficult to access, the contractor may use equipment with an effective wheel base of 12 feet or more.
- 

**450.3.2.8 Jointing**

Replace paragraphs three through five with the following effective with the December 2018 letting:

- (3) Construct notched wedge longitudinal joints for mainline paving if the pavement thickness conforms to the minimums specified in 460.3.2, unless the engineer directs or allows an alternate joint. Construct the wedge using a slope no steeper than 3:1. Extend the wedge 12 inches beyond the normal lane width, or as the engineer directs. Ensure that the wedge for all layers directly overlaps and slopes in the same direction.
  - (4) Locate the joint at the pavement centerline for 2-lane roadways, or at lane lines if the roadway has more than 2 lanes. Construct a vertical notch 1/2-inch to 3/4-inch high on the centerline or lane line at the top of each wedge. Place a 1/2-inch to 3/4-inch notch at the outside bottom edge of the wedge after compacting each layer. Align the finished longitudinal joint line of the upper layer with the centerline or lane line.
  - (5) Construct the wedge for each layer using an engineer-approved strike-off device that will provide a uniform slope and will not restrict the main screed. Shape and compact the wedge with a weighted steel side roller wheel the same width as the wedge. Apply a tack coat to the wedge surface and both notches before placing the adjacent lane.
- 

**455.2.4.3 Emulsified Asphalts**

Replace paragraph two with the following effective with the December 2018 letting:

- (2) The bill of lading for emulsified asphalts shall indicate the asphalt content of the original emulsion and dilution rate of the additional water added to the original emulsion. If undiluted samples are not available, test the diluted material and modify AASHTO M140, M208, or M316 to reflect properties resulting from dilution of the asphalt.
- 

**460.2.8.3.1.4 Department Verification Testing Requirements**

Replace paragraph three with the following effective with the December 2018 letting:

- (3) The department will perform testing conforming to the following standards:
    - Bulk specific gravity ( $G_{mb}$ ) of the compacted mixture according to AASHTO T166.
    - Maximum specific gravity ( $G_{mm}$ ) according to AASHTO T209.
    - Air voids ( $V_a$ ) by calculation according to AASHTO T269.
    - VMA by calculation according to AASHTO R35.
    - Asphalt content by ignition oven according to AASHTO T308 as modified in CMM 8-36.6.3.6, chemical extraction according to AASHTO T-164, or Asphalt Analyzer™ according to manufacturer recommendations.
- 

**460.2.8.3.1.6 Acceptable Verification Parameters**

Replace paragraph one with the following effective with the December 2018 letting:

- (1) The engineer will provide test results to the contractor within 2 mixture-production days after obtaining the sample. The quality of the product is acceptably verified if it meets the following limits:
  - $V_a$  is within a range of 2.0 to 4.3 percent. For SMA,  $V_a$  is within a range of 2.7 to 5.3 percent.
  - VMA is within minus 0.5 of the minimum requirement for the mix design nominal maximum aggregate size.
  - Asphalt content is within minus 0.3 percent of the JMF.

**460.2.8.3.1.7 Dispute Resolution**

Replace paragraph one with the following effective with the December 2018 letting:

- (1) When QV test results do not meet the specified limits for 100 percent pay, the bureau's AASHTO accredited laboratory and certified personnel will referee test the retained portion of the QV sample and the retained portion of the required forward and backward QC retained samples according to CMM 8-36.

**460.5.2.1 General**

Replace paragraphs five and six with the following effective with the December 2018 letting:

- (5) The department will reduce pay for nonconforming QMP HMA mixtures as specified in 460.2.8.2.1.7, starting from the stop point to the point when the running average of 4 is back inside the warning limits. The engineer will determine the quantity of material subject to pay reduction based on the testing data and an inspection of the completed pavement. The department will reduce pay as follows:

**PAYMENT FOR MIXTURE<sup>[1] [2] [3]</sup>**

ITEM	PRODUCED WITHIN WARNING BANDS	PRODUCED OUTSIDE JMF LIMITS
Gradation	90%	75%
Asphalt Content <sup>[4]</sup>	—	—
Air Voids	70%	50%
VMA	90%	75%

<sup>[1]</sup> For projects or plants where the total production of each mixture design requires less than 4 tests refer to CMM 8-36.

<sup>[2]</sup> Payment is in percent of the contract unit price for the HMA Pavement bid item. The department will reduce pay based on the nonconforming property with lowest percent pay. If the quantity of material subject to pay adjustment based on the running average of 4 is also subject to pay adjustment resulting from dispute resolution in accordance with 460.2.8.3.1.7, the department will apply the single pay adjustment resulting in the lowest percent pay.

<sup>[3]</sup> In addition to any pay adjustment listed in the table above, the department will adjust pay for nonconforming binder under the Nonconforming QMP Asphaltic Material administrative item. The department will deduct 25 percent of the contract unit price of the HMA Pavement bid item per ton of pavement placed with nonconforming PG binder the engineer allows to remain in place.

<sup>[4]</sup> The department will not adjust pay based on a running average of 4 asphalt content tests; however, corrective action will be applied to nonconforming material according to 460.2.8.2.1.7.

- (6) If during a QV dispute resolution investigation the department discovers unacceptable mixture defined by one or more of the following:
- Va greater than 5.0 or less than 1.5.
  - VMA more than 1.0 below the minimum allowed in table 460-1.
  - AC more than 0.5 % below the JMF target.

Remove and replace the material, or if the engineer allows the mixture to remain in place, the department will pay for the quantity of affected material at 50 percent of the contract price.

**506.3.2 Shop Drawings**

Replace paragraph four with the following effective with the December 2018 letting:

- (4) Ensure that the fabricator submits a PDF file of shop drawings for railroad structures to the railroad company's chief engineering officer upon contract completion.

**646.3.1.2 Liquid Marking**

Replace paragraph five with the following effective with the January 2019 letting:

- (5) Apply liquid marking and glass beads across the line at or exceeding the following:

LIQUID MARKING	PAVEMENT TYPE	THICKNESS (mils)	BEAD APPLICATION (pounds per gallon)
Paint	all	16	8
Epoxy	SMA, seal coats, and polymer overlays	25	25
Epoxy	all other	20	22.5
Wet Reflective Epoxy	all	20	18

**646.3.2.3.2 Wet Reflective Epoxy**

*Replace paragraph five with the following effective with the January 2019 letting:*

- (1) Apply wet reflective epoxy binder in a grooved slot. and provide a double drop bead system as follows:
  - First: wet reflective/recoverable elements at the application rate specified for the product chosen from the department's APL.
  - Second: glass beads at the application rate specified in 646.3.1.2(5).

**650.3.1 General**

*Replace the entire text with the following effective with the December 2018 letting:*

- (1) Department and contractor responsibilities for construction staking are specified in 105.6. Conform to 105.6 and the additional requirements specified here in 650.3 for the individual contractor-staking bid items the contract includes.
- (2) Protect and preserve known property and survey marks and land monuments as specified in 107.11.3. The contract may require related work under the 621 bid items.
- (3) Obtain or calculate benchmark data, grades, and alignment from plan information. The engineer will furnish data for the horizontal and vertical control points, control point ties, horizontal alignments, profiles, and elevations. Reestablish, set additional, and maintain the horizontal and vertical control points and control point ties, as needed for bid items.
- (4) Check horizontal and vertical information including but not limited to alignments, locations, elevations, and dimensions, that either the plans show or the engineer provides, for compatibility with existing field conditions. Conduct similar compatibility checks and accuracy checks of horizontal and vertical positions either the department or the contractor establishes in the field.
- (5) Perform survey work using conventional methods, or AMG methods capable of achieving the lines and grades the plans show for the work in question. Establish additional benchmarks and control points as necessary to support the method of operation.

**650.3.1.1 Staking**

- (1) Furnish, set, reference, and maintain stakes and markings necessary to establish the alignment, location, benchmarks, elevations, and continuous profile-grades for road and structure work as needed for bid items. Supervise and coordinate construction staking.
- (2) Maintain neat, orderly, and complete survey notes, drawings, and computations used in establishing the lines and grades. Make the survey notes and computations available to the engineer within 24 hours, upon request, as the work progresses.
- (3) Furnish surveying equipment, stakes, flags, pins, lath, whiskers, and other materials necessary to perform this work, subject to the engineer's approval.

**650.3.1.2 Automated Machine Guidance****650.3.1.2.1 General**

- (1) The contractor may substitute AMG for conventional staking on all or part of the work under the individual staking bid items. Coordinate with the engineer throughout the course of construction to ensure that work performed using AMG conforms to the contract tolerances and that the methods employed conform to the contractor's AMG work plan and accepted industry standards. Revert to conventional staking methods for all or part of the work at any point during construction if AMG is producing unacceptable results.

**650.3.1.2.2 AMG Work Plan**

- (1) Submit a comprehensive written AMG work plan for department review at least 5 business days before the preconstruction conference. In that plan discuss how AMG technology will be integrated into other

technologies employed on the project. List the staking bid items that will have work performed using AMG and, for each bid item listed, include the following:

1. Designate which portions of the contract will be done using AMG and which portions will be done using conventional staking.
  2. Designate a single staff person as the primary contact for AMG technology issues.
  3. List and map the primary and secondary control points required under 105.6.2 enveloping the site.
  4. Describe the contractor's quality control procedures. Include the frequency and type of checks performed to ensure that the work conforms to the contract plans.
- (2) The engineer will review the plan to determine if it conforms to the contract. Do not perform AMG work until the engineer approves the governing portion of the AMG workplan. Perform the work as the contractor's AMG work plan provides. Update the plan as necessary.

#### **650.3.1.2.3 Geometric and Surface Information**

##### **650.3.1.2.3.1 Department Responsibilities**

- (1) At any time after the contract is awarded the contractor may request the contractor data packet. The department will provide the packet within 5 business days of receiving the contractor's request.

##### **650.3.1.2.3.2 Contractor Responsibilities**

- (1) Develop and maintain a contractor construction model for areas of the project employing AMG. Confirm that the resulting model agrees with the contract plans.
- (2) If the engineer requests, provide the construction model to the department in LandXML or other engineer-approved format.

##### **650.3.1.2.4 Managing and Updating Information**

- (1) Notify the department of any errors or discrepancies in department-provided information. The department will determine what revisions may be required. The department will revise the contract plans, if necessary, to address errors or discrepancies that the contractor identifies. The department will provide the best available information related to those contract plan revisions.
- (2) Revise the construction model as required to support construction operations and to reflect any contract plan revisions the department makes. Perform checks to confirm that the revised construction model agrees with the contract plan revisions. If the engineer requests, provide construction model updates to the engineer. The department will pay for costs incurred to incorporate contract plan revisions as extra work.

##### **650.3.1.2.5 Construction Checks**

- (1) Check the work against the plan elevation at randomly selected points on cross-sections located at stations evenly divisible by 100 at the frequency the engineer approved as a part of the AMG work plan. Submit the results of these random checks to the engineer daily. Notify the engineer immediately if a check exceeds the tolerances specified in 650.3.1.2.6 below.
- (2) Check the work at additional points as the engineer directs. The department may conduct periodic independent checks.

##### **650.3.1.2.6 Construction Tolerances**

- (1) Ensure that the finished work vertically matches existing or other completed features. Ensure that the work conforms to revised plan elevations as follows:
- Subgrade : +/- 0.10 feet.
  - Base : within the tolerance specified in 301.3.4.1(2).

---

### **650.3.3 Subgrade**

*Retitle and replace the entire text with the following effective with the December 2018 letting:*

#### **650.3.3 Subgrade Staking**

- (1) Set construction stakes or marks at intervals of 100 feet, or more frequently, for rural sections and at intervals of 50 feet, or more frequently, for urban sections. Include additional stakes at each cross-section as necessary to match the plan cross-section, achieve the required accuracy, and to support construction operations. Also set and maintain stakes as necessary to establish the horizontal and vertical positions of intersecting road radii, auxiliary lanes, horizontal and vertical curves, and curve

transitions. Locate stakes to within 0.25 feet horizontally and establish the grade elevation to within 0.03 feet vertically.

---

**Errata**

---

**520.3.3 Laying Pipe**

Correct errata by replacing "sections" with "joints" to clarify the intent that the last 3 joints need ties.

- (5) Provide joint ties on the upstream and downstream ends of circular and horizontal elliptical concrete culvert and concrete cattle pass installations. Tie the next 3 pipe joints or, if using apron endwalls, the endwall joint and the last 2 pipe joints. Ties are not required on culverts with masonry endwalls unless the plans show otherwise.
- 

**608.3.3 Laying Pipe**

Correct errata by replacing "sections" with "joints" to clarify the intent that the last 3 joints need ties.

- (5) Provide joint ties on concrete storm sewer system infall and outfall pipes. Tie the last 3 pipe joints or, if using apron endwalls, the endwall joint and the next 2 pipe joints. Ties are not required on installations with masonry endwalls unless the plans show otherwise.

### ADDITIONAL SPECIAL PROVISION 7

- A. Reporting 1<sup>st</sup> Tier and DBE Payments During Construction
1. Comply with reporting requirements specified in the department's Civil Rights Compliance, Contractor's User Manual, Sublets and Payments.
  2. Report payments to all DBE firms within 10 calendar days of receipt of a progress payment by the department or a contractor for work performed, materials furnished, or materials stockpiled by a DBE firm. Report the payment as specified in A(1) for all work satisfactorily performed and for all materials furnished or stockpiled.
  3. Report payments to all first tier subcontractor relationships within 10 calendar days of receipt of a progress payment by the department for work performed. Report the payment as specified in A(1) for all work satisfactorily performed.
  4. All tiers shall report payments as necessary to comply with the DBE payment requirement as specified in A(2).
  5. Require all first tier relationships, DBE firms and all other tier relationships necessary to comply with the DBE payment requirement in receipt of a progress payment by contractor to acknowledge receipt of payment as specified in A(1), (2), (3) and (4).
  6. All agreements made by a contractor shall include the provisions in A(1), (2), (3), (4) and (5), and shall be binding on all first tier subcontractor relationships and all contractors and subcontractors utilizing DBE firms on the project.
- B. Costs for conforming to this special provision are incidental to the contract.

NOTE: CRCS Prime Contractor payment is currently not automated and will need to be manually loaded into the Civil Rights Compliance System. Copies of prime contractor payments received (check or ACH) will have to be forwarded to [paul.ndon@dot.wi.gov](mailto:paul.ndon@dot.wi.gov) within 5 days of payment receipt to be logged manually.

\*\*\*Additionally, for information on Subcontractor Sublet assignments, Subcontractor Payments and Payment Tracking, please refer to the CRCS Payment and Sublets manual at:

<https://wisconsindot.gov/Documents/doing-bus/civil-rights/labornwage/crcs-payments-sublets-manual.pdf>



**ADDITIONAL SPECIAL PROVISION 9-S**  
**Electronic Labor Data Submittal for**  
***State Funded Only Projects***

(1) Use the Workforce Utilization Report Microsoft Excel spread sheet, or other compatible spread sheet (i.e., Google Spread Sheet), to report required labor data. Details and the Excel spreadsheet are available online through the department's highway construction contract information (HCCI) site on the Labor, Wages, and EEO Information page at:

<http://wisconsindot.gov/Pages/doing-bus/civil-rights/labornwage/default.aspx>

(2) Ensure that all tiers of subcontractors, including all trucking firms, submit their labor data electronically via the Excel spread sheet to the prime contractor within 14 calendar days of the end of each quarter (quarters are defined as January-March, April-June, July-September, and October-December). The prime contractor shall coordinate collection of their subcontractors' spread sheets and forward them to the Regional Labor Compliance Specialist within 21 calendar days of the end of each quarter. Every company or contractor providing physical labor towards completing the project is a subcontractor under this special provision.

(3) Upon receipt of contract execution, promptly make all affected companies or contractors aware of the requirements under this special provision and arrange for them to receive an Excel spreadsheet as part of their subcontract documents.

(4) The department will reject all paper submittals of information required under this special provision. All costs for conforming to this special provision are incidental to the contract.

## **Non-discrimination Provisions**

**During the performance of this contract, the contractor, for itself, its assignees, and successors in interest (hereinafter referred to as the "contractor") agrees as follows:**

**1. Compliance with Regulations:** The contractor (hereinafter includes consultants) will comply with the Acts and the Regulations relative to Non-discrimination in Federally-assisted programs of the U.S. Department of Transportation, Federal Highway Administration, as they may be amended from time to time, which are herein incorporated by reference and made a part of this contract.

**2. Non-discrimination:** The contractor, with regard to the work performed by it during the contract, will not discriminate on the grounds of race, color, or national origin in the selection and retention of subcontractors, including procurements of materials and leases of equipment. The contractor will not participate directly or indirectly in the discrimination prohibited by the Acts and the Regulations, including employment practices when the contract covers any activity, project, or program set forth in Appendix B of 49 CFR Part 21.

**3. Solicitations for Subcontracts, Including Procurements of Materials and Equipment:** In all solicitations, either by competitive bidding, or negotiation made by the contractor for work to be performed under a subcontract, including procurements of materials, or leases of equipment, each potential subcontractor or supplier will be notified by the contractor of the contractor's obligations under this contract and the Acts and the Regulations relative to Non-discrimination on the grounds of race, color, or national origin.

**4. Information and Reports:** The contractor will provide all information and reports required by the Acts, the Regulations, and directives issued pursuant thereto and will permit access to its books, records, accounts, other sources of information, and its facilities as may be determined by the Recipient or the Federal Highway Administration to be pertinent to ascertain compliance with such Acts, Regulations, and instructions. Where any information required of a contractor is in the exclusive possession of another who fails or refuses to furnish the information, the contractor will so certify to the Recipient or the Federal Highway Administration, as appropriate, and will set forth what efforts it has made to obtain the information.

**5. Sanctions for Noncompliance:** In the event of a contractor's noncompliance with the Non-discrimination provisions of this contract, the Recipient will impose such contract sanctions as it or the Federal Highway Administration may determine to be appropriate, including, but not limited to:

- a. Withholding payments to the contractor under the contract until the contractor complies; and/or
- b. Cancelling, terminating, or suspending a contract, in whole or in part.

**6. Incorporation of Provisions:** The contractor will include the provisions of paragraphs one through six in every subcontract, including procurements of materials and leases of equipment, unless exempt by the Acts, the Regulations and directives issued pursuant thereto. The contractor will take action with respect to any subcontract or procurement as the Recipient or the Federal Highway Administration may direct as a means of enforcing such provisions including sanctions for noncompliance. Provided, that if the contractor becomes involved in, or is threatened with litigation by a subcontractor, or supplier because of such direction, the contractor may request the Recipient to enter into any litigation to protect the interests of the Recipient. In addition, the contractor may request the United States to enter into the litigation to protect the interests of the United States.

**During the performance of this contract, the contractor, for itself, its assignees, and successors in interest (hereinafter referred to as the "contractor") agrees to comply with the following non-discrimination statutes and authorities; including but not limited to:**

**Pertinent Non-Discrimination Authorities:**

- Title VI of the Civil Rights Act of 1964 (42 U.S.C. § 2000d et seq., 78 stat. 252), (prohibits discrimination on the basis of race, color, national origin); and 49 CFR Part 21.
- The Uniform Relocation Assistance and Real Property Acquisition Policies Act of 1970, (42 U.S.C. § 4601), (prohibits unfair treatment of persons displaced or whose property has been acquired because of Federal or Federal-aid programs and projects);
- Federal-Aid Highway Act of 1973, (23 U.S.C. § 324 et seq.), (prohibits discrimination on the basis of sex);
- Section 504 of the Rehabilitation Act of 1973, (29 U.S.C. § 794 et seq.), as amended, (prohibits discrimination on the basis of disability); and 49 CFR Part 27;
- The Age Discrimination Act of 1975, as amended, (42 U.S.C. § 6101 et seq.), (prohibits discrimination on the basis of age);
- Airport and Airway Improvement Act of 1982, (49 USC § 471, Section 47123), as amended, (prohibits discrimination based on race, creed, color, national origin, or sex);
- The Civil Rights Restoration Act of 1987, (PL 100-209), (Broadened the scope, coverage and applicability of Title VI of the Civil Rights Act of 1964, The Age Discrimination Act of 1975 and Section 504 of the Rehabilitation Act of 1973, by expanding the definition of the terms "programs or activities" to include all of the programs or activities of the Federal-aid recipients, sub-recipients and contractors, whether such programs or activities are Federally funded or not);
- Titles II and III of the Americans with Disabilities Act, which prohibit discrimination on the basis of disability in the operation of public entities, public and private transportation systems, places of public accommodation, and certain testing entities (42 U.S.C. §§ 12131-12189) as implemented by Department of Transportation regulations at 49 C.F.R. parts 37 and 38;
- The Federal Aviation Administration's Non-discrimination statute (49 U.S.C. § 47123) (prohibits discrimination on the basis of race, color, national origin, and sex);

- Executive Order 12898, Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations, which ensures Non-discrimination against minority populations by discouraging programs, policies, and activities with disproportionately high and adverse human health or environmental effects on minority and low-income populations;
- Executive Order 13166, Improving Access to Services for Persons with Limited English Proficiency, and resulting agency guidance, national origin discrimination includes discrimination because of Limited English proficiency (LEP). To ensure compliance with Title VI, you must take reasonable steps to ensure that LEP persons have meaningful access to your programs (70 Fed. Reg. at 74087 to 74100);
- Title IX of the Education Amendments of 1972, as amended, which prohibits you from discriminating because of sex in education programs or activities (20 U.S.C. 1681 et seq).

**Effective August 2015 letting**

### **BUY AMERICA PROVISION**

All steel and iron materials permanently incorporated in this project shall be domestic products and all manufacturing and coating processes for these materials from smelting forward in the manufacturing process must have occurred within the United States. Coating includes epoxy coating, galvanizing, painting and any other coating that protects or enhances the value of a material subject to the requirements of Buy America. The exemption of this requirement is the minimal use of foreign materials if the total cost of such material permanently incorporated in the product does not exceed one-tenth of one percent (1/10 of 1%) of the total contract cost or \$2,500.00, whichever is greater. For purposes of this paragraph, the cost is that shown to be the value of the subject products as they are delivered to the project. The contractor shall take actions and provide documentation conforming to CMM 2-28.5 to ensure compliance with this "Buy America" provision.

<https://wisconsindot.gov/rdwy/cmm/cm-02-28.pdf>

Upon completion of the project certify to the engineer, in writing using department form WS4567, that all steel, iron, and coating processes for steel or iron incorporated into the contract work conform to these "Buy America" provisions. Attach a list of exemptions and their associated costs to the certification form. Department form WS4567 is available at:

<https://wisconsindot.gov/hcciDocs/contracting-info/ws4567.doc>



## Proposal Schedule of Items

Page 1 of 7

Proposal ID: 20190115015 Project(s): 2100-00-70

Federal ID(s): N/A

SECTION: 0001

Contract Items

Alt Set ID:

Alt Mbr ID:

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0002	201.0110 Clearing	140.000 SY	_____.	_____.
0004	201.0210 Grubbing	140.000 SY	_____.	_____.
0006	203.0600.S Removing Old Structure Over Waterway With Minimal Debris (station) 001. 03+04.48	LS	LUMP SUM	_____.
0008	204.0100 Removing Pavement	11.000 SY	_____.	_____.
0010	204.0105 Removing Pavement Butt Joints	20.000 SY	_____.	_____.
0012	204.0115 Removing Asphaltic Surface Butt Joints	282.000 SY	_____.	_____.
0014	204.0150 Removing Curb & Gutter	322.000 LF	_____.	_____.
0016	204.0155 Removing Concrete Sidewalk	1,624.000 SY	_____.	_____.
0018	204.0175 Removing Concrete Slope Paving	250.000 SY	_____.	_____.
0020	204.0220 Removing Inlets	2.000 EACH	_____.	_____.
0022	205.0100 Excavation Common	105.000 CY	_____.	_____.
0024	206.1000 Excavation for Structures Bridges (structure) 001. P-40-511	LS	LUMP SUM	_____.
0026	210.1500 Backfill Structure Type A	230.000 TON	_____.	_____.
0028	213.0100 Finishing Roadway (project) 001. 2100- 00-70	1.000 EACH	_____.	_____.
0030	305.0120 Base Aggregate Dense 1 1/4-Inch	131.000 TON	_____.	_____.



## Proposal Schedule of Items

Page 2 of 7

Proposal ID: 20190115015 Project(s): 2100-00-70

Federal ID(s): N/A

SECTION: 0001

Contract Items

Alt Set ID:

Alt Mbr ID:

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0032	415.0410 Concrete Pavement Approach Slab	395.000 SY	_____.	_____.
0034	416.0610 Drilled Tie Bars	50.000 EACH	_____.	_____.
0036	416.0620 Drilled Dowel Bars	136.000 EACH	_____.	_____.
0038	455.0605 Tack Coat	34.000 GAL	_____.	_____.
0040	460.2000 Incentive Density HMA Pavement	30.000 DOL	1.00000	30.00
0042	460.5224 HMA Pavement 4 LT 58-28 S	46.000 TON	_____.	_____.
0044	502.0100 Concrete Masonry Bridges	310.000 CY	_____.	_____.
0046	502.3100 Expansion Device (structure) 001. P-40-511	LS	LUMP SUM	_____.
0048	502.3200 Protective Surface Treatment	950.000 SY	_____.	_____.
0050	502.4205 Adhesive Anchors No. 5 Bar	530.000 EACH	_____.	_____.
0052	505.0600 Bar Steel Reinforcement HS Coated Structures	67,750.000 LB	_____.	_____.
0054	506.2610 Bearing Pads Elastomeric Laminated	22.000 EACH	_____.	_____.
0056	506.3015 Welded Stud Shear Connectors 7/8x6-Inch	2,508.000 EACH	_____.	_____.
0058	506.7050.S Removing Bearings (structure) 001. P-40-511	22.000 EACH	_____.	_____.
0060	509.1500 Concrete Surface Repair	48.000 SF	_____.	_____.
0062	509.9025.S Epoxy Injection Crack Repair	52.000 LF	_____.	_____.



## Proposal Schedule of Items

Page 3 of 7

Proposal ID: 20190115015 Project(s): 2100-00-70

Federal ID(s): N/A

SECTION: 0001

Contract Items

Alt Set ID:

Alt Mbr ID:

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0064	509.9026.S Cored Holes 2-Inch Diameter	4.000 EACH	_____.	_____.
0066	511.1200 Temporary Shoring (structure) 001. P-40-511	60.000 SF	_____.	_____.
0068	513.7084 Railing Steel Type NY4 P-40-511	300.000 LF	_____.	_____.
0070	516.0100 Dampproofing	130.000 SY	_____.	_____.
0072	516.0500 Rubberized Membrane Waterproofing	44.000 SY	_____.	_____.
0074	517.0900.S Preparation and Coating of Top Flanges (structure) 001. P-40-511	LS	LUMP SUM	_____.
0076	517.1010.S Concrete Staining (structure) 001. P-40-511	1,740.000 SF	_____.	_____.
0078	517.1800.S Structure Repainting Recycled Abrasive (structure) 001. P-40-511	LS	LUMP SUM	_____.
0080	517.4500.S Negative Pressure Containment and Collection of Waste Materials (structure) 001. P-40-511	LS	LUMP SUM	_____.
0082	517.6001.S Portable Decontamination Facility	1.000 EACH	_____.	_____.
0084	601.0331 Concrete Curb & Gutter 31-Inch	322.000 LF	_____.	_____.
0086	602.0410 Concrete Sidewalk 5-Inch	1,624.000 SF	_____.	_____.
0088	602.0515 Curb Ramp Detectable Warning Field Natural Patina	66.000 SF	_____.	_____.
0090	603.8000 Concrete Barrier Temporary Precast Delivered	170.000 LF	_____.	_____.





## Proposal Schedule of Items

Page 4 of 7

Proposal ID: 20190115015 Project(s): 2100-00-70

Federal ID(s): N/A

SECTION: 0001

Contract Items

Alt Set ID:

Alt Mbr ID:

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0092	603.8125 Concrete Barrier Temporary Precast Installed	310.000 LF	_____.	_____.
0094	604.0400 Slope Paving Concrete	250.000 SY	_____.	_____.
0096	611.2005 Manholes 5-FT Diameter	1.000 EACH	_____.	_____.
0098	619.1000 Mobilization	1.000 EACH	_____.	_____.
0100	623.0200 Dust Control Surface Treatment	6,720.000 SY	_____.	_____.
0102	625.0100 Topsoil	175.000 SY	_____.	_____.
0104	628.1504 Silt Fence	150.000 LF	_____.	_____.
0106	628.1520 Silt Fence Maintenance	150.000 LF	_____.	_____.
0108	628.1905 Mobilizations Erosion Control	2.000 EACH	_____.	_____.
0110	628.1910 Mobilizations Emergency Erosion Control	5.000 EACH	_____.	_____.
0112	628.2027 Erosion Mat Class II Type C	175.000 SY	_____.	_____.
0114	628.6005 Turbidity Barriers	250.000 SY	_____.	_____.
0116	628.7005 Inlet Protection Type A	4.000 EACH	_____.	_____.
0118	628.7015 Inlet Protection Type C	11.000 EACH	_____.	_____.
0120	630.0120 Seeding Mixture No. 20	6.000 LB	_____.	_____.
0122	631.1000 Sod Lawn	175.000 SY	_____.	_____.



## Proposal Schedule of Items

Page 5 of 7

Proposal ID: 20190115015 Project(s): 2100-00-70

Federal ID(s): N/A

SECTION: 0001

Contract Items

Alt Set ID:

Alt Mbr ID:

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0124	642.5201 Field Office Type C	1.000 EACH	_____.	_____.
0126	643.0300 Traffic Control Drums	3,870.000 DAY	_____.	_____.
0128	643.0420 Traffic Control Barricades Type III	1,998.000 DAY	_____.	_____.
0130	643.0500 Traffic Control Flexible Tubular Marker Posts	21.000 EACH	_____.	_____.
0132	643.0600 Traffic Control Flexible Tubular Marker Bases	21.000 EACH	_____.	_____.
0134	643.0705 Traffic Control Warning Lights Type A	2,096.000 DAY	_____.	_____.
0136	643.0715 Traffic Control Warning Lights Type C	3,870.000 DAY	_____.	_____.
0138	643.0900 Traffic Control Signs	2,480.000 DAY	_____.	_____.
0140	643.1050 Traffic Control Signs PCMS	28.000 DAY	_____.	_____.
0142	643.5000 Traffic Control	1.000 EACH	_____.	_____.
0144	644.1601.S Temporary Curb Ramp	1.000 EACH	_____.	_____.
0146	644.1616.S Temporary Pedestrian Safety Fence	388.000 LF	_____.	_____.
0148	644.1810.S Temporary Pedestrian Barricade	540.000 LF	_____.	_____.
0150	646.1020 Marking Line Epoxy 4-Inch	945.000 LF	_____.	_____.
0152	646.9000 Marking Removal Line 4-Inch	864.000 LF	_____.	_____.
0154	649.0150 Temporary Marking Line Removable Tape 4-Inch	3,670.000 LF	_____.	_____.



## Proposal Schedule of Items

Page 6 of 7

Proposal ID: 20190115015 Project(s): 2100-00-70

Federal ID(s): N/A

SECTION: 0001

Contract Items

Alt Set ID:

Alt Mbr ID:

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0156	650.4000 Construction Staking Storm Sewer	3.000 EACH	_____.	_____.
0158	650.5500 Construction Staking Curb Gutter and Curb & Gutter	322.000 LF	_____.	_____.
0160	650.6500 Construction Staking Structure Layout (structure) 001. P-40-511	LS	LUMP SUM	_____.
0162	650.9000 Construction Staking Curb Ramps	6.000 EACH	_____.	_____.
0164	650.9910 Construction Staking Supplemental Control (project) 001. 2100-00-70	LS	LUMP SUM	_____.
0166	652.0230 Conduit Rigid Nonmetallic Schedule 40 2 1/2-Inch	460.000 LF	_____.	_____.
0168	690.0150 Sawing Asphalt	349.000 LF	_____.	_____.
0170	690.0250 Sawing Concrete	758.000 LF	_____.	_____.
0172	715.0415 Incentive Strength Concrete Pavement	500.000 DOL	1.00000	500.00
0174	715.0502 Incentive Strength Concrete Structures	1,860.000 DOL	1.00000	1,860.00
0176	SPV.0060 Special 102. Inlet Covers Type MS 57	3.000 EACH	_____.	_____.
0178	SPV.0060 Special 103. Manhole Cover Type MS 58-A	1.000 EACH	_____.	_____.
0180	SPV.0060 Special 112. Storm Inlet Type 45A	1.000 EACH	_____.	_____.
0182	SPV.0060 Special 400. Adjusting CUC Manhole Covers	2.000 EACH	_____.	_____.
0184	SPV.0060 Special 426. Sawing Concrete Encased Duct Package	2.000 EACH	_____.	_____.



## Proposal Schedule of Items

Page 7 of 7

Proposal ID: 20190115015 Project(s): 2100-00-70

Federal ID(s): N/A

SECTION: 0001

Contract Items

Alt Set ID:

Alt Mbr ID:

Proposal Line Number	Item ID Description	Approximate Quantity and Units	Unit Price	Bid Amount
0186	SPV.0060 Special 510. End Diaphragm Adjustment	20.000 EACH	_____.	_____.
0188	SPV.0090 Special 001. Marking Line Epoxy 6-Inch	524.000 LF	_____.	_____.
0190	SPV.0090 Special 002. Construction Staking Concrete Sidewalk	167.000 LF	_____.	_____.
0192	SPV.0090 Special 404. 4-Duct Conduit Cement Encased DB-60	35.000 LF	_____.	_____.
0194	SPV.0105 Special 400. Underdeck Utility Structure P-40-511 City of Milwaukee Communications Condu	LS	LUMP SUM	_____.
Section: 0001			Total:	_____.
			Total Bid:	_____.

**PLEASE ATTACH SCHEDULE OF ITEMS HERE**





## Wisconsin Department of Transportation

---

December 19, 2018

**Division of Transportation Systems  
Development**

Bureau of Project Development  
4802 Sheboygan Avenue, Rm 601  
P O Box 7916  
Madison, WI 53707-7916

Telephone: (608) 266-1631  
Facsimile (FAX): (608) 266-8459

### **NOTICE TO ALL CONTRACTORS:**

#### **ASP-9 Addendum #01**

#### **Letting of January 15, 2019**

Attached is a copy of the revised ASP-9. This ASP-9 combines and replaces ASP-9 and ASP-9-S in all proposals in the January 15, 2019 letting.

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractors.

Sincerely,

*Mike Coleman*

Proposal Development Specialist  
Proposal Management Section

## **ADDITIONAL SPECIAL PROVISION 9**

### **Electronic Certified Payroll or Labor Data Submittal**

(1) Use the department's Civil Rights Compliance System (CRCS) to electronically submit certified payroll reports for contracts with federal funds and labor data for contracts with state funds only. Details are available online through the department's highway construction contractor information (HCCI) site on the Labor, Wages, and EEO Information page at:

<https://wisconsindot.gov/Pages/doing-bus/civil-rights/labornwage/default.aspx>

(2) Ensure that all tiers of subcontractors, including all trucking firms, either submit their weekly certified payroll reports (contracts with federal funds) or labor data (contracts with state funds only) electronically through CRCS. These payrolls or labor data are due within seven calendar days following the close of the payroll period. Every firm providing physical labor towards completing the project is a subcontractor under this special provision.

(3) Upon receipt of contract execution, promptly make all affected firms aware of the requirements under this special provision and arrange for them to receive CRCS training as they are about to begin their submittals. The department will provide training either in a classroom setting at one of our regional offices or by telephone. Contact Paul Ndon at (414) 438-4584 to schedule the training.

(4) The department will reject all paper submittals for information required under this special provision. All costs for conforming to this special provision are incidental to the contract.

(5) Firms wishing to export payroll/labor data from their computer system into CRCS should have their payroll coordinator contact Paul Ndon at [paul.ndon@dot.wi.gov](mailto:paul.ndon@dot.wi.gov). Not every contractor's payroll system is capable of producing export files. For details, see Section 4.8 CPR Auto Submit (Data Mapping) on pages 49-50; 66-71 of the CRCS Payroll Manual at:

<https://wisconsindot.gov/Documents/doing-bus/civil-rights/labornwage/crcs-payroll-manual.pdf>





## Wisconsin Department of Transportation

---

January 8, 2019

**Division of Transportation Systems  
Development**

Bureau of Project Development  
4822 Madison Yards Way, 4<sup>th</sup> Floor South  
Madison, WI 53705

Telephone: (608) 266-1631

Facsimile (FAX): (608) 266-8459

### **NOTICE TO ALL CONTRACTORS:**

**Proposal #15: 2100-00-70**  
**South 35<sup>th</sup> Street**  
**Bridge Over Kinnickinnic River**  
**Local Street**  
**Milwaukee County**

### **Letting of January 15, 2019**

This is Addendum No. 01, which provides for the following:

#### **Special Provisions:**

Revised Special Provisions	
Article No.	Description
6	Utilities

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

*Mike Coleman*

Proposal Development Specialist  
Proposal Management Section

**ADDENDUM NO. 01**  
**PROJECT ID 2100-00-70**  
**January 8, 2019**

**Special Provisions**

**6. Utilities.**

*Replace entire article language with the following:*

This contract does not come under the provision of Administrative Rule Trans 220.

stp-107-066 (20080501)

The City of Milwaukee has notified the department that the following operations necessary for the construction of new facilities and/or adjustment of existing facilities will be coordinated with the contractor's construction operations by each representative utility unless otherwise noted. Coordinate construction activities with a call to Digger's Hotline or a direct call to the utilities that have facilities in the area as required by statutes. Use caution to ensure the integrity of underground facilities and maintain code clearances from overhead facilities at all times.

Note: Bidders are advised to contact each utility company listed in the plans prior to preparing their bid to obtain current information on the status of each utility company's work required in association with the project. Existing trees, street light poles, hydrants and utility poles are to remain in place during construction unless noted on plans. Conduct an on-site visit prior to bidding to determine any special measures required for proper clearance between the trees, hydrants, poles, other utilities and any other physical structures and the construction equipment. During construction operations, keep all manholes accessible to utility companies for emergencies.

**City of Milwaukee – Communications**

Facilities are located within the project limits, including conduits attached to structure P-40-511.

Existing circuits will be moved to cables outside of the project area and impacted cables will be cut and pulled out of the conduits prior to construction. Existing sub-duct within the conduits will be abandoned in place.

Work will be done in October of 2018. No work is proposed during construction.

Contact Bryan M. Pawlak, DPW/Communications at (414) 286-3686 with concerns or questions.

**City of Milwaukee - City Underground Conduit (CUC)**

There is an existing CUC package suspended from the South 35<sup>th</sup> Street Bridge. The removal of the conduit is incidental to the bridge removal. All cables located within the conduit on the bridge will be removed prior to the start of construction.

A new 4-duct conduit package is to be installed suspended from the bridge as shown on the plans and included in the contract. New conduit will be installed by the contractor extending both north and south of the abutments and tied into the existing CUC packages as shown on the plans. There are two existing CUC manholes that will need to be adjusted to grade by the contractor.

All CUC work including conduit installation, sawing concrete encased packages, conduit suspended from the bridge and manhole adjustments are incorporated into the contract documents and shown in the plan set.

Contact Karen Rogney at (414) 286-3243 with concerns or questions.

**City of Milwaukee – Sewers**

Underground facilities are located within the project limits. No work and or adjustments of these facilities are anticipated, in conjunction with this project.

Contact Mr. Zafar Yousuf at (414) 286-2467 with concerns or questions.

**City of Milwaukee - Street Lighting**

Facilities are located within the project limits.

Existing street lighting pole located at Sta 1+75; 36' RT and Sta 3+60, 40' LT will be removed before construction starts. Temporary overhead circuitry will be installed north and east of the bridge over the roadway to keep the remaining street lights working during construction.

During and after construction permanent underground street lighting facilities will be reinstalled.

The street lighting contact below will need to be kept informed on the status of the project to coordinate street lighting work with the bridge contractor.

Contact Mr. Dennis Miller at (414) 286-5942 with concerns or questions.

### **City of Milwaukee - Water Works**

Underground facilities are located within the project limits. No work and or adjustments of these facilities are anticipated, in conjunction with this project.

Contact Mr. Dave Goldapp at (414) 286-6301 with concerns or questions.

### **Milwaukee Metropolitan Sewage District (MMSD)**

Underground facilities are located within the project limits.

MMSD has (6) manholes within the project limits.

Structure BSO601P (3) Manholes: these will not be adjusted, new finished pavement will match existing at approximately Sta 2+26, 4' RT.

Manhole BSO601D: this will not be adjusted, new finished pavement will match existing at approximately Sta 2+21, 3' LT.

Manhole BSO601C: this will not be adjusted, new finished pavement will match existing at approximately Sta 2+27, 19' LT.

Manhole 07707: repair and minor adjustment will be done during construction at approximately Sta 3+64, 3' LT.

MMSD has flow monitoring equipment within the existing MMSD MH No. 07707. The manhole is located in the proposed new bridge approach North. The existing 2" DIA galvanized PVC coated conduit carries instrumentation cable from the MMSD panel which is located at the west side bridge. The conduit traverses below grade from the panel east to and along the west wall of the north abutment and is at grade traversing east below the bridge deck secured to the north abutment wall penetrating through the wall north entering the MMSD manhole No. 07707. Pre-construction bridge rehabilitation MMSD will de-energize power to the flow monitoring equipment, remove the existing instrumentation cable from the panel to the manhole including the removal of the flow monitoring equipment within the manhole. MMSD will remove the vacated 2" DIA PVC conduit from the point of exit at the manhole south leaving a "stub" connection of minimum 24 – inches beyond the south face of the abutment wall for re-connection of the 2" conduit by MMSD upon completion of the proposed bridge rehabilitation. The conduit removal will extend west to a point where it does not present an obstruction to the bridge rehab work the location of which will be determined in the field.

Contact Mr. Larry Anderson at (414) 225-2241 with concerns or questions.

### **Charter/Spectrum**

Overhead facilities are located within the project limits, they will be relocated to the west side of S. 35<sup>th</sup> street prior to construction.

Charter to place temporary 30' class 5 poles at/near Sta 2+42, LT 43.5' and Sta 4+04, LT 44'. Charter will detach existing strand and fiber and reattach to temporary poles. When bridge work is complete, the strand and fiber will be relocated back to the original poles, and the temporary poles will be removed.

Contact Mr. Steve Cramer at (414) 277-4045 with concerns or questions.

### **We Energies - Electric**

Overhead facilities are located within the project limits; they will be relocated to the west side of S. 35<sup>th</sup> street prior to construction.

When working with a crane, load, or load line in the vicinity of overhead electrical facilities, the contractor will be required to maintain a minimum clearance of 20 feet. There are alternatives to the 20-foot minimum clearance, please see Table A of Section 1407-1411 of the OSHA Small Entity Compliance Guide for Final Rule for Cranes and Derricks in Construction.

The We Energies neutral conductor is a multi-grounded neutral conductor and part of a multi-grounded system as defined in the National Electrical Safety Code as adopted and amended by the Wisconsin State

Electrical Code. Because the multi-grounded neutral conductor is visibly grounded at the point of work and also multiple other locations, no specific working clearance is required between the crane or load and the multi-grounded neutral conductor. However, some clearance is to be maintained between the crane or load and the multi-grounded neutral conductor to avoid any physical damage to the conductor or adjacent structures.

If extensive EBS work beyond that shown in the plans is found during construction, the road contractor will inform We Energies of the change in plans so potential conflicts can be resolved.

Contact Mr. Alex Dantinne at (920) 621-6903 with concerns or questions.

### **We Energies – Gas**

Facilities are located within the project limits.

Gas Main is to be discontinued in place at Sta 0+64, 28' RT to Sta 4+69, 26' RT.

Work will be done in October of 2018. No work is proposed during construction.

Contractor may remove the discontinued pipe pursuant to the following:

It is imperative that the highway contractor contact We Energies before removing any gas facilities or electrical underground cables, to verify that they have been discontinued and carry no natural gas or electrical current. The contractor must not assume that unmarked facilities have been discontinued. At no time is it acceptable to push, pull, cut or drill an unmarked facility without explicit consent from We Energies. Contractor must call the We Energies 24 hour Dispatch lines to arrange for this verification.

We Energies Electric Dispatch #1-800-662-4797

We Energies Gas Dispatch #1-800-261-5325

If the line has been verified by We Energies to be dead per the above paragraph, it is the responsibility of the contractor to remove and dispose of all sections of the discontinued facility necessary for them to continue with the project.

Contact Mr. Alex Dantinne at (920) 621-6903 with concerns or questions.

END OF ADDENDUM