

NOTE:

THE LOCATION OF EXISTING AND PROPOSED UTILITIES AS SHOWN ON THE PLANS ARE APPROXIMATE. IN ADDITION, THERE MAY BE OTHER UTILITIES WITHIN THE PROJECT AREA WHICH ARE NOT SHOWN. THE CONTRACTOR SHALL VERIFY THE LOCATIONS OF ALL UTILITIES PRIOR TO CONSTRUCTION.

III -150-6-5-A-4

— LIGHT UNIT NUMBER IN CIRCUIT
— CIRCUIT NUMBER
— BASE TYPE
— MAST ARM LENGTH (in feet)
— LAMP WATTAGE
— DISTRIBUTION TYPE

240 VOLT SYSTEM
120/240 VOLT ELECTRIC SERVICE

LEGEND

LIGHTING CONTROL CABINET TYPE 10 — ○
METER BREAKER PEDESTAL — ■
24" x 36" PULL BOX — ●
2" CONDUIT, NON-METALLIC (UNLESS OTHERWISE NOTED) — ---
250 WATT LUMINAIRE, TYPE 5 POLE, TYPE 5 CONCRETE BASE, SINGLE MEMBER - 4½" CLAMP - 6FT — ●—●
UNDERGROUND ELECTRIC — E —
OVERHEAD LINES — OH —

