

THE LOCATION OF EXISTING AND PROPOSED UTILITIES AS SHOWN ON THE PLANS ARE APPROXIMATE. IN ADDITION, THERE MAY BE OTHER UTILITIES WITHIN THE PROJECT AREA WHICH ARE NOT SHOWN. THE CONTRACTOR SHALL VERIFY THE LOCATIONS OF ALL UTILITIES PRIOR TO CONSTRUCTION.

### LEGEND

LIGHTING CONTROL CABINET WITH METER BREAKER PEDESTAL	
2" CONDUIT, NON-METALLIC (UNLESS OTHERWISE NOTED)	
150 WATT LUMINAIRE, TYPE 5 POLE, TYPE 5 CONCRETE BASE, TRUSS TYPE - 4 1/2" CLAMP - 12FT WITH TRANSFORMER BASE	
PULL BOX 24" X 42"	
POWER POLE	
SERVICE GROUND TRANSFORMER	
ELECTRIC, UNDERGROUND	
ELECTRIC, OVERHEAD	

III -150-12-5-A-4	LIGHT UNIT NUMBER IN CIRCUIT
	CIRCUIT
	BASE TYPE
	MAST ARM LENGTH (In feet)
	LAMP WATTAGE
	DISTRIBUTION TYPE

240 VOLT SYSTEM

Changed to LED A

As-Built 10-4-2010

STH 76 & CTH 0  
TOWN OF ELLINGTON  
OUTAGAMIE COUNTY

LIGHTING NO. 642

DESIGNER: WISDOT NE Region Traffic Unit

DATE: 1-27-2009

SHEET NO. 1 OF 1

PROJECT NO: 6517-07-71

HWY: STH 76

COUNTY: OUTAGAMIE

ROUNDABOUT LIGHTING

L-642

SHEET

E