| | |
|---|---|
| **From:** | Edwards, Brian - DOT |
| **To:** | Kobus, Thomas - DOT |
| **Cc:** | Edwards, Brian - DOT |
| **Subject:** | FW: 4854-03-00 CTH G Fond du Lac County - Stormwater Quality - DES |
| **Date:** | Monday, September 19, 2016 11:04:58 AM |
| **Attachments:** | WisDOT 30% Drainage Report.pdf |

---

As we discussed, please review and provide any necessary comments.


**Brian A. Edwards, P.E.**
Local Program Project Manager
Wisconsin Department of Transportation
NE Region
920-360-2801
wisconsindot.gov


---

**From:** Rich Glen [mailto:richglen@jt-engineering.com]
**Sent:** Monday, September 19, 2016 10:38 AM
**To:** Edwards, Brian - DOT <Brian.Edwards@dot.wi.gov>
**Cc:** NE Local Program <NELP@jt-engineering.com>
**Subject:** FW: 4854-03-00 CTH G Fond du Lac County - Stormwater Quality - DES

Brian,

I looked through this drainage report, but it isn't something that I'm very familiar with. Should we run this by Tom Kobus (since he is the regional storm water engineer) for his review and comment? Otherwise we have some staff that is more up to date on this, but they aren't currently part of the LP contract.

Thanks,


**Rich Glen, P.E.**
**JT Engineering, Inc.** – Project Manager
1077 Centennial Centre Blvd., Hobart, WI 54155-8820
Office: 920.468.4771 | Cell: 920.606.6288 | Fax: 920.468.7135
www.jt-engineering.com

**From:** Peg Hawley [mailto:Peg.Hawley@omnni.com]
**Sent:** Tuesday, September 13, 2016 11:14 AM
**To:** Rich Glen <richglen@jt-engineering.com>
**Cc:** Tom Janke (Tom.Janke@fdlco.wi.gov) <Tom.Janke@fdlco.wi.gov>; NE Local Program <NELP@jt-engineering.com>
**Subject:** 4854-03-00 CTH G Fond du Lac County - Stormwater Quality - DES

Rich,
Attached is the 30% drainage report. We plan to meet the 40% TSS reduction with the use of catch basins along the project. No pond is needed. Please review and let us know if WisDOT has any issues or concerns.
Peg

**MARGARET (PEGGY) HAWLEY, P.E.**
*Project Manager*

OMNNI ASSOCIATES, INC.
ONE SYSTEMS DRIVE, APPLETON, WI 54914
P:920-830-6176 |F:920-830-6100

Check us out on:
Website | Facebook | Twitter

This email is subject to OMNNI Associates, Inc. Electronic File Disclaimer. For full disclaimer see http://www.omnni.org/legal/OMNNI_Email_Disclaimer.pdf